

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/CGHS/SZ/2024/ 487

Dated: 29/07/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Bhartiya CGHS Ltd. Located at Plot No – 04, Sector – 19, Dwarka, New Delhi, having 02 blocks comprised of Basement +Ground/Stilt+ 10 Upper floors was issued FSC by this department vide letter No. F6/DFS/MS/CGHS/2009/3121, dated 29/10/2009. The premise was re inspected by the officer concerned of this department on 20/07/2024 in the presence of. Sh. Rajesh Dahiya (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “Residential Building” Group A-4 with effect from 29/07/2024 for a period of **five years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/07/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service.

Copy to:

1. The President, Bhartiya CGHS Ltd. Located at Plot No – 04, Sector – 19, Dwarka, New Delhi.
2. The Joint Director (Building) DDA, Vikas Sadan, INA, Delhi-110023.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Bhartiya CGHS Ltd. Located at Plot No – 04, Sector – 19, Dwarka, New Delhi.
2. Type of Occupancy : Residential Building “A” (Apartment)
3. Type of Case ; - Renewal 02 Blocks (Basement +Ground/Stilt+ 10 U.Fs)
4. Details of previous NOC : F6/DFS/MS/CGHS/2009/3121, dated 29/10/09
5. Fire Safety directives L. No. : F6/DFS/MS/CGHS/2004/2472 dated 15/10/04
6. Date of inspection : 20/07/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Rajesh Dahiya (Manager)
9. Year of Construction : before 2005
10. Applicant’s letter No. : Email, dated -11/07/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1	Access of building			
	• Road width	9 mtrs	Provided	MR
	• Gate width	5 mtrs	Provided	MR
	• Width of internal road	6 mtrs	5.5m to 6m	MR(Being old case)
2	Number, width, Type & Arrangements of exits			
	a. Number of staircases	2 Nos each block	Provided	MR
	• Upper floors	2 stair + Ramp	Provided	MR
	• Basements			
	b. Width of staircases	1.25 m	125cm& 120cm each block	MR(Being old case)
	• Upper floors	125cm	2x120cm	MR(Being old case)
	• Basements			
	c. Protection of exits	Required in basement	Provided	MR
	• Fire check door	N/A	N/A	N/A
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	1 m	Provided	MR
	f. Door Size			
3	Compartmentation			
	• Fire check door	Required in basement	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	N/A	Natural Ventilation	MR



5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	2 nos. each floor CO ₂ & WCO ₂ ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 each floor 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required N/A N/A	Provided N/A N/A	MR N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100mm 1 each block per floor Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	2 nos each tower Required	Provided Provided	MR MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 900lpm & 180 lpm 40m Required Required	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided Provided Provided Provided	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A MR MR MR MR




14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	2,00000 ltrs	200000ltrs	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25000ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/CGHS/2009/3121, dated 29/10/2009 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved, the FSC may be issued.

Signature of the Inspecting Officer
Name
Designation

[Handwritten Signature]
28/10/2014

[Handwritten Signature]
28/10/2014

CFO(S2)
24/10/2014

Director
[Handwritten Signature]

[Handwritten Signature]