

C-55

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No: F.6/DFS/MS/SCHOOL/2024/ 757

Dated: 02/08/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Blooming Buds Public School**, located at **First & second floor, B-Block, New Moti Nagar, New Delhi – 110015** comprised of { One Block = Ground (**Religious Function**) + 03 Upper floors, owned/occupied by **Blooming Buds Public School**, was issued FSC vide Letter No:- F.6/DFS/MS/School/2021/469 Dated 12/07/2021. The premises was re-inspected by the officer concerned of this department on 18/07/2024 in the presence of Sh. Lav Shukla and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and that the premises is fit for occupancy class "Educational" (Group-B) with effect from 02/08/2024 for a period of three years subject to compliance of the conditions mentioned below.

Issued on 02/08/2024 at New Delhi by.

(Atul Garg)  
Director

Copy to:-

1. To, Lav Shukla, Blooming Buds Public School, B-Block, Moti Nagar, New Delhi-110015.
2. The Director, Director of Education, Old Secretariat, New Delhi-110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good
2. Working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The basement shall be used strictly as per building bye laws.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

1/c  
29/7/2024

## INSPECTION REPORT

1. Name & address of the building	Blooming Buds Public School, located at B Block, New Moti Nagar, New Delhi - 110015.
2. Type of Occupancy	Educational (One Block = Ground Floor Religious Function), 1 <sup>st</sup> & 2 <sup>nd</sup> floors ( for school)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/2021/469 dated 12/07/2021
5. Fire Safety directives letter No	DOE Circular No.-3298-3398 dated 01/03/2011
6. Date of inspection	18/07/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Lav Shukla
9. Year of Construction	1967
10. Applicant's letter No.	Letter No. BBPS/B-37A/April/2024/2934 dated - 18/05/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010/DOE Circular No.-3298-3398 dated 01/03/2011	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	7m Provided	MR
	• Gate width	Accessible	On Road	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	01	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts	1 x 92cm (up to 3 <sup>rd</sup> floor) 1 x 154cm (up to 1 <sup>st</sup> floor) 1 x 108cm (up to 2 <sup>nd</sup> floor)	MR (being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5m Required	160cm Provided	MR
	g. Door Size	1 mts	101cm Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

Sx

g

2/15				
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	07 Nos. CO <sub>2</sub> , ABC type ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>			
		NA	NA	NA
9	<b>Public Address System.</b>			
		NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

		r/l/6		
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
15	Exit Signage.	5,000 ltrs	Provided	MR
		Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/2021/469 dated 12/07/2021, renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

190/ADO/MN  
22/07/2024

*(Signature)*

*(Signature)*  
22/7/2024

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

DCFO ..... 11/6/24  
Dated..... 22/7/2024

*(Signature)*  
22/7/2024  
CFO  
*(Signature)*  
25/7/2024  
Director  
*(Signature)*  
22/07/24

*(Signature)*