



No. F6/DFS/MS/School/NDZ/2024/ 746

Dated: 01/08/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Lovely Public English School, located at A-Block, Yojna Vihar, Delhi – 110092** building comprised **ground plus two upper floors** owned/occupied by **Lovely Public English School** was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2021/NDZ/487 dated 15/07/2021. The School building was re-inspected by the officer concerned of this department on 19.07.2024 in presence of Mrs. Sunita Dhingra (Manager) and observed that all the fire prevention and fire safety requirements provided in the premises found in good working condition. The premises have therefore deemed complied with the Fire Prevention and Fire Safety requirements in accordance with Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education and that the building is fit for occupancy class **“Educational Building” (Group-B)** with effect from 01/08/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to conditions printed below.

Issued on 01/08/2024 at New Delhi by.

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

**Copy to:-**

1. The Director of Education, D-Block, Anand Vihar, Delhi -
2. The Manager, Lovely Public English School, located at A-Block, Yojna Vihar, Delhi – 110092.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/12

**INSPECTION REPORT**

1	Name & address of the building	Lovely Public English School, located at A-Block, Yojan Vihar, Delhi - 110092.		
2	Building is comprised of	Ground plus two upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2021/NDZ/487 dated 15/07/2021.		
6	Fire safety directives letter no.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
7	Date of inspection	19.07.2024.		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mrs.Sunita Dhingra (Manager)		
10	Year of construction	1996		
11	Applicant's letter no.	Outdoor Dairy No. 3855 dated 08/07/2024		
S.No	Minimum standard of fire safety requirements as per circular no.262-362 dated 17.01.2005	Circular Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
A	Road width	6.0 mtrs.	6.0 mtrs.	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	01 no.	02 nos.	MR
c	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.5 mtrs	1.50 mtrs & 1.30 mtrs	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	02 no.	02 no.	MR
E	Width of corridor	1.50 mtrs.	1.50 mtrs.	MR
F	Door size	1.0 mtrs.	1.0 mtrs.	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

w

5. Fire Extinguisher:				
A	Total numbers	06 nos.	08 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	01 no	Provided	MR
B	Length of hose reel hose	30 mtrs	Provided	MR
C	Nozzle diameter	5 mm	Provided	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	N/A	N/A
9	Public Address System:	N/A	N/A	N/A
10 Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	N/A	100 mtres	MR
B	Number of hydrants per floor	N/A	01 no	MR
C	Hose box	N/A	01 no	MR
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump	450 LPM	Provided	MR
B	Head of the pump	40 m	Provided	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

Lovely Public English School, located at A-Block, Yojan Vihar, Delhi - 110092

(4)

✓

N/12

N/13


Lovely Public English School, located at A-Block, Yojan Vihar, Delhi - 110092.

<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>			
	<b>A</b>	Underground tank capacity	N/A	N/A
	<b>B</b>	Draw-off connection	N/A	N/A
	<b>C</b>	Fire service inlet	N/A	N/A
	<b>D</b>	Access to tank	N/A	N/A
	<b>E</b>	Overhead tank capacity	10,000 liters	Provided ✓ MR
<b>15</b>	<b>Exit Signage:</b>		Required	Provided ✓ MR
<b>16</b>	<b>Provision of Lifts:</b>			
	<b>A</b>	Pressurization of lift shaft	N/A	N/A
	<b>B</b>	Pressurization of lift lobby	N/A	N/A
	<b>C</b>	Communication in lift car	N/A	N/A
	<b>D</b>	Firemen's grounding switch	N/A	N/A
	<b>E</b>	Lift signage	N/A	N/A
<b>17</b>	<b>Standby Power Supply:</b>			
<b>18</b>	<b>Refuge Area:</b>			
	<b>A</b>	Total area	N/A	N/A
	<b>B</b>	Location	N/A	N/A
<b>19</b>	<b>Fire Control Room:</b>			
	<b>A</b>	Detector system panel	N/A	N/A
	<b>B</b>	Flow switch panel	N/A	N/A
	<b>C</b>	PA system panel	N/A	N/A
	<b>D</b>	Battery backup	N/A	N/A
	<b>E</b>	Building floor plans	N/A	N/A
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2021/NDZ/487 dated 15/07/2021 under the Circular no F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 is recommended to be renewed.

No file is pending with me before disposal of this case.



22/7/2024

Signature of the Inspecting Officer

Name: - Yashwant Singh Meena

Designation: - ADO (L.N)

~~DY.CFO (NDZ)~~

Imp  
24/07/24

C.F.O.

25/7/2024

Director  
26/7/24

Sir, F.T Letter is put up for sign. Please

Director  
27/7/24

30/7/2024