

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2024/School/WZ/ 745

Dated: 01/08/2024

FIRE SAFETY CERTIFICATE

Certified that the MaxFort School, Zone H-4 & 5, Parwana Road, Pitampura, Delhi-110034, comprised of Ground + 03 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2021/768 dated 22.09.2021. The premises was re-inspected by the officer concerned of this department on 19.07.2024 in the presence of Mr. Manoj Ahuja (Officer In charge) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with NBC/Circular 262-362 dated 17.01.2005 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 01/08/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/08/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, MaxFort School, Zone H-4 & 5, Parwana Road, Pitampura, Delhi-0110034.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	MaxFort School, Zone H-4 & 5, Parwana Road, Pitampura, Delhi-110034.			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal (Ground + 03 upper floors)			
4. Details of Previous NOC	F.6/DFS/MS/School/WZ/2021/768 dated 22.09.2021.			
5. Fire Safety directives letter No	F.6/DFS/Ms/BP/2004/431 dated 23.02.2004.			
6. Date of inspection	19.07.2024			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Mr. Manoj Ahuja (Officer In charge)			
9. Year of Construction	2005			
10. Applicant's letter No.	OD No.2815 dated 11.06.2024.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per guideline/DOE cir. 2005/letter dated 15.11.2018	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03nos.	Provided	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	2 x 1.5m	2 X 1.5 & 1.4m	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	02nos.	Provided	MR
	e. Width of Corridor	1.5m	2.3m	MR
	f. Door Size	1.0m	Provided (including door frame)	MR
3.	Compartmentation			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers			
	a) Total numbers	1 nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	01nos.	Provided	MR

	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	100mm	Provided	MR
	b) Number of hydrants per floor	01nos.	Provided	MR
	c) Hose Box	01nos.	Provided	MR
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm & 180lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	50,000ltr	Provided	MR
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-

	e) Lift Signage	-NA-	-NA-	-NA-
	Standby power supply	-NA-	Provided	-NA-
18.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no **F.6/DFS/MS/School/WZ/2021/768** dated **22.09.2021** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay Kumar Sharma
 Signature of the Inspecting Officer
 Name **Ajay Kumar Sharma**
 Designation **ADO(Rohini)**

DO(N/W)

Ajay
 24/07/2024

By cfo (wz)

DCFO. 2-12...A/12
 Dated. 24/07/24.

Ajay
 24/7

CFO
 25/7/2024

Director
 26/7/24
Ajay Kumar

FF letter is put up for kind perusal and signature please.

Director
 26/7/24

Ajay Kumar
 25/7/24