

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2024/SZ/ 748

Dated: 01/08/2024

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya, Kair, New Delhi-110043, comprised of ground floor only having total 19 rooms (Including Class rooms, Office, Labs, Library, Sports Room, Staff Room etc.) owned/occupied by Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/SZ/2021/581 dated 05.08.2021 was re-inspected by the officer concerned of this department on 26.07.2024 in the presence of Mrs. Meenu Singh (Principal) and found that Sarvodaya Kanya Vidyalaya have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as below.

Issued on 01/08/2024 at New Delhi.


 (Atul Garg)
 Director
 Delhi Fire Service

Copy to:-

1. The Principal, Sarvodaya Kanya Vidyalaya, Kair, New Delhi-110043
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.

N/22

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, Kair, New Delhi-110043.
2. Building Comprised of : Ground floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/SZ/2021/581 dated 05.08.2021
6. Fire Safety directives letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
7. Date of inspection : 26.07.2024
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Mrs. Meenu Singh (Principal)
10. Year of Construction : 1972
11. Applicant's letter No. : Online email Id ecircular4@gmail.com dated 24.07.2024

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Requirement as per FSC dt. 05.08.2021 | Provided at site | Remarks MR/NMR |
|--------|---|---|--|---------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | Accessible (06 mtrs) 4.5 mtrs N/A | Provided Directly accessible from road N/A | MR MR N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | N/A | N/A | Ground floor only |
| | <ul style="list-style-type: none"> Upper Floors Basements | N/A | N/A | N/A |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor Basements | N/A | N/A | Ground floor only |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door Pressurization | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | d. No. of continuous staircases to terrace | N/A | N/A | N/A |
| | e. Width of Corridor | N/A | N/A | N/A |
| | f. Door Size | 100 cms | 100 & 97 cms (Double door) few single door 107 cms | M/R, being old case |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> Basements | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Upper floors | N/A | N/A | N/A |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 05 no's ABC/CO ₂ type ISI marked | Provided Provided ISI marked | M/R M/R M/R |

g

h

N/23

| | | | | |
|-----|--|-----------|-----|-----|
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 15. | Exit Signage. | N/A | N/A | N/A |
| 16. | Provision of Lifts. | (No Lift) | | |

N/24

N/A
N/A
4

| | | | | |
|-----|---|-----|-----|-----|
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 17. | Standby power supply | N/A | N/A | N/A |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/SZ/2021/581 dated 05.08.2021, renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

R.K. Yadav
29/7/2024
Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (South West)
[Signature]
29/7/24

CFD (S2)
[Signature]
29/7/2024

Director
[Signature]
30/07/24

ADO (JKP)