



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ/ 246

Dated: 01/08/2024

FIRE SAFETY CERTIFICATE

Certified that M/s **Caffé Tonino** (A unit of Pyramids) at Unit No. IN25-A, International Departure, Security Hold Area, IGI Airport, New Delhi-110037, building comprised of Two-Tier Basement, Ground & Five Upper Floors, but the restaurant running at 2nd floor only, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2021/SZ/198 dated 26/08/2021. The said premise was re-inspected by the officer concerned of this department on 23/07/2024 in the presence of Mr. Sanjay Yadav (Restt. Manager) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said premises is fit for occupancy class "Assembly Group D" (Eating House) with effect from the date of issue of this certificate for a period upto 31/03/2027 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/08/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of Police (Lic.), 1st Floor, Police Station Defence Colony, New Delhi-110049 (w.r.t. MHA ID No. 2024071210935 dated 12/07/2024)
2. Authorized Signatory M/s Caffé Tonino (A unit of Pyramids) at Unit No. IN25-A, International Departure, Security Hold Area, IGI Airport, New Delhi-110037

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

N-8

INSPECTION REPORT

1.	Name & address of the building	M/s Caffé Tonino (A unit of Pyramids), Unit No. IN25-A, International Departure, Security Hold Area, IGI Airport, New Delhi-110037		
2.	Type of Occupancy	Assembly (Restaurant at 2 nd Floor only)		
3.	Building Comprised of	Two Tier Basement, Ground + 5 Upper Floors,		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/2021/SZ/198 dated 26/08/2021		
6.	Fire Safety directives letter No.	Nil		
7.	Date of inspection	23/07/2024		
8.	Name of Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from building side	Mr. Sanjay Yadav (Restt. Manager)		
10.	Year of Construction	2010		
11.	Applicant letter No. / Online MHA	ID No. 2024071210935 dated 12/07/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building (T-3 Bldg. FSC No. F6/DFS/MS/SZ/2023/602 dated 18/12/2023)			
	• Road width	Restaurant within T-3	As above	MR
	• Gate width	Building	As above	MR
	• Width of internal road		As above	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	Provided & Maintained by T-3 Bldg. Mgmt.		
	• Upper floors	Restt. within T-3	3 Nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases	Provided & Maintained by T-3 Bldg. Mgmt.		
	• Upper floors	Restt. within T-3	1.5m (each)	MR
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Restt. within T-3	As above	MR
	• Pressurization	Restt. within T-3	As above	MR
	d. No of continuous staircase to terrace	Restt. within T-3	As above	MR
	e. Width of Corridor	Restt. within T-3	As above	MR
	f. Door Size	Required	Open area round the clock	MR
3.	Compartmentation	Provided & Maintained by T-3 Bldg. Mgmt.		
	• Fire check door	Restt. within T-3	As above	MR
	• Sealing of electrical shafts	Restt. within T-3	As above	MR
	• Fire Rating of shaft door	Restt. within T-3	As above	MR
	• Water Curtain	Restt. within T-3	As above	NA
	• Fire Dampers	Restt. within T-3	As above	MR
4.	Smoke managements System	Provided & Maintained by T-3 Bldg. Mgmt.		
	• Basements	NA	NA	NA
	• Upper floors	Restt. within T-3	As above	MR
5.	Fire Extinguishers			
	• Total numbers	ISI marked	04 Nos	MR
	• Types		ABC & CO ₂	MR
	• ISI marking		Provided	MR
6.	First-Aid Hose Reels	Provided & Maintained by T-3 Bldg. Mgmt.		
	• Total numbers on each floor	Hose-reel	3 Nos	MR
	• Length of hose reel hose		30m	MR
	• Nozzle diameter		5mm	MR

N-9

7.	Automatic fire detection and alarming system. Provided & Maintained by T-3 Bldg. Mgmt.			
	• Type of detector	Restt. within T-3	Smoke & Heat	MR
	• Location of Main Panel	Restt. within T-3	Upper Basement	MR
	• Location of Repeater Panel	Restt. within T-3	Provided	MR
	• Alternate source of power	Restt. within T-3	Provided	MR
	• Hooters' Location	Restt. within T-3	All Areas	MR
8.	MOEFA	Restt. within T-3	Provided	MR
9	Public Address System	Restt. within T-3	As above	MR
10	Automatic Sprinkler System			
	• Basements	Restt. within T-3	As above	NA
	• Upper floors	Restt. within T-3	As above	MR
	• Sprinkler above false ceiling	Restt. within T-3	As above	NA
11	Internal Hydrants			
	• Size of riser/down-comer	Restt. within T-3	As above	MR
	• Number of hydrants per floor	Restt. within T-3	As above	MR
	• Hose Box	Restt. within T-3	As above	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	As above	NA
	• Hose Box	NA	As above	NA
13	Pumping Arrangements			
	• Ground Level	Provided & Maintained by T-3 Bldg. Mgmt.		
	➤ Discharge of main pump	Restt. within T-3	4731 & 3785 LPM	MR
	➤ Head of main pump	Restt. within T-3	130m & 70m	MR
	➤ Number of main pumps	Restt. within T-3	Two (1 + 1)	MR
	➤ Jockey pump out put	Restt. within T-3	280 LPM x 2	MR
	➤ Jockey pump head	Restt. within T-3	130m & 80m	MR
	➤ Standby Pump out put	Restt. within T-3	4731 & 3785 LPM	MR
	➤ Standby Pump Head	Restt. within T-3	130m & 70m	MR
	➤ Auto Starting/Manual stopping	Restt. within T-3	Provided	MR
	➤ Pump House Access	Restt. within T-3	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Underground tank capacity	Restt. within T-3	As above	MR
	➤ Draw of connection	Restt. within T-3	As above	MR
	➤ Fire service inlet	Restt. within T-3	As above	MR
	➤ Access to tank	Restt. within T-3	As above	MR
	• Overhead Tank capacity	Restt. within T-3	As above	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Restt. within T-3	As above	MR
	➤ Pressurization of lift lobby	Restt. within T-3	As above	MR
	➤ Communication in lift Car	Restt. within T-3	As above	MR
	➤ Fireman's Grounding Switch	Restt. within T-3	As above	MR
	➤ Lift Signage	Restt. within T-3	As above	MR
17.	Standby power supply	Restt. within T-3	As above	MR
18.	Refuge Area			
	➤ Total area	Restt. within T-3	As above	MR
	➤ Location	Restt. within T-3	As above	MR

MR

7

N-10

19.	Fire control room	Provided & Maintained by T-3 Bldg. Mgmt.		
		Restt. within T-3	As above	MR
	> Detector system panel	Restt. within T-3	As above	MR
	> Flow Switch Panel	Restt. within T-3	As above	MR
	> PA System Panel	Restt. within T-3	As above	MR
	> Battery backup	Restt. within T-3	As above	MR
	> Building Floor Plans	Restt. within T-3	As above	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Restt. within T-3	As above	MR

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/2021/SZ/198 dated 26/08/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Santosh Kumar
24/07/24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

meel
27/7/24

cf
25/07/2024

Director
26/07/24
ADP (SJ)

Sir,

F.T letter is put up for your kind pl

Director
24/07/24

uploaded
1/8/24

Santosh Kumar
29/07/24