

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No.F.6/DFS/MS/School/2024/SZ/ 764

Dated: 06/08/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls/Boys Sr. Sec. School, Shiv Vihar, New Delhi-110059 comprised of three blocks namely A-Block, B-Block & C-Block having ground plus one upper floor & New building block (SPS) comprised of ground plus three upper floors owned/occupied by Govt. Girls/Boys Sr. Sec. School was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2021/SZ/282 dated 01.04.2021. The school building was re-inspected by the officer concerned of this department on 26.07.2024 in the presence of Smt. Suman Sharma (Principal) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of Delhi Fire Service Rules 2010 and that the building/premises is fit for occupancy "Educational Building" for with effect from .06./08./2024 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on ..06./08./2024.. at New Delhi.


 (Atul Garg)
 Director
 Delhi Fire Service

Copy to:-

1. The Principal, Govt. Girls/Boys Sr. Sec. School, Shiv Vihar, New Delhi-110059
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.

Following fire safety directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

26

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Sr. Sec. School, Shiv Vihar, New Delhi-110059
2. Building comprised of : 3 blocks A, B & C each blocks having ground plus one upper floor
New building namely SPS block G+3 Upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2021/SZ/282 dated 01.04.2021
6. Fire Safety directives letter No : N/A
7. Date of inspection : 26.07.2024
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Smt. Suman Sharma (Principal)
10. Year of Construction : Block A & B in 2004, Block C in 2015 and Block D in 2017-18
11. Applicant's letter No. : Online email Id ggsssv2013@gmail.com dated 04.07.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	Provided Provided N/A	MR M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 no.'s in A & C Blk 01 no. in B blk & 1 no. of SPS blk N/A	02 no.s's in A,B & C blk & 1 no. of SPS blk provided N/A	MR, old case N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 m & .75 m N/A	1.41 & 1.62 m in A blk, 1.27 & 1.56 m in B blk 1.50 & 1.50 m in C blk 1 no. of 1.85 m in SPS blk N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	1 No.	One in each block	MR
	e. Width of Corridor	1.50 M	1.57, 1.58 & 1.77 m in A, B & C & 1.85 in SPS blk respectively	MR
	f. Door Size	1.0 M	1.01 & .97 m A Blk, 1.14 & 1.0 m B blk, 1.07 & 1.0 m C blk & 1.05 double door in SPS blk	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N/A Required	N/A Natural Ventilation provided	N/A MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	30 No's ABC/CO ₂ type ISI marked	Provided Provided ISI marked	MR MR MR

6.	First-Aid Hose Reels in SPS Block			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 No. 30 m 05 mm	Provided	MR
			Provided	MR
			Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements in SPS Block			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A 450 LPM 40 M Required Required	N/A Provided Provided Provided Provided	N/A MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity in SPS Block 	N/A N/A N/A N/A 10,000 ltrs	N/A N/A N/A N/A Provided	N/A N/A N/A N/A MR
15.	Exit Signage.	Required	Provided	MR

N/28

16. Provision of Lifts.		(No Lift)		
16.	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18. Refuge Area.				
	> Total Area	N/A	N/A	N/A
	> Location	N/A	N/A	N/A
19. Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcoming was already issued vide letter no. F6/DFS/MS/EH//SZ/2024/264 dated 21.05.2024 has been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2021/SZ/282 dated 01.04.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R. K. Yadav
29/7/2024

Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (South West)

AK
31/07/24

CFO (S2)
11/08/2024
Director

ADG/24/1