

C44

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2024/SZ/ 763

Dated: 06/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Sarvodaya Bal Vidyalaya No. 1**, at Tilak Nagar, New Delhi-110018, having 04 blocks namely- Main building blk comprised of ground plus two upper floors, Primary blk comprised of ground plus one upper floor, Auditorium blk comprised of ground floor only and New blk comprised of ground plus three upper floors, owned/occupied by Govt. Sarvodaya Bal Vidyalaya was issued FSC by this department vide letter no. F.6/DFS/MS/School/2021/SZ/423 dated 02.07.2021 (only for New Blk). The School building was re- inspected by the officer concerned of this department on 26.07.2024 in the presence of Sh. K.L. Surela (Principal) and found that the School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule-33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "**Educational**" w.e.f 06/08/24 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 06/08/2024 at New Delhi.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Principal, Govt. Sarvodaya Bal Vidyalaya No. 1, at Tilak Nagar, New Delhi-110018.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Following fire safety directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/26

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Bal Vidyalaya No.-1, Tilak Nagar, New Delhi-110018.
2. Building Comprised of : 04 blocks namely Main Building Block, Primary Block, Auditorium Block & New block Main Building Block having ground plus two upper floor, Primary block is having ground plus one upper floor, Auditorium block is having ground floor only and New block having ground plus three upper floors.
3. Type of Occupancy : Educational
4. Type of Case : New/renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2021/SZ/423 dated 02.07.2021 (only for New Blk)
6. Fire Safety directives letter No : N/A
7. Date of inspection : 26.07.2024
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. K.L. Surela (Principal)
10. Year of Construction : 1981 (main building block), Before 2010 & 2020 (New Block)
11. Applicant's letter No. : SBV/No.-1/TN/2024/274 dated 26.06.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	09 mtrs 05 mtrs N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 no.'s each in M blk & P blk N/A	Provided N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms/additional staircase of 75 cms if less than 150 cms N/A	165 & 155 cms in P blk & 134 (02 no.'s), 160 & 140 cms in MB Blk & 180 cms (02 nos.) in New blk N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	M/R
	e. Width of Corridor	150 cms.	150 cms in P blk & 236 in MB blk & 1.60 m in New blk	M/R
	f. Door Size	100 cms in Class rooms & 200 cms in MP Hall	105 & 98 cms in P Blk & 100 cms (Double door) in MB blk & 100 cms (03 no's) in Adt. Blk & 130 cms in New blk	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	Fire Extinguishers			

N/27

	<ul style="list-style-type: none"> Total numbers Types IS marking 	35 no's ABC/CO ₂ type ISI marked	Provided	M/R
			Provided	M/R
			Provided	M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	One each in MB blk, Adt. Blk & new blk	Provided	M/R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 mtrs	Provided	M/R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM in MB blk, Adt. Blk & New blk	450 LPM (03 no.'s) provided	MR
		40 mtrs	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10000 ltrs in MB blk, 5000 ltrs in Adt. Blk & 10,000 ltr in New blk	10000 ltrs in MB blk, 5000 ltrs in Adt. Blk & 10,000 ltr in New blk	MR
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			No Lift

N/28

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcoming was already issued vide letter no. F6/DFS/MS/EH/SZ/2024/310 dated 07.06.2024 has been Complied.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2021/SZ/423 dated 02.07.2021 (only for New Blk) renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
 30/7/2024
 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

Divisional Officer (South West)
[Signature]
 31/8/24

CPD (S2)
[Signature]
 01/01/2024

Director
[Signature]
 9/8/24

[Signature]
 ADO/JKP