

C-30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 729

Dated: 29/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **New Delhi Public School, A-Block, Vikaspuri, New Delhi-110018**, comprised of ground floor plus three upper floors, owned/occupied by New Delhi Public School was issued FSC by this department vide letter no. F.6/DFS/MS/school/2021/SZ/410 dated 28.06.2021. The School building was re-inspected by the officer concerned of this department on 16.07.2024 in the presence of Sh. Naresh Sharma (Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. 29/07/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 29/07/2024 at New Delhi.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Principal, New Delhi Public School, A-Block, Vikaspuri, New Delhi-110018.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

M/14

INSPECTION REPORT

1. Name & address of the building : New Delhi Public School, A-Block, Vikaspuri, New Delhi-18.
2. Building is comprised of : **Ground plus three upper Floors**
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/school/2021/SZ/410 dated 28.06.2021
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 16.07.2024
8. Name of the Inspecting Officers: : ADO R.K. YADAV
9. Name of the designation of Officer
from the building side : Sh. Naresh Sharma (Manager)
10. Year of Construction : 2003-2004
11. Applicant's letter No : Online email Id abcfiresystems@hotmail.com dated 24.06.2024

S. No.	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	06 m	06 m	MR
	Gate width	4.5 mtrs.	4.5 mtrs.	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases Upper Floor Basement	03 no.	03 no.	MR
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
	B. Width of Staircases Upper Floor Basement	1.50 m	1.60,1.60 &1.70 m	MR
		N.A.	N.A.	N.A.
	c. Protection of exits Fire check door Pressurization	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		01 no.	01 no.	MR
	e. No. of continuous staircases to terrace	1.50 m	2.15 & 2.10 m	MR
	g. Width of Corridor	1.0 m	1.12 m	MR
h. Door Size				
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Natural Ventilation	MR

15

h

N/15


5.	Fire Extinguisher			
	Total numbers	16 Nos.	16 Nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 Nos.	Provided	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	Provided	MR
	Number of hydrants per floor	01Nos.	Provided	MR
	Hose Box	01Nos.	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump			
	➤ Head of the Pump	450 & 180 LPM	450 & 180 LPM	MR
	➤ Power supply	40 m	40 m	MR
	➤ Auto Starting of pump	Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	50,000 ltrs	MR
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	Two way	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10,000 ltrs	30,000 ltrs	N.A.

MIG





15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire prevention and Fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/school/2021/SZ/410 dated 28.06.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 22/7/2024
 Signature of the Inspecting Officer
 Name- R.K. Yadav
 Designation- ADO (JKP)

DO (South West)


 22/7/24
 CPO(S2)

 23/7/2024
 Director



PTO