

c36

FORM 'II'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2024/School/733

Dated: 30/07/2024

FIRE SAFETY CERTIFICATE

Certified that the building New Era Public School Located at Pochanpur Sector – 24, Phase-II Dwarka, New Delhi – 110077 having two blocks, A block comprised of Ground + One Upper Floor, & B- block comprised of Basement + ground + 01 Upper floor was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/2021/638 dated 24/08/2021. The premises was re inspected by the officer concerned of this department on 19/07/2024 in the presence of Sh. Arvind Sharma (Maintenance In charge) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 and that the building is fit for occupancy class B “Educational building” with effect from 30/07/2024 for a period of **three years**, subject to compliance of the condition printed as under.

Issued on 30/07/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service.

Copy to:

1. The Principal, New Era Public School, Pochanpur Sector – 24, Phase-II Dwarka, New Delhi – 110077
2. The, Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: New Era Public School Located at Pochanpur Sector – 24, Phase-II Dwarka, New Delhi – 110077
2. Type of Occupancy : Educational Two Blocks, A- blocks= Ground + One Upper Floor, & B- block= Basement + ground + 01 Upper floor
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2021/638 dated 24/08/2021
5. Fire Safety directives Letter No. : . Circular. No 3298-3398 Dated 01/03/2011
6. Date of inspection : 19/07/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Arvind Sharma (Maintenance Incharge)
9. Year of Construction : 2011
10. Applicant's letter No. : Email Dated - 29/06/2024

No. of Students=550
No. of class rooms=26
Plot area=20234m ²
Covered area=6280m ²

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/12, N/13 & N/14	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	09 mtr	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos.	04 Nos.	MR
	• Basements	02 Nos.	02 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr	2 x 1.45 mtr & 2x1.44 mtr (including railing)	MR (Being Old case)
	• Basements	1.5 mtr	2x142cm(including railing)	MR (Being Old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5 mtr	Provided	MR
	f. Door Size	01 mtr	100 cm(including door frame)	MR, old Case
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Exhaust fan provided	MR
	• Upper floors	NA	Natural ventilation	NA

Handwritten signature/initials

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	01 nos.ABC & CO ₂ for every 300 sq. mtrs ISI marked	08 nos each floor Provided ISI marked	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	03 Nos. 30 mtr 05 mm	03 Nos. 30 mtr 05 mm	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	NA NA NA	100 mm 03 Nos. Provided	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA NA	02 Nos. Provided	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➢ Head of main pump ➢ Number of main pumps ➢ Jockey pump out put ➢ Jockey pump head ➢ Standby Pump out put ➢ Standby Pump Head ➢ Auto Staring/Manual stopping ➢ Pump House Access • Terrace level ➢ Discharge of pump ➢ Head of the pump ➢ Power supply ➢ Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA
		450 lpm & 180 lpm	450 lpm & 180 lpm	MR
		30 mtr	30 mtr	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➢ Draw off connection ➢ Fire service inlet ➢ Access to tank • Overhead Tank capacity 	NA NA NA NA	NA NA NA NA	NA NA NA NA
15	Exit Signage	5,000 ltr	12,000 ltr	MR (Old case)
		NA	NA	NA

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F.6/DFS/MS/2021/638 dated 24/08/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note :- Two pumps of 450 lpm connected with a underground water tank are also found provided.

Signature of the Inspecting Officer
 Name: *Uday Vir Singh*
 Designation: *AO/SD/24*

[Signature] 23/2/24

CFO (S2) *[Signature]*
 21/7/2024

Director *[Signature]*
 05/01/24

[Signature]