

C-35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No.F.6/DFS/MS/School/2024/SZ/726

Dated: 29/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **Royal Indian Public School**, D-55 A, Sita Puri Part-I, Street No.-17, Dabri Palam Road, New Delhi-110045, running at ground plus two upper floors only of a building comprised of ground plus three upper floors, owned/occupied by Royal Indian Public School was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2021/328 dated 16.04.2021. The School building was re- inspected by the officer concerned of this department on 22.07.2024 in the presence of Sh. Ravinder Kumar (Manager) and found that the School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule-33 of the Delhi Fire Service Rules, 2010 and that the building/ premises **(ground plus two upper floors only)** is fit for occupancy class "**Educational**" w.e.f 29/07/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 29/07/2024 at New Delhi.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Manager, Royal Indian Public School, D-55 A, Sita Puri Part-I, Street No.-17, Dabri Palam Road, New Delhi-110045.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

Following fire safety directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/18

INSPECTION REPORT

1. Name & address of the building : Royal Indian Public School, D-55 A, Sita Puri Part-I, Street No.-17, Dabri Palam Road, New Delhi-110045.
2. Type of Occupancy : Educational
3. Building Comprised of : Ground plus three upper floors, but school running at G+2 floors only
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2021/328 dated 16.04.2021
6. Fire Safety directives letter No : N/A
7. Date of inspection : 22.07.2024
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Ravinder Kumar (Manager)
10. Year of Construction : 2004-05
11. Applicant's letter No. : Online email Id royalindian2005@gamil.com dated 21.06.2024

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Requirement as per FSC dt. 16.04.2021 | Provided at site | Remarks MR/NMR |
|--------|---|--|--|----------------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | Accessible 4.5 mtrs N/A | 05 & 4.5 mtrs Directly accessible from road N/A | M/R, being old case MR N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | 02 No.'s N/A | 02 No.'s N/A | M/R N/A |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floor • Basements | 150 cms/additional staircase of 75 cms if less than 150 cms N/A | 150 & 100-80 cms N/A | M/R N/A |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | N/A N/A | N/A N/A | N/A N/A |
| | d. No. of continuous staircases to terrace | Required | One | M/R |
| | e. Width of Corridor | 150 cms | 350, 230 & 120 cms | M/R |
| | f. Door Size | 100 cms | 100 to 90 cms | M/R, being old case |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | N/A Required | N/A Natural ventilation provided | N/A M/R |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | 08 no's ABC/CO ₂ type ISI marked | Provided Provided Provided | MR MR MR |

| | | | | | |
|-----|--|-------------------------------|----------|----------|----|
| 6. | First-Aid Hose Reels | | | | |
| | | • Total numbers on each floor | One | Provided | MR |
| | | • Length of hose reel hose | 30 mtrs | Provided | MR |
| | | • Nozzle diameter | 5 mm | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | | |
| | • Type of detectors | N/A | N/A | N/A | |
| | • Location of Main Panel | N/A | N/A | N/A | |
| | • Location of Repeater Panel | N/A | N/A | N/A | |
| | • Alternate source of power | N/A | N/A | N/A | |
| | • Hooters' Location | N/A | N/A | N/A | |
| 8. | MOEFA | N/A | N/A | N/A | |
| 9. | Public Address System | N/A | Provided | N/A | |
| 10. | Automatic Sprinkler System | | | | |
| | • Basement | N/A | N/A | N/A | |
| | • Ground Floor | N/A | N/A | N/A | |
| | • Sprinkler above false ceiling | N/A | N/A | N/A | |
| 11. | Internal Hydrants | | | | |
| | • Size of down-comer for HR | N/A | Provided | N/A | |
| | • Number of hydrants per floor | N/A | N/A | N/A | |
| | • Hose Box | N/A | N/A | N/A | |
| 12. | Yard Hydrants | | | | |
| | • Total number of hydrants | N/A | N/A | N/A | |
| | • Hose Box | N/A | N/A | N/A | |
| 13. | Pumping Arrangements | | | | |
| | • Ground Level > Discharge of main Pump > Head of Main pump > Number of main pumps > Jockey Pump out put > Jockey pump head > Standby Pump out put > Standby Pump Head > Auto Starting/Manual Stopping | | | | |
| | | N/A | N/A | N/A | |
| | | N/A | N/A | N/A | |
| | | N/A | N/A | N/A | |
| | | N/A | N/A | N/A | |
| | | N/A | N/A | N/A | |
| | | N/A | N/A | N/A | |
| | • Pump House Access • Terrace level > Discharge of pump > Head of the pump > Power Supply > Auto Starting of pump | | | | |
| | | N/A | N/A | N/A | |
| | | N/A | N/A | N/A | |
| | | 450 LPM | Provided | MR | |
| | | 40 mtrs | Provided | MR | |
| | Required | Provided | MR | | |
| | N/A | N/A | N/A | | |
| 14. | Captive Water Storage for fire fighting | | | | |
| | • Underground tank capacity | | | | |
| | > Draw-off connection | N/A | N/A | N/A | |
| | > Fire service inlet | N/A | N/A | N/A | |
| | > Access to tank | Required | Provided | MR | |
| | • Overhead Tank capacity | N/A | N/A | MR | |
| | | 10,000 ltrs | Provided | N/A | |
| 15. | Exit Signage. | | | MR | |
| 16. | Provision of Lifts. | Required | Provided | MR | |

No Lift

N/20

| | | | | |
|-----|---|-----|-----|-----|
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 17. | Standby power supply | N/A | N/A | N/A |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2021/328 dated 16.04.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note: - as per affidavit submit by school management (Placed at C- 31) the school running at ground plus two upper floors only and two rooms at third floor used for guard and manager personal room.

R.K. Yadav
22/2/2024

Signature of the Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (South West)

W/
25/2/24

CFO (S2)

Vugh
26/4/2024

Director

W/
26/9/24
W