



No. F6/DFS/MS/School/NDZ/2024/ 766

Dated: 06/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **Salwan Public School Located at Kondli Gharouli Complex, Mayur Vihar, Phase-III, Delhi-110096**, building comprised of **ground plus four upper floors** owned/occupied by **Salwan Public School**, was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2021/628 dated 23/03/2021. The School building was re-inspected by the officer concerned of this department on 23/07/2024 in presence of Mr. Maj. Gen. Ajay Khandpur VSM (Retd.) (Director) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class **“Educational Building” (Group-B)** ground + 4 upper floors only with effect from 06/08/2024 for a period of **three years**, in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below

Issued on 06/08/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE
(u)

Copy to:-

1. The Dy. Director of Education, D-Block, Anand Vihar, Delhi-110091.
2. The Principal, Salwan Public School Located at Kondli Gharouli Complex, Mayur Vihar, Phase-III, Delhi-110096.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any..
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

01.	Name & address of the building	Salwan Public School Located at Kondli Gharouli Complex, Mayur Vihar, Phase-III, Delhi-110096.
02.	Building is comprised of	Ground plus + 04 upper floors
03.	Type of occupancy	Educational Building
04.	Type of case	Renewal
05.	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/628 dated 23/08/2021.
06.	Fire safety directives letter no.	F.16/DFS/MS/2005/478 dated 04/03/2005.
07.	Date of inspection	23/07/2024
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)
09.	Name of the designation of officer from the building side	Mr. Maj. Gen. Ajay Khandpur VSM (Retd.) (Director)
10.	Year of construction	2004
11.	Applicant's letter no.	Outdoor Diary no.4239 dated 16/07/2024

S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
A	Road width	12 mtrs.	15 mtrs. ✓	MR
B	Gate width	4.5 mtrs	4.5 mtrs ✓	MR
C	Width of internal road	6 mtrs	6 mtrs ✓	MR
02.	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	02 nos.	02 nos. ✓	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	1.50 mtrs	1.50 mtrs, 1.70mtrs ✓	MR
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	01 no	02 nos ✓	MR
E	Width of corridor	1.50 mtrs.	02 mtrs. ✓	MR
F	Door size	01 mtr	01 mtr ✓	MR
03.	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	Required	Provided	MR
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
04.	Smoke Management System:			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA


05.	Fire Extinguisher:				
	A	Total numbers	20 nos.	20 nos.	MR
	B	Types	ABC/CO ₂	ABC/CO ₂	MR
	C	ISI marking	ISI marked	ISI marked	MR
06.	First-Aid-Hose Reel:				
	A	Total numbers of each floor	02 nos	02 nos	MR
	B	Length of hose reel hose	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	05 mm	05 mm	MR
07.	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
08.	MOEFA:		N/A	Provided	MR
09	Public Address System:		N/A	Provided	MR
10.	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	100 mm	MR
	B	Number of hydrants per floor	N/A	02 nos	MR
	C	Hose box	N/A	02 nos	MR
12.	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13.	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM	450 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

14. Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	60,000 liters	MR
B	Draw-off connection	N/A	Provided	MR
C	Fire service inlet	N/A	Provided	MR
D	Access to tank	N/A	Provided	MR
E	Overhead tank capacity	10,000 liters	10,000 liters	MR
15. Exit Signage:		Required	Provided	MR
16. Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17. Standby Power Supply:		N/A	Provided	MR
18. Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19. Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20. Special Fire Protection systems for protection of special Risks, if any:				N/A




The fire protection systems provided in the school building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the compliance of minimum standards of fire prevention and fire safety measures required as required under the rules the FSC issued vide letter no. F6/DFS/MS/School/NDZ/2021/628 dated 23/08/2021, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case.


 26/7/2024

Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (L.N)

~~DY. CFO/NDZ~~

 29/07/24
 C.F.O.

 31/07/2024
 Director

 11/07/24


 ADO/LN