

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F.6/DFS/MS/Indl./2024/SZ/ 498

Dated : ...02.../08.../2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Industrial building** in the Name & Style of **M/s Supreme Impex** located at S-59, Okhla, Industrial Area, Phase-II, New Delhi-110020 comprised of Basement, Ground plus Three upper floors was issued FSC by this department vide letter no F6/DFS/MS/Indl./SZ/2021/356 Dated 26/07/2021. The Premise was re-inspected by the officer concerned of this department on 25/07/2024 in the presence of Mr. Kamla Parshad and found that said Industrial building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and found that the said building / premises is fit for occupancy class G "**Industrial Building**" with effect from 02/08/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/08/2024 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:

1. M/s Supreme Impex Industrial building at S-59, Okhla, Industrial Area, Phase-II, New Delhi-110020.
2. The Executive Engineer (Bldg Department), Central Zone Jal Vihar Lajpat Nagar, New Delhi 110024.

**Conditions for the validity of the safety certificate:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
4. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
5. Basement shall be used strictly as per Building Bye Laws.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & Address of the Building	M/s Supreme Impex, at S- 59, Okhla Industrial Area, Ph- II, New Delhi -110020		
2	Type of Occupancy	Industrial Building		
3	Building Comprised of	Basement, Ground + Three Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Indl./SZ/2021/356 Dated 26/07/2021		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	25/07/2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Kamla Parshad		
10	Year of construction	1986		
11	Applicant letter No.	Outdoor diary no 4280 dated 18/07/2024		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/ NBC requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	14 mtr Required N/A	Provided 5 mtr N/A	MR MR N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	1. Upper floors	2 No's	Provided	MR
	2. Basement floor	2 No's	Provided	MR
	b. Width of Staircase			
	1. Upper floors	1.50 m	1.50m & 0.90m	MR (old case)
	2. Basement floor	1.50 m	1.50m & 0.90m	MR (old case)
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	Required Required N/A N/A N/A	Provided Provided N/A N/A N/A	MR MR N/A N/A N/A
4	Smoke Management system.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	30 ACPH 12 ACPH	Exhaust Fan provided Natural ventilation	M/R M/R
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	17 ABC / Co2 ISI Marked	Provided Provided Provided	MR MR MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	01 at each floor 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic Fire Detection & Alarming System.			
			Provided	MR

	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	NA	N/A	NA
		Required	Provided at GF	MR
		NA	N/A	NA
		Required	Battery backup	MR
		All area	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System		Provided	MR
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors (on 2<sup>nd</sup> floor)</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		Required	Provided	N/A
		N/A	N/A	
11.	Internal Hydrants.		Provided	MR
	<ul style="list-style-type: none"> <li>Size of Riser / Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	100 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12.	Yard Hydrants.		N/A	N/A
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting / Manual Stopping.</li> <li>Pump House Access</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace Level</li> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul>	900 LPM	900 LPM	MR
		40 mtr	Provided	MR
		Required	Provided (DG Set)	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> <li>Overhead tank capacity.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		10,000 Ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	NMR
16.	Provision of Lifts.		Good lift provided	
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room.			
	<ul style="list-style-type: none"> <li>Detector System Panel.</li> </ul>	Required	Provided	MR

N/17

	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Indl./SZ/2021/356 Dated 26/07/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*AK*  
26/7/21

*Manoj*  
Signature of the Inspection Officer  
Name: Sh. Manoj Kumar Sharma  
Design: DO (South)

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

CFO (HQ)  
*Wagle*  
29/7/2021

*Director*  
*AK*  
29/7/21  
ADO/BCP

As approved, f.s. letter is put up for your signature P1  
*AK*  
30/7/21

*Director*  
11/8/21