

e-85

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/EH/2024/ 239

Dated : 25/07/2024

FIRE SAFETY CERTIFICATE

Certified that The 'W' Restaurant (A Unit of Wingflow Construction Pvt. Ltd) located at G-68, 1st Floor, Outer Circle, Connaught Place, New Delhi-110001 in a building is comprised of ground floor + 03 upper floors, Restaurant running at 1st floor only, was earlier granted FSC by this department vide letter No.F6/DFS/MS/EH/2021/127 dated 09/07/2021. Now, the premises was re-inspected by the officers concerned of this department on 11/07/24 in the presence of Sh. Rajesh Kumar Singh, Manager and found that the said restaurant premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said restaurant premises is fit for occupancy class **Assembly Building (Group D) - Restaurant at 1st floor only** and valid up to the period of three year from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 25/07/2024 at New Delhi by.


(Ajul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect , NDMC, Palika Kendra , New Delhi
2. The Dy. Commissioner of Police (Lic), 1st floor, PS Defence Colony, New Delhi ID NO. 2024070210318 dated 02.07.24.
3. The Manager, The 'W' Restaurant (A Unit of Wingflow Construction Pvt. Ltd) located at G-68, 1st Floor, Outer Circle, Connaught Place, New Delhi-110001.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is valid only for restaurant at first floor only .
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned. Basement shall not be used for any purpose.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

2/20

1. Name & address of the building The 'W' Restaurant (A Unit of wingflow construction pvt. Ltd) located at G-68, First floor, Outer Circle, Connaught Place, New Delhi. (Gr. + 3 upper floors)
2. Type of occupancy:- Assembly Building Group-D
(Restaurant at 1st floor only)
3. Type of case:- Renewal
4. Details of previous FSC:- No.F6/DFS/MS/EH/2021/127 dated 09/07/2021
5. Fire safety directives No.- N/A
6. Date of inspection:- 11/07/24
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD) &
Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Rajesh Kumar Singh, Manager
9. Year of construction:- 1977(old heritage)
10. Applicant's letter No:- Online id 2024070210318 dated 02.07.24.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR (
1.	Access to Building			
	1) Road width	6.0mtr	6.0 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02nos	02 nos	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 mtr. &1.25 mtr.	0.80 mtr. &1.25 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR

✓ 62

		21/24	Required	Provided	MR
	3) ISI marking				
6.	First-Aid Hose Reel				
	1) Total number of each floor	01	01	MR	
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR	
	3) Nozzle diameter	05 mm	05 mm	MR	
7.	Automatic Fire Detection & Alarming System				
	1) Type of detectors	Required	Provided	MR	
	2) Location of main panel (1 st floor)	Required	Provided	MR	
	3) Location of repeater panel	N/A	N/A	N/A	
	4) Alternate source of power	Required	Provided	MR	
	5) Hooter's Location	Required	Provided	MR	
8.	MOEFA	N/A	N/A	N/A	
9.	Public Address System	N/A	N/A	N/A	
10.	Automatic Sprinkler System				
	1) Basement	N/A	N/A	N/A	
	2) Upper floors	Required	Provided	MR	
	3) Sprinkler above false ceiling	N/A	N/A	N/A	
11.	Internal Hydrants				
	1) Size of riser/down-comer	N/A	100mm	N/A	
	2) Number of hydrants per floor	N/A	01 nos	N/A	
	3) Hose box	N/A	provided	N/A	
12.	Yard Hydrants				
	1) Total number of hydrants	N/A	N/A	N/A	
	2) Hose box	N/A	N/A	N/A	
13.	Pumping Arrangement				
	1) Ground level	N/A	N/A	N/A	
	a) Discharge of main pump	N/A	N/A	N/A	
	b) Head of main pump	N/A	N/A	N/A	
	c) Number of main pump	N/A	N/A	N/A	
	d) Jockey pump out put	N/A	N/A	N/A	
	e) Jockey pump head	N/A	N/A	N/A	
	f) Stand by pump output	N/A	N/A	N/A	
	g) Stand by pump head	N/A	N/A	N/A	
	h) Auto starting/Manual stopping	N/A	N/A	N/A	
	2) Terrace level	Required	provided	MR	
	a) Discharge of pump	450 LPM&180 LPM	450 LPM&180 LPM	MR	
	b) Head of pump	30 mtr.	30 mtr.	MR	
	c) Power supply	Required	provided	MR	
	d) Auto starting of pump	Required	provided	MR	
14.	Captive Water Storage for Fire Fighting				
	1) Under ground tank capacity	N/A	N/A	N/A	
	a) Draw-off connection	N/A	N/A	N/A	
	b) Fire service inlet	N/A	N/A	N/A	

N

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 ltr.	5,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the restaurant were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/EH/2021/127 dated 09/07/2021, under rule 35(6) of the Delhi Fire Service rules 2010. Accordingly, reply letter prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

[Handwritten Signature]

Name:- Rajinder Atwal
Designation:-DO(CD)

[Handwritten Signature]
Dy. C.F.O. (MS-2)

[Handwritten Signature]
C.F.O.
24/07/2022

[Handwritten Signature]
Director

[Handwritten Signature]
As approved, it is put up for kind perusal and
Reply in Pleas.

[Handwritten Signature]

Signature of the Inspecting Officer

[Handwritten Signature]

Name:- Ravinder Singh
Designation:- ADO (CC)

[Handwritten Signature]
18/07/21

uploaded
26/7

[Handwritten Signature]
23/07/21