



No.F6/DFS/MS/School/SZ/2024/ 774

Dated: 08/08/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Lakshay Bharti School located at Block E-10, 16 & 17, Aali Vihar, New Delhi-76, comprised of Basement (Vacant) + Upper Ground + 02 upper floors, owned & occupied by M/s Lakshay Bharti School have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concerned of Delhi Fire Service on 06.08.2024 in the presence of Mrs. Usha Paneshwar (Manager) and found that the building/premises Basement (Vacant) + Upper Ground + 02 upper floors is fit for occupancy of Group B "Educational Building" with effect from 08/08/2024.... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 08/08/2024 at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, 15<sup>th</sup> floor, Dr. SPM Civic Centre, Minto Road, New Delhi-110002.
2. The Principal, M/s Lakshay Bharti School located at Block E-10, 16 & AALI Vihar, New Delhi-76.

**Conditions for the validity of Fire Safety Certificate:-**

1. Basement shall be used as per NBC/UBBL-2016 & circular no. DE.23(399)/Sch.Br./2024/572 dated 31.07.2024 issued by the Directorate of Education.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

2/20 2/4

## INSPECTION REPORT

1	Name & address of the building	M/s Lakshay Bharti School located at Block E-10, 16 & 17, Aali Vihar, New Delhi-76.				
2	Building is comprised of	Basement (Vacant) + Upper Ground + 02 upper floors				
3	Type of occupancy	Group B- Educational Building (School)				
4	Type of case	New Case				
5	Details of previous NOC	Nil				
6	Fire safety direction letter no.	UBBL & NBC -2016				
7	Date of inspection	06.08.2024				
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M.Road)				
9	Name of the designation of officer from the building side	Mrs. Usha Paneshwar (Manager)				
10	Year of construction	2008				
11	Applicant's letter no.	Outdoor diary no. 2476 dated 04.06.2024				
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per UBBL/NBC	Provided at site	Remarks MR/NMR		
1.	<b>Access to Building:</b>					
	A	Road width	6.0 mtrs.	Provided	MR	
	B	Gate width	NA	NA	NA	
	C	Width of internal road	NA	NA	NA	
2.	<b>Number, Width, Type and Arrangement of Exits:</b>					
	A	Number of staircases				
		a	Upper floor	2 nos.	2 nos.	MR
		b	Basement	2 nos.	2 nos.	MR
	B	Width of staircases				
		a	Upper floor	* 1.50 m & 0.75 m (As per order no. F6/DFS/MS/2011/293 dated 15.02.2011)	1.60 m to 1.75 m & 1.09 m	MR
		b	Basement	* 1.50 m & 0.75 m (As per order no. F6/DFS/MS/2011/293 dated 15.02.2011)	2.0 m & 1.09 m	MR
	C	Protection of exits				
		a	Fire check door	NA	NA	NA
		b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	01 no.	Provided		MR
	E	Width of corridor	1.50 m	2.50 m		MR
	F	Door size	1.0 mtrs (for class room)	Provided		MR
3.	<b>Compartmentation:</b>					
	A	Fire check door	NA	NA	NA	
	B	Sealing of electrical shafts	NA	NA	NA	
	C	Fire rating of shaft door	NA	NA	NA	
	D	Water curtain	NA	NA	NA	
	E	Fire dampers	NA	NA	NA	
4.	<b>Smoke Management System:</b>					
	A	Basement	NA	NA	NA	
	B	Upper floor	NA	NA	NA	
5.	<b>Fire Extinguisher:</b>					
	A	Total numbers	08 nos.	10 no.	MR	
	B	Types	CO <sub>2</sub> & ABC	Provided	MR	
	C	ISI marking	Required	Provided	MR	

<b>6</b>	<b>First-Aid-Hose Reel:</b>				
	<b>A</b>	Total numbers of each floor	01 no.	01 no.	MR
	<b>B</b>	Length of hose reel hose	30 mtrs	30 mtrs	MR
	<b>C</b>	Nozzle diameter	5 mm	5 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>				
	<b>A</b>	Type of detectors	NA	NA	NA
	<b>B</b>	Location of main panel	NA	NA	NA
	<b>C</b>	Location of repeater panel	NA	NA	NA
	<b>D</b>	Alternate source of power	NA	NA	NA
	<b>E</b>	Hooters	NA	NA	NA
<b>8</b>	<b>MOEFA:</b>		NA	NA	NA
<b>9</b>	<b>Public Address System:</b>		NA	NA	NA
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement (Area more than 200 m <sup>2</sup> )	Required	Provided	MR
	<b>B</b>	Upper floor	NA	NA	NA
	<b>C</b>	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	Size of riser/down-comer	NA	NA	NA
	<b>B</b>	Number of hydrants per floor	NA	NA	NA
	<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	NA	NA	NA
	<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>				
	<b>A Ground level</b>				
	<b>a</b>	Discharge of main pump	NA	NA	NA
	<b>b</b>	Head of main pump	NA	NA	NA
	<b>c</b>	Number of main pumps	NA	NA	NA
	<b>d</b>	Jockey pump out put	NA	NA	NA
	<b>e</b>	Jockey pump head	NA	NA	NA
	<b>f</b>	Standby pump out put	NA	NA	NA
	<b>g</b>	Standby pump head	NA	NA	NA
	<b>h</b>	Auto starting /manual stopping	NA	NA	NA
	<b>i</b>	Pump house access	NA	NA	NA
	<b>B Terrace Level</b>				
	<b>a</b>	Discharge of pump	900 LPM	2 nos. of 450 LPM	MR
	<b>b</b>	Head of the pump	40 mtrs	Provided	MR
	<b>c</b>	Power supply	Required	Provided	MR
	<b>d</b>	Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>				
	<b>A</b>	Underground tank capacity	NA	NA	NA
	<b>B</b>	Draw-off connection	NA	NA	NA
	<b>C</b>	Fire service inlet	NA	NA	NA
	<b>D</b>	Access to tank	NA	NA	NA
	<b>E</b>	Overhead tank capacity	15,000 liters	15,000 liters	MR
<b>15</b>	<b>Exit Signage:</b>		Required	Not provided	MR

✓

<b>16</b>	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply:</b>	NA	NA	NA
<b>18</b>	<b>Refuge Area:</b>			
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
<b>19</b>	<b>Fire Control Room:</b>			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	NA		

**LEGENDS: Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**

**\*Note:-** The requirement of staircase width is as per order no. F6/DFS/MS/2011/293 dated 15.02.2011 place on file on C/7.

The shortcomings issued to the building by this department vide letter no. F6/DFS/MS/School/SZ/2024/263 dated 21.05.2024 has been rectified by the school management.

If agreed to note above & in view the substantial deemed compliance of the minimum standards on fire prevention and fire safety required under the Rules, it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer  
 Name Rajesh Kumar Shukla  
 Designation ADO (M. Road)

DO (SD)

Mehal  
 07/8/24

CFO  
 7/8/2024

Director

7/8/24

mu