



No. F6/DFS/MS/School/NDZ/2024/ 783

Dated: 09/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **Bharti Adarsh Vidya Public School** running on ground + 1st floor only building comprised of ground plus three upper floors, second and third floor not in use as per affidavit given by the owner 16/07/2024, located at **Village - Kondli, Pandit Mohalla, Delhi - 110096**, owned/occupied by **Bharti Adarsh Vidya Public School**, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2008/2100 dated 24.07.2008. The School building was re-inspected by the officer concerned of this department on 23/07/2024 in presence of Mr. Sunil Kumar (Manager) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular letter No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building"** ground plus first floor only with effect from 09/08/2024 for a period of **three years**, in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 09/08/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, D - Block, Anand Vihar, Delhi-110091.
2. The Principal, Bharti Adarsh Vidya Public School located at Village - Kondli, Pandit Mohalla, Delhi - 110096.

Conditions for the validity of Fire Safety Certificate

1. **Fire Safety Certificate is valid for ground plus one upper floor only.**
2. **Second and third floor shall not be used (as per affidavit dated 16.07.2024) for any purpose.**
3. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
4. All the means of escape shall be kept free of all the type of obstruction all the time.
5. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
6. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
7. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
8. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/134

INSPECTION REPORT

1	Name & address of the building	Bharti Adarsh Vidya Public School located at Village - Kondli, Pandit Mohalla, Delhi - 110096.
2	Building is comprised of	Ground plus three floors. (School running on Ground + 01 floor only)
3	Type of occupancy	Educational Building
4	Type of case	Renewal
5	Details of previous FSC	F.6/DFS/MS/2008/2100 dated 24.07.2008
6	Fire safety directives letter no.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011
7	Date of inspection	23.07.2024
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)
9	Name of the designation of officer from the building side	Mr. Sunil Kumar (Manager)
10	Year of construction	2003
11	Applicant's letter no.	Outdoor Diary No.4223 dated 16/07/2024

S.No	Minimum standard of fire safety requirements as per circular no.3298 to 3398 dated 01/03/2011	Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 mtrs.	3.0 mtrs.	MR (Old Case)
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	01 nos.	02 nos.	MR
c	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 mtrs	01 mtrs & 0.55 mtrs (up to 1 st F)	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 nos.	01 nos.	MR
E	Width of corridor	1.5 mtrs.	1.5 mtrs.	MR
F	Door size	1.0 mtrs.	1.0 mtrs.	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

W

4/15

Parti Adarsh Vidya Public School located at Village-Kondli, Pandit Mohalla, Delhi-110096.

5.	Fire Extinguisher:				
	A	Total numbers	04 nos.	08 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 m	30 m	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	Provided	MR
9	Public Address System:		N/A	Provided	MR
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	220 LPM	220 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

W


✓

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	2500 liters	2500 liters	MR
		Required	Provided	MR
15	Exit Signage:			
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:			
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/2014/NDZ/844 dated 03/04/2014 by this department have been rectified by the management.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F.6/DFS/MS/2008/2100 dated 24.07.2008 under the Circular no F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 is recommended to be renewed.

No file is pending with me before disposal of this case.


 5/8/2024
 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (L.N)

~~DY.CFO (NDZ)~~

Handwritten signature

~~C.F.O.~~

6/8/2024

~~Director~~

Handwritten signature

P-T-O