



No. F6/DFS/MS/WZ/2023/296

Dated:- 20/06/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Anil Filling Station, Located at A-Block, Community Centre, Paschim Vihar, New Delhi-110063, owned / occupied by M/s Anil Filling Station was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/2019/CNG/1983 Dated 16.10.2019 (for CNG Pump) & F6/DFS/MS/2019/1982 dated 16.10.2019 (For Petrol Pump). The said premise was re-inspected by the officer concerned of this department on 24.05.2023 in the presence of Sh. Anil Kumar (Proprietor) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Hazardous Building" Group – J (CNG Pump & Petrol Pump) with effect from 20/06/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 20/06/2023 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service *Q. D. C.*

Copy to :-

1. Sh. Anil Kumar, M/s. Anil Filling Station, A-Block, Community Centre, Paschim Vihar, New Delhi-110063.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of authorized construction or alteration (Clause of 1.4.3 of UBBL-2016), if any.
6. Work under procurement/installation mentioned in the undertaking shall be complied before the commencement of the plant. The same shall be get inspected from OISD under intimation to this department.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	M/s Anil Filling Station, A-Block, Community Centre, Paschim Vihar, New Delhi-110063		
2	Type of Occupancy	Hazardous "Group- "J" (CNG Station) & (Petrol Pump)		
3	Type of Case	Renewal		
4	Details of Previous NOC	F6/DFS/MS/2019/CNG/1983 dated 16.10.2019 (For CNG) F6/DFS/MS/2019/1982 dated 16.10.2019 (For Petrol Pump)		
5	Fire Safety Directives Letter No	NBC (Part-IV)/OISD 179		
6	Date of Inspection	24.05.2023		
7	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (JWP)		
8	Name & Designation of Officers from the building side	Sh. Anil Kumar (Proprietor)		
9	Year of construction	2014		
10	Applicant letter No.	nil dated nil		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC-IV/OISD Requirements/as per FSC dated 16.10.2019	Provided at Site	Remarks NR/NMR
1	Access to Building.			
	• Road width	6 m	30 m	MR
	• Gate width	-N/A-	-N/A-	-N/A-
	• Width of internal road	-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	-N/A-	-N/A-	-N/A-
	➤ Basement floor.	-N/A-	-N/A-	-N/A-
	b) Width of Staircase			
	➤ Upper floors	-N/A-	-N/A-	-N/A-
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	-N/A-	-N/A-	-N/A-
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	01 m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-N/A-	-N/A-	-N/A-
	• Sealing of electrical shafts.	-N/A-	-N/A-	-N/A-
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	-N/A-	-N/A-	-N/A-
4.	Smoke Management system.			
	• Basement	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
5.	Fire Extinguishers.			
	• Total numbers	14 Nos.	17 Nos.	MR
	• Types	Foam, CO ₂ & ABC	Provided.	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	-N/A-	-N/A-	-N/A-
	• Length of hose-reel hose.	-N/A-	-N/A-	-N/A-

	• Nozzle Diameter	-N/A-	-N/A-	-N/A-
7	Automatic fire detection & alarming system.			
	• Type of detectors	Hand Held explosive Meter/Detector	Provided	MR
	• Location of Main Panel	-N/A-	-N/A-	-N/A-
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	-N/A-	-N/A-	-N/A-
	• Hooter's location	-N/A-	-N/A-	-N/A-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	CO₂ flooding system			
	• Ground Floor.	Required in compressor area	Provided	MR
	• Upper floors	-N/A-	-N/A-	-N/A-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	-N/A-	-N/A-	-N/A-
	• Number of Hydrant per floor	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
12.	Yard Hydrants.			
	• Total number of hydrants.	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	• Ground Level			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• Terrace Level			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	-N/A-	-N/A-
	➤ Power supply.	-N/A-	-N/A-	-N/A-
	➤ Auto starting of pump.	-N/A-	-N/A-	-N/A-
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	-N/A-	-N/A-	-N/A-
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-N/A-	-N/A-	-N/A-
	• Pressurization of lift lobby.	-N/A-	-N/A-	-N/A-
	• Communication in lift car.	-N/A-	-N/A-	-N/A-
	• Fireman's switch.	-N/A-	-N/A-	-N/A-

	• Lift signage.	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	N/A-	N/A-	N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	DCP flooding system for roof mounted cascades		Provided MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In View of the deemed compliance of the minimum standards of fire prevention and fire safety requirements under the rules, renewal of FSC issued vide letter no. F6/DFS/MS/2019/CNG/1983 dated 16.10.2019 (For CNG) & F6/DFS/MS/2019/1982 dated 16.10.2019 (For Petrol Pump) is recommended under the rule 37 of the Delhi Fire Service rule, 2010 under the DFS Act 2009.

Accordingly DFA is put up for approval and signature please.

DCFO (S)/MKC

Aman Kumar Lathar
09/06/23
ADO (JWP)

DCFO/639
Dated 09/06/2023

[Signature]
09/06/2023

CFO
[Signature]
12/6/2023
Director
[Signature]
12/06/23

How SWP
Sir, F.T. letter is put-up for your signature pl.
Director
[Signature]
09/06/23
And QWP?