

C-40



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**




No. F6/DFS/MS/2024/School/ 807

Dated: 19/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **B.M. Gange Girls Senior Secondary School** located at **21, Raj Niwas Marg, Delhi-110054** comprised of **05 blocks (01 Block comprised of Ground + first floor & 04 Blocks, comprised of Single storey only)** owned/ occupied by **B.M. Gange Girls Senior Secondary School** was issued Fire Safety Certificated by this department vide letter no. **F6/DFS/MS/2021/682 Dated: 31.08.2021**. The premises was inspected by the officer concerned of this department on **07.08.2024** in presence of **Mrs. Sanjana Lamington (Incharge)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class **Group B Educational** with effect from**19/08/2024**.. for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ...**19/08/2024**..... at New Delhi by.


(Atul Garg)
Director
Ph:-011-23414000
ofc Garg

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Incharge, B.M. Gange Girls Senior Secondary School located at 21, Raj Niwas Marg, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : B.M. Gange Girls Sr. Sec. School at 21, Raj Niwas Marg, Delhi-110054.
2. Type of Occupancy : Educational
3. Composition of building : Ground First floor only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2021/682 Dated: 31.08.2021
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
7. Date of inspection : 07.08.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mrs. Sanjana Lamington (Incharge)
10. Year of Construction : Old
11. Applicant's letter No. : Letter No-Nil & DFS Dairy No-4276 Dated- 18.07.2024


	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education circular dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	20m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m & 1.25m	Provided	MR (being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
e. Width of Corridor	NA	NA	NA	
f. Door Size	01m	01m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	14nos	19nos	MR
	• Types	ABC/CO2	ABC—15/Co2-02 Water Co2-02	MR
	• ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			


		N/A	01	NA
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	30m	NA
		NA	05mm	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	220 LPM	NA
		NA	30m	NA
		N/A	Provided	N/A
		N/A	Provided	N/A
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	2500 LTR	NA

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.



Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2021/682 Dated: 31.08.2021.


 Signature of the Inspecting Officer
 Name :-C.L. Meena
 Designation:- ADO/RN

DO/NW

 09/08/2024

By CFO (W2)


 10/8

CFO

 Director

 13/08/2024



LCPD/213
 Date: 10/8/2024