

637

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**

No. F.6/DFS/MS/School/2024/SZ/ 802

Dated: 19/08/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Boys Sr. Sec. School No. 1 (1515006), Rajouri Garden (Extn.), New Delhi-110027, comprised of two blocks namely A-Block & B-Block. Each block is having ground plus one upper floor, owned/occupied by Govt. of Delhi, was issued Fire Safety Certificate by this department vide letter No .6/DFS/MS/School/2021/SZ/658 dated 27.08.2021 (for name of SKV). The school building was re- inspected by the officer concerned of this department on 09.08.2024 in the presence of Sh. Parmanand Jha (HOS) and found that the School Building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on 19/08/2024 at New Delhi.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The HOS, Govt. Boys Sr. Sec. School No. 1 (1515006), Rajouri Garden (Extn.), New Delhi-110027.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.

**Following fire safety directives must be adhered to: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building : Govt. Boys Sr. Sec. School No. 1, Rajouri Garden (Extn.), New Delhi-27.
2. Building comprised of : Two blocks, namely A-Block & B-Block, each block are comprised of Ground plus one upper floor only.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2021/SZ/658 dated 27.08.2021 (for name of SKV)
6. Fire Safety directives letter No : N/A
7. Date of inspection : 09.08.2024
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers  
From the building side : Sh. Parmanand Jha (HOS)
10. Year of Construction : 2013
11. Applicant's letter No. : GBSSS No-1/RGE/2024/207 dated 11.07.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible 06 m 4.5 m N/A	Provided 05 & 4.6 m N/A	MR M/R N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02 Nos at each blk	06 no.'s in block A 03 No's in Block-B	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	1.50 & 0.75 m	1.45 (06 no.'s) in A blk & 1.45 (03 no.'s), in B blk	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.50 m	1.75 m	MR
	f. Door Size	1.0 m	1.0-1.05 m (Double door) few including door frame)	MR
3.	<b>Compartmentation</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural Ventilation provided	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	20 No's ABC/CO <sub>2</sub> type ISI marked	Provided	MR
	• Types		Provided	MR
	• IS marking		ISI marked	MR
6.	<b>First-Aid Hose Reels</b>			
	<b>Provided at New Block</b>			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A

N/18

7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>		<b>Provided at New Block</b>	
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14.	<b>Captive Water Storage for fire-fighting</b>		<b>Provided at New Block</b>	
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	<b>Provision of Lifts.</b>		<b>(No Lift)</b>	
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

AS

W


N/O

17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note:- Earlier FSC issued by this department vide letter No. F.6/DFS/MS/School/2021/SZ/658 dated 27.08.2021 for name of Sarvodaya Kanya Vidyalaya (1515021). That time this building was being use for double sift schools and the building incharge was HOS, SKV, Rajouri Garden Extn, New Delhi- 110027. But now constructed new building of G+3 upper floors and some area of B-Block added in this building. After the bifurcation of school between 1515006 (Govt. Boys Sr. Sec. School No. 1) and 1515021 (SKV) from Delhi Govt. this building was handed over to this school by Sarvodaya Kanya Vidyalaya, Rajouri Garden Extn. New Delhi- 27 (FSC already issued vide letter No. F.6/DFS/MS/School/2022/SZ/515 dated 12.05.2022)

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2021/SZ/658 dated 27.08.2021 (for name of SKV), renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

  
 Signature of Inspecting Officer  
 Name: - R.K. Yadav  
 Designation: - ADO (JKP)

DO (South/West) 