

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2024/SZ/ 819

Dated: 20/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **Green Valley International School** at 205, Deepak Vihar, Najafgarh, New Delhi-110043, comprised of ground plus three upper floors, owned/occupied by Green Valley International School was issued Fire Safety Certificate by this department vide letter No F6/DFS/MS/School/2021/SZ/304 Dated 05.04.2021. The school building was re-inspected by the officer concerned of this department on dated 07.08.2024 in the presence of Sh. Omprakash Sharma (Manager) and found that the School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule-33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "**Educational**" w.e.f. 20/08/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 20/08/2024 at New Delhi.


(Atul Garg)
 Director
 Delhi Fire Service

Copy to:-

1. The Chairman, Green Valley International School at 205, Deepak Vihar, Najafgarh, New Delhi-110043.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.
3. Executive Engineer (Bldg.), MCD office, Dhansa Stand, Najafgarh, New Delhi- 43.

Conditions for the validity of fire safety certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Green Valley International School, 205, Deepak Vihar, Najafgarh, New Delhi-110043.
2. Building is comprised of : G+3 upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/School/2021/SZ/304 Dated 05.04.2021
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 07.08.2024
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer:
From the building side : Sh. Om Parkash Sharma (Manager)
10. Year of Construction : 2002-03 & 2015
11. Applicant's letter No : GVIPS/FC/2024 dated 23.07.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R33	BBL & NBC Part-IV	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m.	7 M	MR
	• Gate width	4.5 m	4.80 & 1.15 m	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	03 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 m each	1.60, 1.60 & 1.28 m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02No.	02 No.	MR
	e. Width of Corridor	1.5 m.	1.90 m.	MR
	f. Door Size	1.0 m.	1.0 m.	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	16 nos.	16 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	IS I marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	02 Nos.	02 Nos.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity			
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	10,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR

17/23

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings were already issued vide letter no. F6/DFS/MS/School/SZ/2024/358 dated 26.06.2024 have been complied.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F6/DFS/MS/School/2021/SZ/304 Dated 05.04.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note: - As per undertaking given by the Manager (placed at C- 35) that swimming pool is the part of sport complex of this school and fully equipped with lifesaving items. All precautions are taken for safety and security of swimmers are per procedure laid down. FSC issued for only school building (ground plus three upper floors) and not for swimming pool.

R.K. Yada
 Signature of the Inspecting Officer
 Name- R.K. YADAV
 Designation- ADO (JKP)

DO (South West)
[Signature]
 9/8/24

CFO (S2)
[Signature]
 12/8/24

Director
[Signature]
 13/8/24

Ado JKP