



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 806

Dated: 19/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **MCD Primary School No. 3/1** (School ID: 1757424) at Kapashera. New Delhi-110037, comprised of ground plus one upper floor only was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2021/SZ/401 dated 23/06/2021. The said premises was re-inspected by the officer concerned of this department on 09/08/2024 in the presence of Ms. Narinder Kaur (Principal) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in according with Circular No. F.16/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the premises is fit for occupancy class "**Educational**" (Group-B) with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/08/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
etc 8/8

Copy to: -

1. The Principal, MCD Primary School No. 3/1 located at Kapashera. New Delhi-110037
2. The Director of Education, Municipal Corporation of Delhi, Dr. SPM Civic Centre, New Delhi-110002

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The foam is available on www.dfs.delhigovt.nic.in.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

N-14

INSPECTION REPORT

| | | | | |
|--------|---|---|------------------|----------------|
| 1. | Name & address of the building | MCD Primary School No. 3/1 at Kapashera, New Delhi-110037 (ID: 1757424 & 1757425) | | |
| 2. | Type of Occupancy | Educational Group-B (School) | | |
| 3. | Building Comprised of | Ground plus one upper floor only | | |
| 4. | Type of Case | Renewal | | |
| 5. | Details of previous NOC No. | F.6/DFS/MS/School/2021/SZ/401 Dt. 23/06/2021 | | |
| 6. | Fire Safety directives Letter No. | DOE Circular dated 01/03/2011 | | |
| 7. | Date of inspection | 09/08/2024 | | |
| 8. | Name of the Inspecting Officer | ADO (SJ) | | |
| 9. | Name and designation of Officer from the building side | Ms. Narinder Kaur (Principal) | | |
| 10. | Year of Construction | 2011 | | |
| 11. | Applicant's letter No. | E-mail Id kapasherano.31@gmail.com dated 18/07/2024 | | |
| S. No. | Minimum standards on fire prevention and fire safety U/R 33 | Old NOC Requirements | Provided at site | Remarks MR/NMR |
| 1. | Access of building | | | |
| | • Road width | Required | 18 mtr | MR |
| | • Gate width | NA | 3.25 mtr | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | Required | One | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1.50m / 0.75m | 1.50m | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width of Corridor | NA | 1.5m | NA |
| | f. Door Size | 1m | Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | Required | 05 Nos | MR |
| | • Types | ABC / CO ₂ | Provided | MR |
| | • ISI marking | Required | Provided | MR |
| 6. | First-Aid Hose Reels | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |

87

| | | | | |
|-----|--|----|----|----|
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | | | |
| 9. | Public Address System | | | |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down- comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power supply | NA | NA | NA |
| | ➤ Auto starting of pump | NA | NA | NA |
| 14. | Captive water storage for fire-fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw of connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15 | Exit Signage | | | |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | | | |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE Circular dated 01.03.2011, the FSC issued vide letter No. F.6/DFS/MS/School/2021/SZ/401 dated 23/06/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S. Kumar
12-08-24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

mml
12/8

chd
14/8/2024

Director
14/8/24
17/8/24

Sir, F.T letter is put up for your sig. pl

Director
14/8/24

S. Kumar
12/08/24