

e-27

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.


No.F.6/DFS/MS/School/2024/SZ/ 8/8

Dated: 20/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **National Model School**, B-4, Mansa Ram Park, Sunday Bazar Road, Uttam Nagar, New Delhi-110059, comprised of ground plus two upper floors but **school running at ground and first floor only** having total 08 rooms (04 rooms at GF & 04 rooms at FF including class rooms & office etc.). Earlier Fire Safety Certificate was issued by this department vide letter no. F.6/DFS/MS/School/2019/SZ/522 dated 14.03.2019. The school was re-inspected by the officer concerned of this department on 05.08.2024 in the presence of Sh. Brahm Prakash Yadav (Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (**Ground and first floor only**) is fit for occupancy class "**Educational**" for a period of **three years**, subject to compliance of the conditions printed as under.

Issued on 20/08/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
e/cu

Copy to:-

1. The Principal, National Model School, B-4, Mansa Ram Park, Sunday Bazar Road, Uttam Nagar, New Delhi-110059.
2. Director of Education GNCT of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

M/10

INSPECTION REPORT

1. Name & address of the building : National Model School, B-4, Mansa Ram Park, Sunday Bazar Road, Uttam Nagar, New Delhi-110059
2. Type of Occupancy : Educational
3. Building comprised of : Ground plus two upper floors (school running at ground and first floor only)
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2019/SZ/522 dated 14.03.2019
6. Fire Safety directives letter No : N/A
7. Date of inspection : 05.08.2024
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Brahm Prakash Yadav (Manager)
10. Year of Construction : Before 2008
11. Applicant's letter No. : NMS/04/2024 dated 05.07.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	Provided Directly accessible from road N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 No.'s N/A	03 No.'s N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	150 cms/additional staircase of 75 cms if less than 150 cms N/A	100, 90 & 90 cms (from GF to FF) N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	150 cms.	185 cms	M/R
	f. Door Size	100 cms	90 cms	M/R, being old case
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R

6.	First-Aid Hose Reels			N/A	N/A
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
7.	Automatic fire detection and alarming system			N/A	N/A
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
8.	MOEFA	N/A	N/A	N/A	
9.	Public Address System	N/A	N/A	N/A	
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
11.	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
12.	Yard Hydrants				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A	
		N/A	N/A	N/A	
13.	Pumping Arrangements				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
14.	Captive Water Storage for fire fighting				
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
15.	Exit Signage.	N/A	N/A	N/A	
16.	Provision of Lifts.	No Lift			

N/12

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2019/SZ/522 dated 14.03.2019, renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

Note: - As per undertaking given by the Manager (placed at C-24) School building is comprised of Ground plus two upper floors but school is running at ground floor and first floor only. The second floor having three rooms are being used for residence of watchmen family (Photo attached). The Fire Safety Certificate may be issue for ground floor and first floor having total eight rooms. The second floor will not be used for any schooling purpose in future also.

DO (South West) *[Signature]*
24/7/2024

CFO (S2) *[Signature]*
7/8/2024

Director *[Signature]*
8/8/24

[Signature]

[Signature]
Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)