

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 514

Dated: 16/08/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Indian Institute of Health Management Research Located at Plot No. 03, Pkt HAF, Sector – 18A, Dwarka, New Delhi, comprised of Basement, Ground+3 UFs was issued Fire Safety Certificate vide letter No. F6/DFS/DFS/MS/2008/1236, dated 30/04/2008. The premises was re inspected by the officer concerned of this department on 02/08/2024 in the presence of Sh. Sujaram (manager) All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with NBC/BBL/DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from 16/08/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/08/2024..... at New Delhi by.


 (Atul Garg)
 Director
 Delhi Fire Service

Copy to:

1. The Manager , Indian Institute of Health Management Research Located at Plot No. 03, Pkt HAF, Sector – 18A, Dwarka, New Delhi
2. Directorate of Education Old Secretariat Delhi – 110054.


Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Indian Institute of Health Management Research Located at Plot No. 03, Pkt HAF, Sector – 18A, Dwarka, New Delhi.
2. Type of Occupancy : Educational (Basement +Ground+ 3 UFs)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2008/1236, dated 30/04/2008
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2007/622, dated 02/03/07
6. Date of inspection : 02/08/2024
7. Name of the Inspecting Officer : ADO/DWK
8. Name and designation of Officer
from the building side: Sh. Sujaram (Manager)
9. Year of Construction : before 2008
10. Applicant's letter No. : Email dated 01/07/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per NBC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	03 Nos.	Provided	MR
	• Upper floors	03 Nos. ramp	Provided	MR
	• Basements			
	b. Width of staircases	1.5 m	1.48m,1.46m & 1.42m	MR(Being old case)
	• Upper floors	1.5 m	1.48m,1.46m & 1.42m	MR(Being old case)
	• Basements			
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	Required	150cm	MR
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required in basement	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA




4.	Smoke managements System				
	• Basements	30 a/c charge	Provided		MR
	• Upper floors	12 a/c charge	Natural ventilation		MR
5.	Fire Extinguishers				
	• Total numbers	01 no. for every 300 sq.mtr ABC or CO ₂ ISI marked	Provided		MR
	• Types		ABC & CO ₂		MR
	• IS marking		ISI marked		MR
6.	First – Aid Hose Reels				
	• Total numbers on each floor	02 Nos.	Provided		MR
	• Length of hose reel hose	30 mtr	Provided		MR
	• Nozzle diameter	05 mm	Provided		MR
7.	Automatic fire detection and alarming system				
	• Type of detectors	Required	Provided		MR
	• Location of Main Panel	NA	NA		NA
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	NA	NA		NA
	• Hooters' Location	NA	NA		NA
8.	MOEFA		NA	NA	NA
9.	Public Address System		Required	Provided	MR
10.	Automatic Sprinkler System				
	• Basements	Required	Provided		MR
	• Upper Floor	NA	NA		NA
	• Sprinkler above false ceiling	NA	NA		NA
11.	Internal Hydrants:				
	• Size of riser/down- comer	100 mm	Provided		MR
	• Number of hydrants per floor	02 Nos.	03 Nos.		MR
	• Hose Box	Required	Provided		MR
12.	Yard Hydrants				
	• Total number of hydrants	NA	NA		NA
	• Hose Box	NA	NA		NA
13.	Pumping Arrangements:				
	• Ground Level	2280 lpm	Provided		MR
	• Discharge of main pump	70 m	Provided		MR
	➤ Head of main pump	1	Provided		MR
	➤ Number of main pumps	180 lpm	Provided		MR
	➤ Jockey pump out put	70 m	Provided		MR
	➤ Jockey pump head	2280 lpm	Provided		MR
	➤ Standby Pump out put	70 m	Provided		MR
	➤ Standby Pump Head	Required	Provided		MR
	➤ Auto starting/Manual stopping	Required	Provided		MR
	➤ Pump House Access				
	• Terrace level	900 lpm	Provided		MR
	➤ Discharge of pump	40 mtr	Provided		MR
	➤ Head of the pump	Required	Provided		MR
	➤ Power supply	Required	Provided		MR
	➤ Auto starting of pump				


14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50,000 ltrs	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 & ABC, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/2008/1236, dated 30/04/2008 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended


 Signature of the Inspecting Officer
 Name: Udai Vir Singh
 Designation: ADO/DWK


 5/8/24


 6/8/24


 Director
 6/8/24

