

c 63



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001




No F 6 / DFS / MS / 2024 / School / WZ / 815

Dated: 19/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidyalaya, No. 2 (New Building), (ID No. 1411030)** located at **Shakurpur, Delhi- 110034** comprised of **Ground and Three upper floors** owned/occupied by **Sarvodaya Kanya Vidyalaya** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of Fire Service on **07.08.2024** in the presence of Smt. Sumedha Chaudhary (H.O.S) and found that the building is fit for **occupancy class Group B Educational** with effect from 19/08/2024 for a period of **03 (Three) years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...19/08/2024..... at New Delhi, by


(Atul Garg)
Director
Delhi Fire Service



Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat ,Delhi-54.
2. The Principal, Sarvodaya Kanya Vidyalaya, No. 2, Shakurpur, Delhi-110034.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. **Electric Panel and electric meter under the staircase must be removed or been segregated by fire check door within a period of three months from the date of issuance of the Fire Safety Certificate. Failing to do so the Fire Safety Certificate will be null and void.**

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya No. 2 (School ID- 1411030) located at Shakurpur, Delhi-110034.
2. Type of Occupancy : Educational
3. Building Comprised : Ground + Three Upper Floors.
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : NBC Part -IV
7. Date of inspection : 07/08/2024
8. Name of Inspecting Officer : ADO, R.K.Sinha
9. Name and designation of officers From the building side : Smt. Sumedha Chaudhry (H.O.S.)
10. Year of Construction : 2020
11. Applicant's letter No. : A.E/PWD/NW B-5/76 , Dated-25/06/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	Accessible to small fire engines	MR(old campus)
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04 & 01 Ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5 m each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	04	04	MR
	d. Width of Corridor	1.50 m	Provided	MR
	e. f. Door Size	1.20 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	25 Nos.	Provided	MR
	• Types	ABC/CO2	ABC/Co2	MR
	• IS marking	Yes	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	04	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA

	<ul style="list-style-type: none"> • Location of Repeater Panel • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Ground Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> • Terrace level <ul style="list-style-type: none"> • Discharge of pump • Head of the pump • Power Supply • Auto Starting of pump 	450 lpm	Provided	MR
		40 m	40 m	MR
		Required	Provided	MR
		-	-	-
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	Provided	MR
		Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			

NA VA A	Total Area	NA	NA	NA
	Location	NA	NA	NA
Fire Control Room				
•	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
Special Fire Protection System for Protection of special Risks, if any:		NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The school management had rectified the shortcoming issued vide letter number F6/DFS/MS/School/2023/WZ/562 dated 29/11/2023.

Note: Electrical panel found installed under the staircase which has to be removed to a safer place.

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

[Signature]
 ADO(BW)
 8/8/24

Signature of Inspecting Officer
 Name : Rajeev Kumar Sinha
 Designation : ADO/B.W.

[Signature]
 ADO(BW)

[Signature]
 9/8

73-N/A
 dated 09.08.24

[Signature]
 CFO

[Signature]
 12/8/2024

[Signature]
 Director

[Signature]
 Director

[Signature]
 ADO/BW

Dr. FT Lett...

prop for samples

[Signature]
 Director (Ops)

[Signature]
 14/8/24

[Signature]
 ADO(BW)
 16/8/24