



No. F6/DFS/MS/NDZ/EH/2024/ 258

Dated: 14/08/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s The Yellow Chilli a unit of Royal Hospitality running at G - 11, ground floor, Plot no. 10, V3S Mall, Laxmi Nagar, Delhi - 110092, comprised of basement, ground plus three upper floors owned/occupied by The Yellow Chilli A Unit of Royal Hospitality, was granted FSC by this department vide letter no. F6/DFS/MS/EH/NDZ/2021/158 dated 29/07/2021. The Premises was re-inspected by the officer concerned of this department of 31/07/2024 in the presence of Mr. Sushil Gupta (Operation Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly building" Group - D (Restaurant) on ground floor only valid up to 31/03/2027 for a period of in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued 14/08/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
0/9/24

Copy to:-

1. Mr. Sushil Gupta (Operation Manager) The Yellow Chill Restaurant (A Unit of Royal Hospitality), G-11, ground floor, Plot no. 10, V3S Mall, Laxmi Nagar, Delhi - 110092.
2. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24 w.e.f. - MHA portal ID - 2024071811186 dated 18/07/2024.

Conditions for the validity of Fire Safety Certificate:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used strictly as per Building By-Laws 1983.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Royal Hospitality located at G - 11, ground floor, Plot no. 10, V3S Mall, Laxmi Nagar, Delhi - 110092.
2	Building is comprised of	B + G + 03 upper floors
3	Type of occupancy	Assembly Building
4	Type of case	Renewal
5	Details of previous FSC	F6/DFS/MS/EH/NDZ/2021/158 dated 29/07/2021
6	Fire safety direction letter no.	N/A
7	Date of inspection	31/07/2024
8	Name of the inspecting officers	Yashwant Singh Meena (ADO/LN)
9	Name of the designation of officer From the building side	Mr. Sushil Gupta (Operation Manager)
10	Year of construction	2006
11	Applicant's letter no	MHA Portal application No. I.D -2024071811186 dated 18/07/2024

S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
a	Road width	12 mtrs.	36 mtrs & 13.8 mtrs.	MR
b	Gate width	4.5 mtrs	06 mtrs.	MR
c	Width of internal road	06 mtrs.	06 mtrs	MR
2	Number, Width, Type and Arrangement of Exits			
A	Number of staircases			
a	Upper floor	N/A	N/A	N/A
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	N/A	N/A	N/A
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	N/A	N/A	N/A
E	Width of corridor	N/A	N/A	N/A
F	Door size	2.0 mtrs. ✓	2.0 mtrs & 1.0 mtr ✓	MR
3	Compartmentation Already existing in mall building			
a	Fire check door	existing	Existing in mall building	MR
b	Sealing of electrical shafts	existing	Existing in mall building	MR
c	Fire rating of shaft door	existing	Existing in mall building	MR
d	Water curtain	N/A	N/A	N/A
e	Fire dampers	N/A	N/A	N/A
4	Smoke Management System Already existing in mall building			
a	Basement	12 A/C Per hour	Provided existing in mall building	MR
b	Upper floor	12 A/C Per hour	N/A	N/A

5.	Fire Extinguisher			
a	Total numbers	04 nos.	06 nos.	MR
b	Types	CO ₂ & ABC	CO ₂ & ABC	MR
c	ISI marking	Required	Provided	MR
6	First-aid-Hose Reels. Already existing in mall building near gate of restaurant			
a	Total numbers of each floor	existing	Provided extended in restaurant	MR
b	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
c	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection & Alarming System. Existing in mall building			
a	Type of detectors	Heat & Smoke existing in main building	Provided extended in restaurant	MR
b	Location of main panel	Control Room	Basement	MR
c	Location of repeater panel	Security Room	Provided	MR
d	Alternate source of power	Battery & D.G Set	Provided	MR
e	Hooter's location	Staircase	Provided	MR
8	MOEFA	Required	Provided existing in main building	MR
9	Public Address System.	Required	Provided existing in main building	MR
10	Automatic Sprinkler System. Already existing in mall building			
a	Basement	existing	Already existing in mall building	MR
b	Upper floors	existing	Already existing in mall building	MR
c	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants Already existing in mall building			
a	Size of riser/down-comer	existing	Already existing in mall building	MR
b	Number of hydrants per floor	Near gate	Already existing in mall building	MR
c	Hose Box	available	Already existing in mall building	MR
12	Yard Hydrants. Already existing in mall building			
a	Total number of hydrants	existing	Already existing in mall building	MR
b	Hose Box	existing	Already existing in mall building	MR
13	Pumping Arrangements. Existing in mall building			
A	Ground Level			
a	Discharge of main Pump	2850 LPM	2850 LPM	MR
b	Head of Main Pump	70 mtrs	70 mtrs	MR
c	Number of main pumps	01 no	01 no.	MR
d	Jockey pump out put	180 LPM	180 LPM	MR
e	Jockey pump head	70 mtrs	70 mtrs	MR
f	Stand by pump out put	2850 LPM	2850 LPM	MR
g	Stand by pump head	70 mtrs	70 mtrs	MR
h	Auto starting /manual stopping	Required	Provided	MR
B	Terrace Level			
a	Discharge of pump	N/A	N/A	N/A
b	Head of the Pump	N/A	N/A	N/A
c	Power supply	N/A	N/A	N/A
d	Auto Starting of pump	N/A	N/A	N/A

N/20

Royal Hospitality located at G-11, ground floor, Plot no. 10, V3S Mall, Laxmi Nagar, Delhi -110092.

14	Captive Water Storage for Fire Fighting Already existing in mall building				
a	Underground tank capacity	1,00,000 liters	1,20,000 liters	✓ MR	
b	Draw-off connection	Required	Provided	MR	
c	Fire service inlet	Required	Provided	MR	
d	Access to tank	Required	Provided	MR	
e	Overhead Tank capacity	20,000 liters	40,000 liters	✓ MR	
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts. Already available in mall building				
a	Pressurization of Lift Shaft	NA	NA	NA	
b	Pressurization of Lift lobby	NA	NA	NA	
c	Communication in lift car	NA	NA	NA	
d	Firemen's switch	NA	NA	NA	
e	Lift Signage	NA	NA	NA	
17	Standby power supply		Required	Provided	MR
18	Refuge Area.				
a	Total area	NA	NA	NA	
b	Location	NA	NA	NA	
19	Fire Control Room Already existing in mall building				
a	Detector system panel	existing	Already existing in mall building	MR	
b	Flow switch panel	existing	Already existing in mall building	MR	
c	PA system panel	existing	Already existing in mall building	MR	
d	Battery backup	Required	Provided	MR	
e	Building Floor Plans	Required	Provided	MR	
20	Special Fire Protection systems for protection of special Risks, if any:			NA	

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC / FSC was issued vide letter no. F6/DFS/MS/EH/NDZ/2021/158 dated 29/07/2021 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

DY. CEO/NDZ

C.F/O.

Director

P.T.O