

C-68

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2024/School/WZ/ 800

Dated: 16/08/2024

FIRE SAFETY CERTIFICATE

Certified that the De Indian Public School located at Pocket-II, Sector-24, Rohini, Delhi-110085 comprised of building Basement + Ground + 03 upper floor owned/ occupied by the DE Indian Public School was granted FSC by this department vide letter No F.6/DFS/MS/2021/School/WZ/864 dated 21.10.2021 for Ground + 02 upper floors. The premises was re-inspected by the officer concerned of this department on 24.07.2024 in the presence of Mrs. Padmini Dubey Ojha (Officiating Principal) and observed that the building all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 262-362 dated 17.01.2005 and the building/ premise is fit for occupancy "Group B Educational" with effect from 16/08/2024 for a period of three years, in accordance with rule 36 unless under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010:

Issued on 16/08/2024 at New Delhi


(Atul Garg)
DIRECTOR
Ph: 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, De-Indian Public School, Pocket-II, Sec-24, Rohini, Delhi-85.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. The occupancy of the school activity is restricted up to 2nd floor level only. The occupancy for 3rd floor & basement will only be considered after obtaining approval of building authority only. Failing which FSC shall stand null and void.

N/34

INSPECTION REPORT

1. Name & address of the building : De Indian Public School located at Pocket-II, Sector-24, Rohini, Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground + 2 upper floors)
4. Details of Previous NOC : F.6/DFS/MS/2016/School/WZ/860 dated 25.05.2016
5. Fire Safety directives letter No : Director of Education Circular letter no.262-362 dated 17.01.2005
6. Date of inspection : 07.09.2021
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Smt. Seema Awasthi (Principal)
9. Year of Construction : 2009 & 2015
10. Applicant's letter No. : Online e-mail dated 21.08.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. dated 17.01.2005	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	1.65m & 1.35m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	15nos.	15nos.	MR
	• Types	ABC/CO2	ABC-15	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA

	<ul style="list-style-type: none"> • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	NA	NA	NA
	<ul style="list-style-type: none"> • Ground & Upper Floors 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	02	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	02	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level 	NA	NA	NA
	<ul style="list-style-type: none"> ➢ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➢ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➢ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➢ Jockey Pump out put 	180lpm	Provided	MR
	<ul style="list-style-type: none"> ➢ Jockey pump head 	40m	Provided	MR
	<ul style="list-style-type: none"> ➢ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➢ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➢ Auto Starting/Manual Stopping 	NA	NA	NA
	<ul style="list-style-type: none"> ➢ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➢ Discharge of pump 	900lpm	900lpm	MR
	<ul style="list-style-type: none"> ➢ Head of the pump 	40m	40m	
	<ul style="list-style-type: none"> ➢ Power Supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➢ Auto Starting of pump 	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➢ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➢ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➢ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	5,000ltr	5,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication In lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➢ Total Area 	NA	NA	NA
	<ul style="list-style-type: none"> ➢ Location 	NA	NA	NA

19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA
		NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education **Circular dated 17.01.2005**, the NOC issued vide letter of even no F.6/DFS/MS/2016/School/WZ/860 dated 25.05.2016, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended for G+2 floors only.

Ajay
17/9/21
Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO (Rohini)**

~~DO (NW)~~
Ajay
30/09/2021

By ADO (W2) proof of closing of two floors.

~~ADO Rohini Sr.~~

Applicant submitted the declaration & photographs as proof.

~~DO (W2)~~

Ajay
5/10/21
8/10/2021

~~ADO Rohini~~

FT letter is put up for kind perusal and signature please

ms/ up

~~DO (W2)~~

Ajay
21/10/2021
13/10/21