



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Audi/2024/SZ/ 520

Dated: 21/08/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Jawaharlal Auditorium** located at AIIMS Complex, Ansari Nagar, New Delhi-110029, comprised of Basement, Ground Plus Balcony, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/Audi/2021/SZ/504 dated 14/10/2021. The premise was re-inspected by the officers concerned of this department on dated 05/08/2024 in the presence of Sh. Manoj Kumar (ASO-AIIMS) & Sh. Ashok Sharma (Fire Consultant) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said premises is fit for occupancy class "**Assembly Group D**" (Auditorium) with effect from 21/08/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/08/2024 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. Sh. Manoj Kumar, Asst. Security Officer (Fire Safety), All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029
2. The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station Defence Colony, New Delhi-110049

**Conditions for the validity of Fire Safety Certificate:**

1. **Basement shall be used in accordance with the provisions of BBL.**
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry.



## INSPECTION REPORT

1.	Name & address of the building	Jawaharlal Auditorium at AIIMS Complex Ansari Nagar, New Delhi-110029		
2.	Type of Occupancy	Assembly Building "Group D"		
3.	Composition of building	Basement, Ground Plus Balcony Floor. Total 930 Seats. GF= 566 & Balcony=354 Seats		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/Audi/2021/SZ/504 Dt 14/10/2021		
6.	Fire Safety directives Letter No	F6/DFS/MS/81/738 dated 20/11/1981		
7.	Date of inspection	26/07/2024 & 06/08/2024		
8.	Name of the Inspecting Officer	DO (SD) & ADO (SJ)		
9.	Name and Designation of Officers from the building side	Sh. Manoj Kumar ASO (Fire Safety), AIIMS & Sh. Ashok Sharma (Fire Consultant)		
10.	Year of Construction	Prior to 1983		
11.	Applicant's letter No./ Email received from ID <a href="mailto:manojkmr@aiims.gov.in">manojkmr@aiims.gov.in</a> dated Jul 24, 2024			
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	12m	MR
	• Gate width	Required	6m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos	04 Nos	MR
	• Basements	01 No	01 No	MR (Old case)
	b. Width of staircases			
	• Upper floors	Required	1.55m (one) & 0.83m (three)	MR (Old case)
	• Basements	Required	0.83m	MR (Old case)
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No of continuous staircase to terrace	One	Provided	MR
	e. Width Of Corridor	-NA-	-NA-	-NA-
	f. Door Size	Required	6 Exits at GF 1.3m each 2 Exits at FF 1.3m each	MR (Old case)
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers			
	• Total numbers	14 Nos	20 Nos	MR
	• Types	ABC/CO <sub>2</sub> /WCO <sub>2</sub>	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	GF=02, FF=01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR



7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detector</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	Required	Beam Detector	MR
		Ground floor	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		All Areas	Provided	MR
8.	MOEFA/MCPs	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	Required	150mm	MR
		GF=02, FF=01	Provided	MR
		GF=02, FF=01	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	02 Nos	Provided	MR
		02 Nos	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level                             <ul style="list-style-type: none"> <li>➤ Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level                             <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul> </li> </ul>	1620 LPM	1620 LPM	MR
		70m	70m	MR
		One	One	MR
		2 x 280 LPM	2 x 280 LPM	MR
		70m (each)	70m (each)	MR
		1620 LPM	1620 LPM	MR
		70m	70m	MR
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.		Captive water Storage for fire fighting		
	<ul style="list-style-type: none"> <li>• Underground tank capacity                             <ul style="list-style-type: none"> <li>➤ Draw of connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	50,000 Ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	Required	Provided	MR	
17.	Standby power supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

82

5

19.	Fire control room	Provided at ground floor		
		Required	Provided	MR
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	-NA-	-NA-	-NA-
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection Systems for Protection of special Risks, if any;	HT, LT & Transformer are provided with ABC & CO <sub>2</sub> fire extinguishers.		MR

**Note:** The basement is provided with single staircase of 0.83m only and AHU is installed there (Photo enclosed).

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under, the fire safety certificate issued vide letter No. F.6/DFS/MS/Audi/2021/SZ/504 Dt 14/10/2021, renewal under rule 37 of Delhi Fire Service Rules, 2010, is recommended.

Accordingly, DFA is put up for approval and signature please.

*Manoj*  
*TJA*

Signature of the Inspecting Officer  
Name: Manoj Kumar Sharma  
Designation: DO (SD)

*Santosh*  
*74-08-24*

Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

CFO(HQ)  
*16/8/2024*

*Director*  
*16/8/24*

*Manoj/SJ*

Sir,  
F.T letter is put up for your sig. pl

*Director*  
*20/08/24*

*Santosh*  
*20/08/24*