



FIRE SAFETY CERTIFICATE

Certified that M/s Leap of Taste at SF – 30D, SF – 30E, Second floor, Plot No. 9B & 9C Cross River Mall, CBD Shahdara, Delhi - 110032, comprised of two basements, ground plus three upper floors (restaurant is running on second floor only) owned/occupied M/s Leap of Taste was issued FSC vide letter no. F6/DFS/MS/NDZ/2021/238 dated 17.09.2021. The premises was re-inspected by the officer concerned of this department on dated 07/08/2024 in the presence of Mr. Maanas Goyal (Owner) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy "Assembly Building" (Group D) Eating House and valid up to 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 21/08/2024 at New Delhi by.

[Signature]
21/8/2024

**VIRENDER SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

o/c

[Signature]

Copy to:-

1. The Owner, M/s Leap of Taste at SF – 30D, SF – 30E, Second floor, Plot No. 9B & 9C Cross River Mall, CBD Shahdara, Delhi - 110032.
2. The Joint Commissioner of police (Lic.), Ist Floor, P.S Defence Colony, New Delhi - 110024. w.r.t. - MHA portal ID - 2024071110837 dated 22/07/2024.

Conditions for the validity of Fire Safety Certificate:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used strictly as per Building By-Laws 1983.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1.	Name & address of the building	M/s Leap of Taste located at Shop no. SF - 30D, SF - 30E, Second floor, Plot No. 9B & 9C Cross River Mall, CBD Shahdara, Delhi - 110032.			
2.	Building is comprised of	Two Basement + Ground + 03 upper floors only. (Restaurant is Second floor only)			
3.	Type of occupancy	Assembly (Restaurant)			
4.	Type of case	Renewal			
5.	Details of previous FSC	F6/DFS/MS/NDZ/2021/238 dated 17.09.2021			
6.	Fire safety direction letter no.	NBC Part-IV			
7.	Date of inspection	07.08.2024			
8.	Name of the inspecting officers	Yashwant Singh Meena (ADO/Laxmi Nagar)			
9.	Name of the designation of officer from the building side	Mr. Maanas Goyal (Owner)			
10.	Year of construction	2010			
11.	Applicant's letter no	MHA Application No. 2024071110837 dated 22/07/2024			
S. No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR	
1	Access to building			MR	
	a	Road width	6.0 meters.	24 meters	MR
	b	Gate width	4.5 meters.	7.0 meters	NA
	c	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits				
A	Number of staircases				
	a	Upper floor	02 nos.	02 nos. ✓	MR
b	Basement		NA	NA	NA
	Width of staircases				
B	a	Upper floor	1.50 mtrs.	2.0 mtrs. & 1.50 mtrs.	NA
	b	Basement	NA	NA ✓	NA
C	Protection of exits				
	a	Fire check door	NA	Provided	MR
b	Pressurization		NA	Provided	MR
	No. of continuous staircases to terrace		NA	NA	NA
D	No. of continuous staircases to terrace		NA	NA	NA
E	Width of corridor	2.0 mtrs.	2.50 mtrs. ✓	MR	
F	Door size	1.50 meters x 02 nos.	1.50 meters x 02 nos.	MR	
3	Compartmentation				
a	Fire check door		NA	NA	NA
	Sealing of electrical shafts		NA	NA	NA
c	Fire rating of shaft door		NA	NA	NA
	Water curtain		NA	NA	NA
e	Fire dampers		NA	NA	NA
	Smoke Management System.				
4	Basement		NA	NA	NA
	Upper floor		NA	NA	NA

5.	Fire Extinguisher				
	a	Total numbers	04 nos.	04 nos.	MR
	b	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	c	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels. Provided In the Mall				
	a	Total numbers of each floor	01 nos.	Provided	MR
	b	Length of hose reel hose	30 mtrs.	Provided	MR
	c	Nozzle diameter	05 mm	Provided	MR
7	Automatic fire detection and alarming system.				
	a	Type of detectors	Heat & Smoke	Provided	N/A
	b	Location of main panel	Control Room	Provided	N/A
	c	Location of repeater panel	Security Room	Provided	N/A
	d	Alternate source of power	Battery & D.G Set	Provided	N/A
	e	Hooter	Stair Case	Provided	N/A
8	MOEFA		Required	Provided	MR
9	Public address System.		NA	Provided	NA
10	Automatic Sprinkler System. Provided In the Mall				
	a	Basement	NA	NA	NA
	b	Upper floors	NA	NA	NA
	c	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants Provided In the Mall				
	a	Size of riser	100 mm	Provided	MR
	b	Number of hydrants per floor	01 no.	01 no.	MR
	c	Hose Box	10 no.	10 no.	MR
12	Yard Hydrants.				
	a	Total number of hydrants	NA	Provided	NA
	b	Hose Box	NA	Provided	NA
13	Pumping Arrangements. Provided In the Mall				
	A	Ground Level			
	a	Discharge of main Pump	2850 LPM	2850 LPM	MR
	b	Head of Main Pump	60 mtrs.	60 mtrs.	MR
	c	Number of main pumps	02 nos.	02 nos.	MR
	d	Jockey pump out put	180 LPM	180 LPM	MR
	e	Jockey pump head	60 mtrs.	60 mtrs.	MR
	f	Standby pump out put	2850 LPM	2850 LPM	MR
	g	Standby pump head	60 mtrs.	60 mtrs.	MR
	h	Auto starting /manual stopping	Required	Provided	MR
	i	Pump House Access	Required	Provided	MR
	B	Terrace Level			
	a	Discharge of pump	NA	NA	NA
	b	Head of the Pump	NA	NA	NA
	c	Power supply	NA	NA	NA
	d	Auto Starting of pump	NA	NA	NA

2/09

M/s Leap of Taste at SF - 30D, SF - 30E, Second floor, Plot No. 9B & 9C Cross River Mall, CBD Shahdara, Delhi - 110032

14	Captive Water Storage for Fire Fighting.		Provided In the Mall	
	a	Underground tank capacity	N/A	2, 00,000 Liters. N/A
	b	Draw-off connection	N/A	Provided by the Mall N/A
	c	Fire service inlet	N/A	Provided by the Mall N/A
	d	Access to tank	N/A	Provided by the Mall N/A
	e	Overhead Tank capacity	10,000 liters.	50,000 liters. MR
15	Exit Signage.		Required	Provided MR
16	Provision of Lifts.		Provided In the Mall	
	a	Pressurization of Lift Shaft	NA	NA NA
	b	Pressurization of Lift lobby	NA	NA NA
	c	Communication in lift car	NA	NA NA
	d	Firemen's grounding switch	NA	NA NA
	e	Lift Signage	NA	NA NA
17	Standby power supply		NA	Provided MR
18	Refuge Area.			
	a	Total area	NA	NA NA
	b	Location	NA	NA NA
19	Fire Control Room			
	a	Detector system panel	NA	Provided MR
	b	Flow switch panel	NA	Provided MR
	c	PA system panel	NA	Provided MR
	d	Battery backup	NA	Provided MR
	e	Building Floor Plans	NA	Provided MR
20	Special Fire Protection systems for protection of special Risks, if any:		NA	Provided in all LT & HT Panels MR

The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC issued vide letter no. F6/DFS/MS/NDZ/2021/238 dated 17.09.2021 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (Laxmi Nagar)

DY.CFO/NDZ
 14/08/21

C.F.O.
 16/9/2021
 Director
 19/12/21

ADP