

C45

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/EH/270

Dated 21/08/2024

FIRE SAFETY CERTIFICATE

Certified that the M/S Pizza Hut Located at Shop No. T-301 3rd Floor Street Plot No. 6 Sector-14, Vegas Mall Dwarka Delhi-110075, in a building comprised of 4 Basement + Ground + 07 Upper Floors was issued FSC vide letter No. F6/DFS/MS/2021/SZ/138 Dated 16/07/2021. (Issued to Mall F6/DFS/MS/SZ/2022/62 dated 09/12/2022) The premises was re - inspected by the officer concerned of this department on 16/08/2024 in the presence of Mr. Shashi Singh (Manager) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly" Group D (T-301, 3rd Floor) with effect from 21/08/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 21/08/2024 at New Delhi by.


 (Atul Garg)
 Director
 Delhi Fire Service
 014

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. The Manager M/S Pizza Hut at Shop No. T-301 3rd Floor Street Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110075.
3. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi

Condition for the validity of fire safety certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/A

INSPECTION REPORT

1. Name & address of the building: **M/S Pizza Hut Located at Shop No. T-301, 3rd Floor Street Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110075.**
2. Type of Occupancy : **Class-D (Assembly)(At 3rd Floor in the Mall)**
3. Type of Case : **Renewal**
4. Details of previous NOC **F6/DFS/MS/2021/SZ/138 Dated 16/07/2021**
5. Fire Safety directives Letter No. : **(Issued to Mall F6/DFS/MS/SZ/2022/62 dated 09/12/2022)**
6. Date of inspection : **16/08/2024**
7. Name of the Inspecting Officer ; **ADO (DWK)**
8. Name and designation of Officer
from the building side : **Mr. Shashi Singh (Manager)**
9. Year of Construction : **2019**
10. Applicant's letter No. : **2024072711670 Dated-27/07/2024**
11. Note- **FSC issued to mall by this department vide letter no F6/DFS/MS/SZ/2022/62 dated 09/12/2022)**

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12mtrs	Provided	MR
	• Gate width	06mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits(Common With Mall)			
	a. Number of staircases			
	• Upper floors	3	03 Provided (by Mall)	MR
	• Basements	NA	12 Provided by Mall	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided by Mall	MR
	• Basements	NA	Provided	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	2m & 1.5 M	Provided	MR
3.	Compartmentation(Common With Mall)			
	• Fire check door	Required	Provided by Mall	MR
	• Sealing of electrical shafts	Required	Provided by Mall	MR
	• Fire Rating of shaft door	Required	Provided by Mall	MR
	• Water Curtain	Required	Provided by Mall	MR
	• Fire Dampers	Required	Provided by Mall	MR

14.	Captive water Storage for fire fighting: Common with Mall		
	• Under ground tank capacity	NA	400000 l (By Mall) NA
	➤ Draw off connection	NA	Provided By Mall NA
	➤ Fire service inlet	NA	Provided By Mall NA
	➤ Access to tank	NA	Provided By Mall NA
	• Overhead Tank capacity	20, 000 litres	Provided By Mall MR
15	Exit Signage	Required	Provided By Mall MR
16.	Provision of Lifts Common with Mall		
	➤ Pressurization of Lift Shaft	NA	Provided By Mall NA
	➤ Pressurization of lift lobby	NA	Provided By Mall NA
	➤ Communication in lift Car	NA	Provided By Mall NA
	➤ Fireman's Grounding Switch	NA	Provided By Mall NA
	➤ Lift Signage	NA	Provided By Mall NA
17.	Standby power supply	Required	Provided By Mall MR
18.	Refuge Area		
	➤ Total area	NA	Provided NA
	➤ Location	6 th & 9 th Floor	Provided NA
19.	Fire control room(Common with Mall)		
	➤ Detector system panel	NA	Provided By Mall NA
	➤ Flow Switch Panel	NA	Provided By Mall NA
	➤ PA System Panel	NA	Provided By Mall NA
	➤ Battery backup	NA	Provided By Mall NA
	➤ Building Floor Plans	NA	Provided By Mall NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided By Mall NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/SZ/2021/138, dated 16/07/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended *of speed.*

UD
17/8/24
Signature of the Inspecting Officer
Name UdaiVir Singh
Designation ADO DWK

20/8/24
19/8/24

CFo(S2)
19/8/2024
Director
29/8/24
m

17/8/24
21/8/24

D