

C-102

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6/DFS/MS/2024/Hospital/WZ/ 522

Dated: 21/08/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Brahm Shakti Hospital located at U-1/78, Budh Vihar, Main Kanjhawala Road, Delhi-86, comprised of building 02 Blk Interconnected, Basement + Gr. + 03 Upper floors & Gr. + 1 upper floor but hospital running at 02 Blk Interconnected, Basement + Gr.+ 02 upper floors & Gr. + 01 upper floor owned/occupied by M/s Brahm Shakti Hospital has already been issued FSC by this department vide letter No. F.6/DFS/MS/2021/WZ/Hospital/321 dated 15.07.2021, The premises was re-inspected by the officer concerned of this department on 19.07.2024 in the presence of Mr. Sudhanshu Sharma and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Institutional "Group C" with effect from 21/08/2024 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 21/08/2024 at New Delhi by

  
(Anil Garg)  
**DIRECTOR**  
Ph: 011-23414000

Copy to:

1. Mr. Sudhanshu Sharma, M/s. Brahm Shakti Hospital, U-1/78, Budh Vihar, Delhi-86.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).
8. The basement is not allowed to use as undertaking given by the Management.
9. 3<sup>rd</sup> floor shall not be used until FSC is issued by this department for 3<sup>rd</sup> floor also.

**INSPECTION REPORT**

1. Name & address of the building	M/s Brahm Shakti Hospital located at U-1/78, Budh Vihar. Main Kanjhawala Road, Delhi-86
2. Type of Occupancy	Institutional
3. Type of Case	Renewal (Comprised of building 02 Blk Interconnected, B+G+3 & G+1 upper floor <b>but hospital running at 02 Blk Interconnected, B+G+2 &amp; G+1 upper floor</b> )
4. Details of Previous NOC	F.6/DFS/MS/2021/WZ/Hospital/321 dated 15.07.2021.
5. Fire Safety directives letter No	BBL-1983.
6. Date of inspection	19.07.2024.
7. Name of Inspecting Officer	A.K.Sharma ADO (Rohini)
8. Name and designation of officers From the building side	Mr. Sudhanshu Sharma
9. Year of Construction	1992
10. Applicant's letter No.	OD No.3549 dated 28.06.2024.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL-1983 Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	6.0m	12m	MR
	• Gate width	4.5m	4.5m & 4.0m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	02nos.	05nos.	MR
	• Basements	02nos.	05nos.	MR
	<b>b. Width of staircases</b>			
	• Upper Floor	2m	2m x 2 & 1.5m x 2 & 1.4m	MR
	• Basements	2m	1.5m & 2.0m	MR
	<b>c. Protection of exits</b>			
	• Fire check door	Required	Provided	MR
	• Pressurization	All	All	MR
	<b>d. No. of continuous staircases to terrace</b>	02nos.	02nos.	MR
	<b>e. Width of Corridor</b>	1.5m	2m	MR
	<b>f. Door Size</b>	2m	2m	MR
3.	<b>Compartmentation</b>			
	a) Fire check door	Required	Provided	MR
	b) Sealing of electrical shafts	Required	Provided	MR
	c) Fire Rating of shaft door	Required	Provided	MR
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	a) Basements	31 /c per hour	Exhaust fan	MR
	b) Upper floors	12 a/c per hour	Natural ventilation	MR
5.	<b>Fire Extinguishers</b>			
	a) Total numbers	26nos.	28nos.	MR
	b) Types	ABC/CO2	ABC-28nos.	MR
	c) IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			

ky

	a) Total numbers on each floor	01nos.	02nos.	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	a) Type of detectors	Heat/ Smoke	Provided	MR
	b) Location of Main Panel	Ground floor	Provided	MR
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	Required	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	a) Basement	Required	Provided	MR
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
<b>11.</b>	<b>Internal Hydrants</b>			
	a) Size of riser/down-comer	100mm	Provided	MR
	b) Number of hydrants per floor	01nos.	Provided	MR
	c) Hose Box	01nos.	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	a) Total number of hydrants	07nos.	Provided	MR
	b) Hose Box	07nos.	Provided	MR
<b>13.</b>	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	2280lpm	2280lpm	MR
	➤ Head of Main pump	60m	60m	MR
	➤ Number of main pumps	01nos.	01nos.	MR
	➤ Jockey Pump out put	180lpm	180lpm	MR
	➤ Jockey pump head	60m	60m	MR
	➤ Standby Pump out put	2280lpm	2280lpm	MR
	➤ Standby Pump Head	60m	60m	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	Terrace level			
	➤ Discharge of pump	450lpm	900lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	1,00,000lr	1,00,000ltr	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000ltr	20,000ltr	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	Required	Provided.	MR

MI  
MR  
MR

	d) Fireman's Grounding Switch	Required	Provided	MR
	e) Lift Signage	Required	Provided	MR
	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	<b>Fire Control Room</b>			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in BBL-1983, and removal of shortcomings issued vide letter no. 258 dated 13.05.2024, the FSC issued vide letter no. F.6/DFS/MS/2021/WZ/Hospital/321 dated 15.07.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

*[Signature]*  
Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

DO (N/W)

*[Signature]* 24/07/2024  
By CFO (02)  
*[Signature]* 25/7/2024  
*[Signature]* 28/7/2024  
*[Signature]* 29/7/2024

DCFO ..... 63 .....  
Dated ..... 24/7/2024

Director *[Signature]*  
FI letter is put up for kind perusal and signature please.  
Director *[Signature]* P/S BPC  
DL R/WL  
*[Signature]* 29/7/2024