

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 526

Dated: 27/08/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s CNG Filling Station (IGL) Located at Sector – 23A, Dwarka, New Delhi – 110075 comprised of Ground + 01 Upper Floor was issued NOC by this department vide Letter No. F6/DFS/MS/CNG/2021/SZ/416 dated – 27/08/2021. The premises was re inspected by the officers concerned of this department on 06/08/2024 in the presence of Mr. Sandeep Kumar (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “Hazardous” (CNG filling station) with effect from 27/08/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/08/2024... at New Delhi by.

(Atul Garg)

Director,
Delhi Fire Service

OK

Copy to:

1. Sh. Ajay Khatri DGM – Fire & Safety Indraprastha Gas Limited New Delhi.
2. The Manager, M/s CNG Filling Station (IGL) Sector – 23A, Dwarka, New Delhi – 110075.

Conditions for validity of fire safety certificate


1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/18

INSPECTION REPORT

1. Name & address of the building: M/s CNG Filling Station (IGL) Located at Sector – 23A, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Group J: Hazardous (CNG Filling Station)
3. Type of Case : Renewal (Ground +01 Upper Floor)
4. Details of previous NOC: F6/DFS/MS/CNG/2021/SZ/416 dated – 27/08/2021.
5. Fire Safety directives Letter No. : OISD -179/F5/(3A)/DFS/CNG/2010/53 Dated 05/03/2010
6. Date of inspection : 06/08/2024
7. Name of the Inspecting Officer : Sh.Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Sandeep Kumar (Manager)
9. Year of Construction : 2010
10. Applicant's letter No. : IGL/F&S/2024/15/76/1 dated 11/07/2024

S No.	Minimum standards on fire prevention and fire safety U/R 33	As per N/8		Provided at site	Remarks MR/NMR
1.	Access of building				
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9m 4.5m NA	30 m Directly accessible from road NA		MR MR NA
2.	Number, width, Type & Arrangements of exits				
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements b. Width of staircases • Upper floors • Basements c. Protection of exits • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 				
		02	02		MR
		NA	NA	NA	
		120cm & 70 cms	120cm & 70 cms		MR
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		01	01		MR
		NA	NA	NA	
		1 mtr	1.25 mtr		MR
3.	Compartmentation				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA


 Ad. k

11/19

4.	Smoke managements System	NA	NA	NA
	<ul style="list-style-type: none"> Basements Upper floors 	Required	Natural Ventilation	MR
5.	Fire Extinguishers			MR
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 nos. DCP, ABC & CO ₂ Required	31 Nos. Co ₂ 4.5 kg (9Nos.) DCP Trolley of 75 kg (9 Nos.) DCP 10 kgs. (18 Nos.) Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7.	Automatic fire detection and alarming system			MR
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Gas & Flame detectors NA NA NA NA	Provided NA NA NA NA	MR NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Ground Floor Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	Required no smoking board		Provided MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided DG set 25 kva	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 Flooding	Provided for compressor	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/CNG/2021/SZ/416 dated - 27/08/2021 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name *Uday Vir Singh*
Designation *Asst. Insp.*

[Signature] 12/8/24
[Signature] 19/8/24
CFO (SZ)
[Signature] 19/8/2024
Director
[Signature] 20/8/24

[Signature]