



No. F6/DFS/MS/School/NDZ/2024/ 827

Dated: 27/08/2024

FIRE SAFETY CERTIFICATE

Certified that the Crescent School, located at Road No. 66, Near Metro Pillar No. 200, Maujpur Road, Delhi - 110053, building comprised of basement, ground plus three upper floors (Third floor has been sealed by MCD, school is running up to two floor only) owned/occupied by Crescent School, was issued FSC vide letter No. F6/DFS/MS/School/2021/ NDZ/532 dated 26/07/2021. The School building was re-inspected by the officer concerned of this department on 14/08/2024 in presence of Mrs. Zatoon Nisah (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular no. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education and the school building is fit for occupancy class 'Educational Building' (Group-B) with effect from 27/08/2024 for a period of three years, in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below

Issued on 27/08/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Joint Director of Education (Land & Estate) Directorate of Education, Lucknow Road, Delhi- 110053.
2. The Principal, Crescent School, located at Road No. 66, Near Metro Pillar No. 200, Maujpur Road, Delhi - 110053.

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for basement, ground plus two floors only.
2. Third floor shall not be used (as per affidavit dated 14.08.2024) for any purpose.
3. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
4. All the means of escape shall be kept free of all the type of obstruction all the time.
5. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
6. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
7. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
8. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any..
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/12

INSPECTION REPORT							
01.	Name & address of the building		Crescent School, located at Road No. 66, Near Metro Pillar No. 200, Maujpur Road, Delhi-110053.				
02.	Building is comprised of		Basement, ground plus three upper floors (Third floor has been sealed by MCD, school is running upto two floor only)				
03.	Type of occupancy		Educational Building				
04.	Type of case		Renewal				
05.	Details of previous FSC		F6/DFS/MS/School/2021/ NDZ/532 dated 26/07/2021.				
06.	Fire safety directives letter no.		F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/2011.				
07.	Date of inspection		07/08/2024				
08.	Name of the inspecting officers		Yashwant Singh Meena ADO (L.N)				
09.	Name of the designation of officer from the building side		Mrs. Zatoon Nisah (Principal)				
10.	Year of construction		1995				
11.	Applicant's letter no.		Email dated 29/07/2024				
S.No	Minimum standard of fire prevention and fire safety U/R 33		Requirement	Provided at site	Remarks MR/NMR		
01.	Access to Building:						
	A	Road width	6.0 mtrs.	20 mtrs. ✓	MR		
	B	Gate width	NA	NA	NA		
	C	Width of internal road	NA	NA	NA		
02.	Number, Width, Type and Arrangement of Exits:						
	A	Number of staircases					
		a	Upper floor	02 nos.	03 nos. ✓	MR	
		b	Basement	02 nos.	03 nos. ✓	MR	
	B	Width of staircases					
		a	Upper floor	1.50 mtrs	1.68 mtrs, 1.40 mtrs & 1.12 mtrs ✓	MR	
		b	Basement	1.50 mtrs	1.68 mtrs, 1.40 mtrs & 1.12 mtrs ✓	MR	
	C	Protection of exits					
		a	Fire check door	NA	NA	NA	
		b	Pressurization	NA	NA	NA	
	D	No. of continuous staircases to terrace			01 no	02 nos. ✓	MR
	E	Width of corridor			1.50 mtrs.	1.80 mtrs & 1.50 mtrs ✓	MR
	F	Door size			01 mtrs	01 mtrs ✓	MR
03.	Compartmentation:						
	A	Fire check door			NA	NA	NA
	B	Sealing of electrical shafts			NA	NA	NA
	C	Fire rating of shaft door			NA	NA	NA
	D	Water curtain			NA	NA	NA
	E	Fire dampers			NA	NA	NA
04.	Smoke Management System:						
	A	Basement			Required	Provided ✓	MR
	B	Upper floor			Required	Provided	MR

N/13

Crescent School, Located at Road No. 66, Near Metro Pillar No. 200, Maujpur Road, Delhi-110053.

05.	Fire Extinguisher:			
A	Total numbers	16 nos.	Provided	MR
B	Types	ABC/CO ₂	ABC/CO ₂	MR
C	ISI marking	ISI marked	ISI marked	MR
06.	First-Aid-Hose Reel:			
A	Total numbers of each floor	01 nos	01 nos	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	05 mm	05 mm	MR
07.	Automatic Fire Detection and Alarming System:			
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
08.	MOEFA:	Required	Provided	MR
09	Public Address System:	Required	Provided	MR
10.	Automatic Sprinkler System:			
A	Basement	Required	Provided	MR
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:			
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12.	Yard Hydrants:			
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13.	Pumping Arrangements:			
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 m	40 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

(W)

✓


N/14



Crescent School, Located at Road No. 66, Near Metro Pillar No. 200, Manjpur Road, Delhi - 110053.



14. Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	15,000 liters	15,000 liters	MR
15. Exit Signage:		Required	Provided	MR
16. Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17. Standby Power Supply:		N/A	N/A	N/A
18. Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19. Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20. Special Fire Protection systems for protection of special Risks, if any:		NA	N/A	N/A


The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view of the compliance of minimum standards of fire prevention and fire safety measures required as per Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011, under the rules the FSC issued vide letter no. F6/DFS/MS/School/2021/NDZ/532 dated 26/07/2021, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended to be renewed.


 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (Laxmi Nagar)

DY. CFO/NDZ

 C.F.O.



 Director


Sir. F/T Letter is Auted for Sign. Please

 Director
