

e/33





**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2024/WZ/ 525


Dated: 27/08/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Ishani Enterprises located at E-368, Sector 5, Bawana Industrial Area, Bawana, Delhi-110039 comprised of Basement, Ground plus Two upper floors was issued fire safety certificate vide Letter No. F6/DFS/MS/2019/673 dated 29/03/2019 have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 12/08/2024 in the presence of Sh. Sanjeev Khurana and that the building premise is fit for occupancy under "Class Industrial Building Group G-2 (ii)" with effect from 27/08/2024... for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 27/08/2024... at New Delhi by

  
(Anil Garg)  
Director  
Ph. 011-23414000



**Conditions for the validity of Fire Safety Certificate:**

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Copy to :-

1. M/s Ishani Enterprises located at E-368, Sec-5, DSII DC Bawana, Delhi-110039.
2. The Dy. Drugs Controller/ Licensing Authority, Drug Control department, F-17, Karkardooma, Delhi- 110032.

**INSPECTION REPORT**

1. Name & address of the building : M/s Ishani Enterprises located at E-368, Sec. 5, Bawana Industrial Area, Bawana, Delhi- 110039.
2. Type of Occupancy : Industrial G- 2(ii)
3. Building Comprised of : Basement, Ground plus Two upper floors.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2019/673 dated 29/03/2019
6. Fire Safety directives letter No : NBC Part- IV
7. Date of inspection : 12/08/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers  
From the building side : Sh. Sanjeev Khurana
10. Year of Construction : 2007
11. Applicant's letter No. : Outdoor Diary No. 4638 dated 27/07/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV/ Inspection report dated 14/03/2019	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	6 m	9 m	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	01	01	MR(old case)
	• Basements	01	01	MR(old case)
	<b>b. Width of staircases</b>			
	• Upper Floor	1.25 m	Provided	MR
	• Basements	1.25 m	Provided	MR
	<b>c. Protection of exits</b>			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	<b>d. No. of continuous staircases to terrace</b>	01	Provided	MR
	<b>e. Width of Corridor</b>	NA	NA	NA
	<b>f. Door Size</b>	1 m	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	Required	Exhaust Fan Provided	MR
	• Upper floors	Required	Naturally Ventilated	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	08	10	MR
	• Types	ABC/CO2 Type	ABC/ CO2 Type	MR
	• IS marking	Required	Provided	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

N-17

	• Hooters' Location	NA	NA	NA
8.	<b>MOEFA</b>	NA	NA	NA
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	10,000 ltrs	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	<b>Standby power supply</b>	NA	NA	NA
18.	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA

W

Fire Control Room

• Detector System Panel	NA	NA	NA
• Flow Switch Panel	NA	NA	NA
• PA System Panel	NA	NA	NA
• Battery backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA
Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter number F6/DFS/MS/WZ/2024/333 dated 14/06/2024.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2019/673 dated 29/03/2019 under Rule 37 of the Delhi Fire Service Rules, 2010.

... 27.8  
 dated... 19/8/2024

DO (B.W)

R/S  
 13/08/2024

By CFO (WZ)

[Signature]  
 19/8

CFO/

[Signature]  
 20/8/2024

Director  
 21/8/24

[Signature]  
 ADO (B.W)  
 13/8/24  
 Signature of Inspecting Officer  
 Name : Rajeev Kumar Sinha  
 Designation : ADO/B.W.

Action on dir. FT letter is put up for sign/keep

Director  
 21/8/24

[Signature]  
 ADO (B.W)  
 21/8/24

m