

C112

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/349

Dated: 27/08/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Naaz Guest House situated at 734, Kabari Bazar, Jama Masjid, Delhi - 06, comprised of Ground + 4 upper floors: Ground floor - (commercial), 1st floor - (12 guest rooms + 01 staff room + reception), 2nd floor - (10 guest rooms + 02 store rooms), 3rd floor - (05 guest rooms + 04 staff rooms) & 4th floor- (not in use), total 27 guest rooms was granted FSC by this department vide letter no. F6/DFS/MS/GH/NDZ/2021/74 dated 05.02.2021. The building/premises was re-inspected by officer concerned of this department on 12.08.2024 in presence of Mohd. Danish (Owner) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. The owner has submitted an affidavit on 12.11.2019 stating not to use any floor above third floor for any purpose. Accordingly, the premises is fit for occupancy of (Group-A-1) "Residential", 1st floor - (12 guest rooms), 2nd floor - (10 guest rooms) & 3rd floor - (05 guest rooms) for total 27 guest rooms upto 3rd floor only with effect from ...27/08/2024... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 subject to condition printed below.

Issued on27/08/2024.....at New Delhi by


(Atul Garg)
Director
Delhi Fire Service o/c
Tel: 011-23414000
24/8

Copy to:-

1. The Commissioner, MCD:- to kindly ensure the occupancy as detailed above & deviation, if any.
2. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2024072411496 dated 24.07.2024.
3. The Licensee, M/s Naaz Guest House at 734, Kabari Bazar, Jama Masjid, Delhi - 06.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
9. The occupancy of above 3rd floor not allowed as per clause 7.31 in UBBL-2016.

INSPECTION REPORT

1	Name & address of the building	M/s Naaz Guest House at 734, Kabari Bazar, Jama Masjid, Delhi - 06.		
2	Building is comprised of	Ground + 04 upper floors Ground floor – (commercial use) 1 st floor – (12 guest rooms + 01 staff room + reception) 2 nd floor – (10 guest rooms + 02 store rooms) 3 rd floor – (05 guest rooms + 04 staff rooms) 4 th floor- (not in use as per affidavit dated 12.11.2019)		
3	Type of occupancy	Residential Group A-1		
4	Type of case	Renewal (old case)		
5	Details of previous FSC	F6/DFS/MS/GH/NDZ/2021/74 dated 05.02.2021		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	12.08.2024		
8	Name of the inspecting officers	Sumit Kumar, ADO (SPM)		
9	Name of the designation of officer from the building side	Mohd. Danish (Owner)		
10	Year of construction	Old		
11	Applicant's letter no.	Online application no. 2024072411496 dated 24.07.2024		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/ NMR
1	Access To Building:			
	Road width	NA	08 m	NA
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 no.	01 no.	MR
	b Basement	NA	NA	NA
	B Width of staircases			
	a Upper floor	80 cms.	96 to 140 cms.	MR
	b Basement	NA	NA	NA
	C Protection of exits			
	a Fire check door	Required	Provided	MR
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	NA	NA	NA
	E Width of corridor	NA	NA	NA
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke Management System:			
	A Upper floors	12 ACPH	Provided	MR
	B Basements	NA	NA	NA

5.	Fire Extinguisher:				
	A	Total numbers	06 nos.	06 nos.	MR
	B	Types	CO ₂ & ABC	Provided	MR
	C	ISI marking	Required	Provided	MR
6	First-Aid-Hose Reels:				
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 m	30 m	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection And Alarming System:				
	A	Type of detectors (CO type)	Required	Provided	MR
	B	Location of main panel	Required	Provided at 1 st floor	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	Required	Provided	MR
	E	Hooters	Required	Provided	MR
8	MOEFA:		NA	NA	NA
9	Public Address System:		Required	Provided	MR
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants:				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements:				
	A	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
	B	Terrace level			
	a)	Discharge of pump	225 LPM	225 LPM	MR
	b)	Head of the pump	40 m	40 m	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage For Fire Fighting:				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	D	Access to tank	NA	NA	NA
	E	Overhead tank capacity	2,500 ltrs.	2,500 ltrs.	MR
15	Exit Signage:		Required	Provided	MR
16	Provision of Lifts:				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Firemen's grounding switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply:		Required	Provided	MR
18	Refuge Area:				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA
19	Fire Control Room :				
	A	Detector system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	Pa system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plans	NA	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:		NA	NA	NA

The fire protection systems provided in the building were tested, checked at randomly and found functional at the time of inspection.

Shortcomings communicated vide letter No.F6/DFS/MS/GH/NDZ/2024/234 dated 16/05/2024 has been rectified.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No F6/DFS/MS/GH/NDZ/2021/74 dated 05.02.2021 is recommended to be renewed upto 3rd floor only, under Rule 35 of the Delhi Fire Service Rules 2010.

[Signature]
14/08/2024

Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (CD)

[Signature]
14/8/24

[Signature]
Dy. C.F.O. (M2)

[Signature]
16/08/24

[Signature]
C.F.O.

[Signature]
19/8/24
Director

[Signature]