



No.F6/DFS/MS/School/SZ/2024 / 825

Dated: 27/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Sr. Sec. School No. 2 (Morning shift)/ Govt. Boys Sr. Sec. School No. 3 (Evening shift)**, located at **Badarpur New Delhi-44**, School ID no. 1925054 (Morning shift), School ID no. 1925247 (Evening shift), Building ID no. 19251202, comprised of four blocks: 1st & 2nd blocks – Ground + 01 upper floor each and 3rd & 4th blocks – Ground + 03 upper floor each, was granted Fire Safety Certificate by this department vide letter no.- F6/DFS/MS/School/2021/SZ/657 dated 27.08.2021. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 14.08.2024 in the presence of Mr. Manisha Vaish (Principal) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises (1st & 2nd blocks – Ground + 01 upper floor each and 3rd & 4th blocks – Ground + 03 upper floor each) is fit for occupancy of **“Group B ‘Educational Building’** with effect from 27/08/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 27/08/2024 at New Delhi by.


(Anil Garg)
Director
Delhi Fire Service
21.8.24 w

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Govt. Girls Sr. Sec. School No. 2 (Morning shift)/ Govt. Boys Sr. Sec. School No. 3 (Evening shift), located at Badarpur New Delhi-44.

Conditions for the validity of Fire Safety Certificate:-

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

2/22

INSPECTION REPORT

1	Name and address of the building:	Govt. Girls Sr. Sec. School No. 2 (Morning shift)/ Govt. Boys Sr. Sec. School No. 3 (Evening shift), located at Badarpur New Delhi-44. School ID no. 1925054 (Morning shift) School ID no. 1925247 (Evening shift) Building ID no. 19251202			
2	Building is comprised of	Comprised of four blocks:- 1 st block – Ground + 01 upper floor 2 nd block – Ground + 01 upper floor 3 rd block – Ground + 03 upper floors 4 th block – Ground + 03 upper floors			
3	Type of occupancy	Educational Building Group -B			
4	Type of case:	Renewal			
5	Details of previous FSC:	F6/DFS/MS/School/2021/SZ/657 dated 27.08.2021			
6	Fire safety directives no.:	1 st & 2 nd block as DOE circular dated 1.3.2011 & 3 rd & 4 th block as NBC PART-IV & UBBL.			
7	Date of inspection:	14.08.2024			
8	Name of the inspecting officer:	Rajesh Kumar Shukla, ADO (M. Road)			
9	Name and designation of the officer from the building side:	Mr. Manisha Vaish (Principal)			
10	Year of construction:	1 st & 2 nd blocks -2008 & 3 rd & 4 th blocks -2016			
11	Reference letter no.:	Outdoor diary no. 2784 dated 11.06.2024			
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirements	Provide at site	Remarks MR/NMR	
1	Access to Building				
	A	Road width	6.0 mtrs.	6.0 mtrs.	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of staircase:			
	a)	Upper floor	1 st block – 2 nos. 2 nd block – 2 nos. 3 rd block – 1 no. 4 th block – 3 nos.	1 st block – 2 nos. 2 nd block – 3 nos. 3 rd block – 1 no. 4 th block – 3 nos.	MR
	b)	Basements	NA	NA	NA
	B	Width of the staircase:			
	a)	Upper floor	1.50 m each blocks	1 st block- 1.7 m, 1.84 m 2 nd block -1.84 m, 1.84 m, 1.45 m 3 rd block- 1.70 m 4 th block- 1.60 m each	MR
	b)	Basements	NA	NA	NA
	C	Protection of exits			
	a)	Fire check door	NA	NA	NA
	b)	Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	1 no. each block	Provided	MR
	F	Width of the corridor	1.5 m each block	1.5 m each block	MR
	E	Door size	1.0 m for class room	1.0 m for class room	MR
3	Compartmentation:				
	A	Fire check doors	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Upper floors	NA	NA	NA
	B	Basements	NA	NA	NA
5	Fire Extinguishers				
	A	Total numbers	40 nos.	45 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	Required	Provided	MR

RE
VE

AT

Mc
44
25

o.
it
/a
ety
se
b)
pe
r

ell

a
)

7
e
)

1

01

6	First Aid Hose reel			
A	Total no. at each floor	3 rd block – 1 no. 4 th block – 3 nos.	3 rd block – 1 no. 4 th block – 3 nos.	MR
B	Length of hose reel	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS)			
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate power source	NA	NA	NA
E	Hooter's location	NA	NA	NA
8	MOEFA	NA	Provided	NA
9	Public Address System	NA		
10	Automatic Sprinkler System			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants			
A	Size of the riser/down comer	NA	NA	NA
B	No. Of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
12	Yard Hydrants			
A	Total no. of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13	Pumping Arrangements			
A	Ground Level			
	a)	Discharge of main pump	NA	NA
	b)	Head of main pump	NA	NA
	c)	Number of main pump	NA	NA
	d)	Discharge of jockey pump	NA	NA
	e)	Head of jockey pump	NA	NA
	f)	Discharge of standby pump	NA	NA
	g)	Head of standby pump	NA	NA
	h)	Auto starting/ manual stopping	NA	NA
B	Terrace Level			
	a)	Discharge of terrace pump	3 rd block – 450 LPM 4 th block – 450 LPM	2 nos. of 450 LPM each 3 rd & 4 th blocks
	b)	Head of terrace pump	40 m	40 m
	c)	Alternate power supply	Required	Provided
	d)	Auto starting of pump	Required	Provided
14	Captive Water Storage for Fire Fighting			
A	Underground tank capacity	NA	NA	NA
B	Draw off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
E	Access to tank	NA	NA	NA
D	Overhead tank capacity	3 rd block – 10,000 Ltrs 4 th block – 10,000 Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of lift			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Fireman switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	Standby Power Supply	NA	NA	NA

2/24

Govt. Girls Sr. Sec. School No. 2 (Morning shift)/ Govt. Boys Sr. Sec. School No. 3 (Evening shift), located at Badarpur New Delhi-44.

18	Refuge Area			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room			
A	Fire detection system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any			

LEGENDS:-Meeting requirement (MR), Not meeting requirement (NMR), Not applicable (NA), Provided but not functional (PNF).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no F6/DFS/MS/School/2021/SZ/657 dated 27.08.2021 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

[Signature]
21.8.24

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

DO (SD)
[Signature]
21/8/24

CFO / *[Signature]*
21/8/2024
Director
[Signature]
23/8/24
[Signature]