



7-62
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/WZ/School/2024/ 837

Dated: 27/08/2024

FIRE SAFETY CERTIFICATE

Certified that the S.K.V. No.1, located at Chand Nagar, New Delhi -110018, comprised of Three Blocks (BL-A = Ground + 3, BL-B = Ground + 3 & BL-C = Ground + 1 upper floor) (Except BL-D = Ground + 2 upper floors) owned/ occupied by S.K.V. No.1 has already issued FSC by this department vide letter No. F6/DFS/MS/School/WZ/2022/815 dated 29/07/2022 for Block C = G + 1 & Block D = G + 2 & F6/DFS/MS/School/2020/363 dated: 22/09/2020 for G + 3 upper floors (Block A & B). The premises was re-inspected by officer concerned of this department on 13/08/2024 in the presence of Smt. Neeti Bharara Oberoi (Vice principal) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010/DOE Circular No – F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by the Director of Education, and that the building/premises is fit for occupancy class “Educational” Group-B, with effect from ...27/08/2024...for a period of three years subject to the conditions mentioned below:-

Issued on 27/08/2024 at New Delhi by


(Atul Garg)
Director

Copy to: -

1. The Principal, S.K.V. No.1, located at Chand Nagar, New Delhi -110018.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

INSPECTION REPORT

1. Name & address of the building	S.K.V. No.-1, Chand Nagar, New Delhi - 110018. New Blocks (School ID- 1514011)
2. Type of Occupancy	Educational (Three Blocks) (BL-A = Ground + 3, BL-B = Ground + 3 & BL-C = Ground + 1 upper floor) (Except BL-D = Ground + 2 upper floors)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/WZ/2022/815 dated 29/07/2022 for G+1 & G+2 upper floors (Block C & D) & F6/DFS/MS/School/2020/363 dated: 22/09/2020 for G + 3 upper floors (Block A & B)
5. Fire Safety directives letter No	DOE circular 3298-3398 dated 01/03/2011
6. Date of inspection	13/08/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Smt. Neeti Bharara Oberoi
9. Year of Construction	1976 (G+1 & G+2) & 2016-2017 (G+3) (As per previous insp. report dtd.-11/09/2020)
10. Applicant's letter No.	Email Dated 15/07/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 Mtr.	Provided	MR
	• Gate width	4.5 Mtr.	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	BL-A & B = 2 BL-C = 1	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 Mtr.	BL-A & B = 1.5m x 2 BL-C = 1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5 Mtr.	Provided	MR
	g. Door Size	1m.	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

S.Y

2/32

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 nos. CO ₂ , ABC type ISI marked	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 each block (A & B) 30 m 5 mm	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA NA NA	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> NA NA NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA NA NA NA NA NA 450lpm each block 40 m Required Required	<ul style="list-style-type: none"> NA NA NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided 	<ul style="list-style-type: none"> NA NA NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 10,000 ltrs in each block	<ul style="list-style-type: none"> NA NA NA NA Provided 	<ul style="list-style-type: none"> NA NA NA NA MR

		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Earlier all the shortcomings which was issued by this department have been complied by the school management.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/WZ/2022/815 dated 29/07/2022 for G+1 & G+2 upper floors (Block C & D) & F6/DFS/MS/School/2020/363 dated: 22/09/2020 for G + 3 upper floors (Block A & B) renewal under rule 35 of the Delhi Fire Service rule 2010, is recommended.

ADO MN
5/08/2024

DCFO/...../11/.....
Dated.....14/08/2024

(Signature)
16/8

(Signature)
16/8

CFD
19/8/2024
Director
21/8/24

(Signature)
16/8/2024

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

for your kind personal & signature please
Sir, F.T is put up
(Signature)
21/8/2024