



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 836

Dated: 27/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **Sri Ram Shiksha Vidyalaya** located at Plot No-357, Village Kapashera, New Delhi-110037 (School ID: 1821264), comprised of ground plus two upper floors, owned/occupied by Sri Ram Shiksha Samiti (Regd.), has already been issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2020/SZ/397 dated 05/10/2020. The school premise was re-inspected by the officer concerned of this department on 09/08/2024 in the presence of Ms. Anju Bala (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirement in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **Group-B** (Educational) with effect from 27/08/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/08/2024 at New Delhi by

(ATUL KARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Sri Ram Shiksha Vidyalaya located at Plot No-357, Village Kapashera, New Delhi-110037
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

N-13

INSPECTION REPORT				
1.	Name & address of the building	Sri Ram Shiksha Vidyalaya at Plot No. 357, Village Kapashera, New Delhi-110037 (School ID: 1821264)		
2.	Type of Occupancy	Educational Group-B (School)		
3.	Building Comprised of	Ground plus two upper floors.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/School/2020/SZ/397 Dt. 05/10/2020		
6.	Fire Safety directives Letter No.	Nil		
7.	Date of inspection	09/08/2024		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Ms. Anju Bala (Principal)		
10.	Year of Construction	2020		
11.	Applicant's letter No	336/2024/SRSV dated 25/07/2024, through Outdoor Diary No. 4598 dated 26/07/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required	Approachable	MR
		NA	4.5m	NA
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02 Nos	02 Nos	MR
	<ul style="list-style-type: none"> Upper floors Basements 	NA	NA	NA
	b. Width of staircases	1.5m	1.5m (each)	MR
	<ul style="list-style-type: none"> Upper floors Basements 	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	One	Two	MR
	e. Width of Corridor	1.5m	2m	NA
	f. Door Size (Classroom / MP Hall)	1m / 1.2m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	10 Nos	10 Nos	MR
		ABC/ CO ₂	ABC & CO ₂	MR
		ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection systems for protection of special risks, if any;	NA	NA	NA

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection. The shortcomings communicated vide this department letter No. F.6/DFS/MS/School/2024/SZ/14 dated 17/01/2024 found complied,

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2020/SZ/397 dated 05/10/2020, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S. Kumar
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)

DO (SD)

mevl
 17/8/24

cfo
 18/8/2024

Director
 19/8/24
ADU/SJ

Sir, FT letter is put up for your sign. pl

Director
 23/8/24

S. Kumar
 22/08/24