



No.F6/DFS/MS/School/SZ/2024/ 842

Dated: 30/08/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Cambridge School located at Srinivas Puri, Ring Road, New Delhi-65, comprised of Ground + 02 upper floors was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2021/SZ/617 dated 16.08.2021. The school building was re-inspected by a team of officers concerned of this department on 28.08.2024 in the presence of Mrs. Madhavi Goswami (Principal) and found that school building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the school premises/building comprised of Ground + 02 upper floors is fit for occupancy of Group B "Educational Building" (School) with effect from 30/08/2024..... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 30/08/2024.....at New Delhi by

  
(Atul Gang)  
Director  
Delhi Fire Service  


**Copy to:-**

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Cambridge School located at Srinivas Puri, Ring Road, New Delhi-65.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.



2/25

INSPECTION REPORT						
1	Name & address of the building	M/s Cambridge School located at Srinivas Puri, Ring Road, New Delhi-65.				
2	Building is comprised of	Ground + 02 upper floors				
3	Type of occupancy	Group B- Education building				
4	Type of case	Renewal				
5	Details of previous FSC	F6/DFS/MS/School/2021/SZ/617 dated 16.08.2021				
6	Fire safety direction letter no.	Nil				
7	Date of inspection	28.08.2024				
8	Name of the inspecting officers	Manoj Kumar Sharma, DO (SD) & Rajesh Kumar Shukla, ADO (M. Road)				
9	Name of the designation of officer from the building side	Mrs. Madhavi Goswami (Principal)				
10	Year of construction	1990				
11	Applicant's letter no.	Outdoor diary no. 5304 dated 14.08.2024				
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per rule 35 (6)	Provided at site	Remarks MR/NMR		
1	<b>Access to Building:</b>					
	A	Road width	6.0 m	12.0 m	MR	
	B	Gate width	4.5 m	Provided	MR	
	C	Width of internal road	NA	NA	NA	
2	<b>Number, Width, Type and Arrangement of Exits:</b>					
	A	Number of staircases				
		a	Upper floor	04 nos.	04 nos.	MR
		b	Basement	NA	NA	NA
	B	Width of staircases				
		a	Upper floor	1.50 m	2.0 m of 2 nos. & 1.25 m of 2 nos.	MR
		b	Basement	NA	NA	NA
	C	Protection of exits				
		a	Fire check door	NA	NA	NA
		b	Pressurization	1.50 m	Provided	MR
	D	No. of continuous staircases to terrace	03 nos.	Provided	MR	
	E	Width of corridor	NA	NA	NA	
	F	Door size	1.0 mtrs. (for class rooms)	Provided	MR	
3	<b>Compartmentation:</b>					
	A	Fire check door	NA	NA	NA	
	B	Sealing of electrical shafts	NA	NA	NA	
	C	Fire rating of shaft door	NA	NA	NA	
	D	Water curtain	NA	NA	NA	
	E	Fire dampers	NA	NA	NA	
4	<b>Smoke Management System:</b>					
	A	Basement	NA	NA	NA	
	B	Upper floor	Required	Provided	MR	
5.	<b>Fire Extinguisher:</b>					
	A	Total numbers	39 nos.	39 nos.	MR	
	B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR	
	C	ISI marking	ISI Marked	Provided	MR	
6	<b>First-Aid-Hose Reel:</b>					
	A	Total numbers of each floor	04 nos.	04 nos.	MR	
	B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR	
	C	Nozzle diameter	05 mm	05 mm	MR	

W DL

<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>			
<b>A</b>	Type of detectors	NA	NA	NA
<b>B</b>	Location of main panel	NA	NA	NA
<b>C</b>	Location of repeater panel	NA	NA	NA
<b>D</b>	Alternate source of power	NA	NA	NA
<b>E</b>	Hooters	NA	NA	NA
<b>8</b>	<b>MOEFA:</b>	NA	Provided	NA
<b>9</b>	<b>Public Address System:</b>	NA	Provided	NA
<b>10</b>	<b>Automatic Sprinkler System:</b>			
<b>A</b>	Basement	NA	NA	NA
<b>B</b>	Upper floor	NA	NA	NA
<b>C</b>	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>			
<b>A</b>	Size of riser/down-comer	NA	NA	NA
<b>B</b>	Number of hydrants per floor	NA	NA	NA
<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants:</b>			
<b>A</b>	Total number of hydrants	NA	NA	NA
<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>			
<b>A</b>	<b>Ground level</b>			
<b>a)</b>	Discharge of main pump	NA	NA	NA
<b>b)</b>	Head of main pump	NA	NA	NA
<b>c)</b>	Number of main pumps	NA	NA	NA
<b>d)</b>	Jockey pump out put	NA	NA	NA
<b>e)</b>	Jockey pump head	NA	NA	NA
<b>f)</b>	Standby pump out put	NA	NA	NA
<b>g)</b>	Standby pump head	NA	NA	NA
<b>h)</b>	Auto starting /manual stopping	NA	NA	NA
<b>i)</b>	Pump house access	NA	NA	NA
<b>B</b>	<b>Terrace Level</b>			
<b>a)</b>	Discharge of pump	450 LPM	450 LPM	MR
<b>b)</b>	Head of the pump	40 mrts	40 mrts	MR
<b>c)</b>	Power supply	Required	Provided	MR
<b>d)</b>	Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>			
<b>A</b>	Underground tank capacity	NA	NA	NA
<b>B</b>	Draw-off connection	NA	NA	NA
<b>C</b>	Fire service inlet	NA	NA	NA
<b>D</b>	Access to tank	NA	NA	NA
<b>E</b>	Overhead tank capacity	10,000 ltrs	10,000 ltrs	MR
<b>15</b>	<b>Exit Signage:</b>	Required	Provided	MR
<b>16</b>	<b>Provision of Lifts:</b>			
<b>A</b>	Pressurization of lift shaft	NA	NA	NA
<b>B</b>	Pressurization of lift lobby	NA	NA	NA
<b>C</b>	Communication in lift car	NA	NA	NA
<b>D</b>	Firemen's grounding switch	NA	NA	NA
<b>E</b>	Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply:</b>	NA	NA	NA
<b>18</b>	<b>Refuge Area:</b>			
<b>A</b>	Total area	NA	NA	NA
<b>B</b>	Location	NA	NA	NA



19	<b>Fire Control Room:</b>				
	<b>A</b>	Detector system panel	NA	NA	NA
	<b>B</b>	Flow switch panel	NA	NA	NA
	<b>C</b>	PA system panel	NA	NA	NA
	<b>D</b>	Battery backup	NA	NA	NA
	<b>E</b>	Building floor plans	NA	NA	NA
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>		NA		NA

**LEGENDS: Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

The shortcomings issued to the building by this department vide letter no. F6/DFS/MS/School/SZ/2024/456 dated 19.07.2024 has been rectified by the school management.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/School/2021/SZ/617 dated 16.08.2021 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.





Signature of the Inspecting Officer  
Name Manoj Kumar Sharma  
Designation DO (SD)



Signature of the Inspecting Officer  
Name Rajesh Kumar Shukla  
Designation ADO (M. Road)

CFO

  
29/07/2024  
  
Director  
29/07/24  
