



No. F6/DFS/MS/School/NDZ/2024/ 845

Dated: 30/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **David Modal Senior Sec. School** located at **Main Road Tukmirpur, Delhi - 110090**, building comprised of **ground plus three upper floors (Two separate blocks)** was granted owned/occupied by **David Modal Senior Sec. School** was issued FSC vide letter No. F6/DFS/MS/School/2021/684 dated 31/08/2021. The School building was re-inspected by the officer concerned of this department on 20/08/2024 in presence of Mr. Rambir Singh (Manager) and observed that all the fire prevention and fire safety requirements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building**" (**Group - B**) with effect from 30 /08/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 30/08/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, B- Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, David Modal Senior Sec. School located at Main Road Tukmirpur, Delhi - 110090.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/23

INSPECTION REPORT

1	Name & address of the building	David Modal Senior Sec. School located at Main Road Tukmirpur, Delhi - 110090.		
2	Building is comprised of	Ground plus three upper floors (Two separate blocks)		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2021/684 dated 31/08/2021		
6	Fire safety directives letter no.	NBC Part - IV		
7	Date of inspection	20/08/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (Laxmi Nagar)		
9	Name of the designation of officer from the building side	Mr. Rambir Singh (Manager)		
10	Year of construction	1992 & 2018		
11	Applicant's letter no.	Outdoor Dairy No. 5032 Dated 07/08/2024		
S. No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building:			
	A	Road width	6.0 mtrs.	6.0 mtrs. ✓ MR
	B	Gate width	4.5 mtrs.	5.0 mtrs. ✓ MR
	C	Width of internal road	N/A	N/A ✓ N/A
2.	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
	a	Upper floor (old block)	02 nos.	02 nos. ✓ MR
		Upper floor (New block)	02 nos.	02 nos. ✓ MR
	b	Basement	N/A	N/A ✓ N/A
	B	Width of staircases		
	a	Upper floor	1.50 mtrs.	1.50 meters each ✓ MR
		Upper floor (New block)	1.50 mtrs.	1.50 mtrs. each ✓ MR
	b	Basement	N/A	N/A ✓ N/A
	C	Protection of exits		
	a	Fire check door	N/A	N/A ✓ N/A
	b	Pressurization	N/A	N/A ✓ N/A
	D	No. of continuous staircases to terrace	02 no.	02 no. ✓ MR
	E	Width of corridor	1.50 meters each block	1.70 mtrs. & 1.50 mtrs. ✓ MR
	F	Door size	1.0 mtr.	1.0 mtr. ✓ MR
3.	Compartmentation:			
	A	Fire check door	NA	NA ✓ NA
	B	Sealing of electrical shafts	N/A	N/A ✓ N/A
	C	Fire rating of shaft door	N/A	N/A ✓ N/A
	D	Water curtain	N/A	N/A ✓ N/A
	E	Fire dampers	N/A	N/A ✓ N/A
4.	Smoke Management System:			
	A	Basement	N/A	N/A ✓ N/A
	B	Upper floor	N/A	N/A ✓ N/A

5. Fire Extinguisher:				
A	Total numbers	18 nos.	18 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor (old block & New Block)	01 no. + 01 no.	01 nos each block & each floors	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8 MOEFA:		N/A	N/A	N/A
9 Public Address System:		N/A	N/A	N/A
10 Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Terrace Level				
A	Discharge of pump each block	450 LPM	450 LPM	MR
B	Head of the pump	40 mtrs.	40 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR


N/25

David Modal Senior Sec. School located at Main Road Tukmirpur, Delhi - 110090.

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 liters in each blocks	10,000 liters in each blocks	MR
		Required	Provided	MR
15	Exit Signage:			
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:			
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2024/352 dated 21/06/2024 by this department have been rectified by the management.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/2021/684 dated 31/08/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed. No file is pending with me before disposal of this case.


 21/8/2024
 Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO (L.N)

~~DY. CFO/NDZ~~

~~C.F.O.~~ *KVP* 22/08/24

~~Director~~ *11/11/2024*

~~Director~~ *29/8/24*

Sir, F.I.T Letter is setup for sign. Please 
 Director *29/8/2024*