




FIRE SAFETY CERTIFICATE

Certified that Restaurant/Eating House located at Suvasini Charitable Trust, Akshardham Temple, NH – 24, IP Extn, Akshardham, Delhi - 110092, comprised of ground plus one upper floors owned/occupied Suvasini Charitable Trust was issued FSC vide letter no. F6/DFS/MS/EH/NDZ/2021/157 dated 28.07.2021. The premises was re-inspected by the officer concerned of this department on dated 17/08/2024 in the presence of Sh. Harish Chimanlal Shastri and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy "Assembly Building" Group D (Restaurant) and valid up to 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 28/08/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE

Copy to:-

1. Sh. Harish Chimanlal Shastri, Suvasini Charitable Trust, Akshardham Temple, NH – 24, IP Extn, Akshardham, Delhi - 110092.
2. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi - 110024. w.r.t. - MHA portal ID - 2024080612274 dated 06/08/2024.

Conditions for the validity of Fire Safety Certificate:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use,of land if any.
7. Basement shall be used strictly as per Building By-Laws 1983.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/29

INSPECTION REPORT

1.	Name & address of the building	Suvasini Charitable Trust located at Akshardham Temple, NH - 24, IP Extn, Akshardham, Delhi - 110092.
2.	Building is comprised of	Ground plus one upper floors
3.	Type of occupancy	Assembly Building Group - D
4.	Type of case	Renewal
5.	Details of previous FSC	F6/DFS/MS/EH/NDZ/2021/157 dated 28.07.2021
6.	Fire safety direction letter no.	NBC Part - IV
7.	Date of inspection	17.08.2024
8.	Name of the inspecting officers	Yashwant Singh Meena (ADO/Laxmi Nagar)
9.	Name of the designation of officer from the building side	Sh. Harish Chimanlal Shastri
10.	Year of construction	2009
11.	Applicant's letter no	MHA Application No. 2024080612274 dated 06/08/2024

S. No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement NBC (Old)	Provided at Site	Remarks MR/NMR
1	Access to building			
a	Road width	12 meters.	30 meters	MR
b	Gate width	NA	NA	NA
c	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
A	Number of staircases			
a	Upper floor	02 nos.	03 nos. ✓	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	1.50 mtrs.	1.35, 1.35 mtrs. & 1.46 mtrs. ✓	MR (Old Case)
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	NA	NA	NA
E	Width of corridor	2.0 meters.	3.0 meters. ✓	MR
F	Door size	2.0 meters.	3.0 mtrs & 1.80 mtrs.	MR
3	Compartmentation			
a	Fire check door	NA	NA	NA
b	Sealing of electrical shafts	Required	Sealed	MR
c	Fire rating of shaft door	NA	NA	NA
d	Water curtain	NA	NA	NA
e	Fire dampers	NA	NA	NA
4	Smoke Management System.			
a	Basement	NA	NA	NA
b	Upper floor	Required	Provided	MR

(u)


5.	Fire Extinguisher			
	a	Total numbers	08 nos.	12 nos. ✓ MR
	b	Types	CO ₂ & ABC	CO ₂ & ABC MR
	c	ISI marking	ISI marked	ISI marked MR
6	First-aid-Hose Reels.			
	a	Total numbers of each floor	02 nos.	03 nos. ✓ MR
	b	Length of hose reel hose	30 mtrs.	30 mtrs. MR
	c	Nozzle diameter	05 mm	05 mm MR
7	Automatic fire detection and alarming system.			
	a	Type of detectors	NA	Heat & Smoke ✓ NA
	b	Location of main panel	NA	Provided NA
	c	Location of repeater panel	NA	Provided NA
	d	Alternate source of power	NA	Provided NA
	e	Hooter	NA	Provided NA
8	MOEFA		Required	Provided MR
9	Public address System.		NA	NA NA
10	Automatic Sprinkler System.			
	a	Basement	NA	NA NA
	b	Upper floors	NA	NA NA
	c	Sprinkler above false ceiling	NA	NA NA
11	Internal Hydrants			
	a	Size of riser	100 mm	Provided MR
	b	Number of hydrants per floor	02 no.	03 no. ✓ MR
	c	Hose Box	02 no.	03 no. MR
12	Yard Hydrants.			
	a	Total number of hydrants	NA	NA NA
	b	Hose Box	NA	NA NA
13	Pumping Arrangements.			
	A	Ground Level		
	a	Discharge of main Pump	NA	NA NA
	b	Head of Main Pump	NA	NA NA
	c	Number of main pumps	NA	NA NA
	d	Jockey pump out put	NA	NA NA
	e	Jockey pump head	NA	NA NA
	f	Standby pump out put	NA	NA NA
	g	Standby pump head	NA	NA NA
	h	Auto starting /manual stopping	NA	NA NA
	i	Pump House Access	NA	NA NA
	B	Terrace Level		
	a	Discharge of pump	450 LPM	450 LPM ✓ MR
	b	Head of the Pump	40 mtrs.	40 mtrs. ✓ MR
	c	Power supply	Required	Provided MR
	d	Auto Starting of pump	Required	Provided MR

W

14	Captive Water Storage for Fire Fighting.			
a	Underground tank capacity	N/A	1, 00,000 Liters.	N/A
b	Draw-off connection	N/A	Provided	N/A
c	Fire service inlet	N/A	Provided	N/A
d	Access to tank	N/A	Provided	N/A
e	Overhead Tank capacity	10,000 liters.	35,000 liters.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
a	Pressurization of Lift Shaft	NA	NA	NA
b	Pressurization of Lift lobby	NA	NA	NA
c	Communication in lift car	NA	NA	NA
d	Firemen's grounding switch	NA	NA	NA
e	Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
a	Total area	NA	NA	NA
b	Location	NA	NA	NA
19	Fire Control Room			
a	Detector system panel	NA	NA	NA
b	Flow switch panel	NA	NA	NA
c	PA system panel	NA	NA	NA
d	Battery backup	NA	Provided	MR
e	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2021/157 dated 28.07.2021 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (Laxmi Nagar)

~~DY.CFO/NDZ~~

ADP
21/08/24

~~C.F.O.~~

ADP
21/08/24

ADP/LN

Sir. RT letter is put up for sign. Please

~~Director~~
21/08/24

ADP
27/8/2024

ADP
21/8/24