



FIRE SAFETY CERTIFICATE

Certified that the **Government Girls Senior Secondary School** located at **Mandoli Extension, Delhi - 110093**, comprised of ground plus three upper floors (New building block), owned/occupied by **Government Girls Senior Secondary School** was issued FSC vide letter No. F6/DFS/MS/School//2021/330 dated 16/04/2021. The School building was re-inspected by the officer concerned of this department on 27/07/2024 in presence of Mr. Sanjay Tyagi (Estate Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building**" (**Group - B**) with effect from 02/09/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 02/09/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

O/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Government Girls Senior Secondary School located at Manadoli Extension, Delhi - 110093.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

M/27

INSPECTION REPORT

1	Name & address of the building	Government Girls Senior Secondary School located at Mandoli Extension, Delhi - 110093.				
2	Building is comprised of	Ground + 03 upper floors. (New Building)				
3	Type of occupancy	Educational Building				
4	Type of case	Renewal				
5	Details of previous FSC	F6/DFS/MS/School//2021/330 dated 16/04/2021				
6	Fire safety direction letter no.	NBC Part - IV				
7	Date of inspection	27.08.2024				
8	Name of the inspecting officers	Yashwant Singh Meena (ADO/L.N)				
9	Name of the designation of officer From the building side	Mr. Sanjay Tyagi (Estate Manager)				
10	Year of construction	2017				
11	Applicant's letter no	Email dated 01/08/2024				
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	NBC Part - IV Requirement	Provided at Site	Remarks MR/NMR		
1	Access to building					
	a	Road width	6.0 mtrs.	18 mtrs	MR	
	b	Gate width	4.5 mtrs.	4.5 mtrs	MR	
	c	Width of internal road	NA	NA	NA	
2	Number, Width, Type and Arrangement of Exits					
	A	Number of staircases				
		a	Upper floor	02 nos.	02 nos.	MR
		b	Basement	NA	NA	NA
	B	Width of staircases				
		a	Upper floor	1.50 mtrs.	1.75 mtrs each.	MR
		b	Basement	NA	NA	NA
	C	Protection of exits				
		a	Fire check door	NA	NA	NA
		b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	01 no.	01 no.	MR	
	E	Width of corridor	1.50 mtrs.	1.72 mtrs.	MR	
	F	Door size	1.0 mtr.	1.0 mtr.	MR	
3	Compartmentation					
	a	Fire check door	NA	NA	NA	
	b	Sealing of electrical shafts	NA	NA	NA	
	c	Fire rating of shaft door	NA	NA	NA	
	d	Water curtain	NA	NA	NA	
	e	Fire dampers	NA	NA	NA	
4	Smoke Management System.					
	a	Basement	NA	NA	NA	
	b	Upper floor	NA	NA	NA	

u

M/28

5. Fire Extinguisher				
a	Total numbers	12 nos.	12 nos.	MR
b	Types	CO ₂ & ABC	CO ₂ & ABC	MR
c	ISI marking	ISI marked	ISI marked	MR
6 First-aid-Hose Reels.				
a	Total numbers of each floor	01 no.	01 no.	MR
b	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
c	Nozzle diameter	05 mm	05 mm	MR
7 Automatic fire detection and alarming system.				
a	Type of detectors	NA	NA	NA
b	Location of main panel	NA	NA	NA
c	Location of repeater panel	NA	NA	NA
d	Alternate source of power	NA	NA	NA
e	Hooter	NA	NA	NA
8 MOEFA		NA	NA	NA
9 Public address System.		NA	NA	NA
10 Automatic Sprinkler System.				
a	Basement	NA	NA	NA
b	Upper floors	NA	NA	NA
c	Sprinkler above false ceiling	NA	NA	NA
11 Internal Hydrants				
a	Size of riser	NA	NA	NA
b	Number of hydrants per floor	NA	NA	NA
c	Hose Box	NA	NA	NA
12 Yard Hydrants.				
a	Total number of hydrants	NA	NA	NA
b	Hose Box	NA	NA	NA
13 Pumping Arrangements.				
A		Ground Level		
a	Discharge of main Pump	NA	NA	NA
b	Head of Main Pump	NA	NA	NA
c	Number of main pumps	NA	NA	NA
d	Jockey pump out put	NA	NA	NA
e	Jockey pump head	NA	NA	NA
f	Standby pump out put	NA	NA	NA
g	Standby pump head	NA	NA	NA
h	Auto starting /manual stopping	NA	NA	NA
i	Pump House Access	NA	NA	NA
B		Terrace Level		
a	Discharge of pump	450 LPM	450 LPM	MR
b	Head of the Pump	40 m	40 m	MR
c	Power supply	Required	Provided	MR
d	Auto Starting of pump	Required	Provided	MR

W


✓

4/29


14	Captive Water Storage for Fire Fighting.				
	a	Underground tank capacity	NA	NA	NA
	b	Draw-off connection	NA	NA	NA
	c	Fire service inlet	NA	NA	NA
	d	Access to tank	Required	Provided	MR
	e	Overhead Tank capacity	10,000 liters.	10,000 liters.	MR
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	a	Pressurization of Lift Shaft	NA	NA	NA
	b	Pressurization of Lift lobby	NA	NA	NA
	c	Communication in lift car	NA	NA	NA
	d	Firemen's grounding switch	NA	NA	NA
	e	Lift Signage	NA	NA	NA
17	Standby power supply		NA	NA	NA
18	Refuge Area.				
	a	Total area	NA	NA	NA
	b	Location	NA	NA	NA
19	Fire Control Room				
	a	Detector system panel	NA	NA	NA
	b	Flow switch panel	NA	NA	NA
	c	PA system panel	NA	NA	NA
	d	Battery backup	NA	NA	NA
	e	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:				


The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2024/167 dated 16/04/2024 by this department has been rectified by the management.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School//2021/330 dated 16/04/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.
No file is pending with me before disposal of this case.


 29/8/2024
 Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO (L.N)

~~DY. CEO/NDZ~~



 29/08/24

C.F.O. 
 30/8/2024

Director 
 2/9/24

Six. F.T Letter is put up for sign. Please

Director 
 2/9/24


 2/9/2024