

455

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 545

Dated: 04/09/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s CNG Filling Station (IGL) Located at Azad Hind Fauj Marg, Sector - 14, Dwarka, New Delhi - 110075 comprised of Ground + 01 Upper Floor was issued NOC vide Letter No. F6/DFS/MS/CNG/2021/SZ/418 dated- 27/08/2021. The premises was re inspected by the officers concerned of this department on 16/08/2024 in the presence of Mr. Dharmendra (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Hazardous" (CNG filling station) with effect from 04/09/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/09/2024 at New Delhi by.


(Atul Garg)
Director,
Delhi Fire Service
o/c

Copy to:

1. Sh. Ajay Khatri DGM - Fire & Safety IGL Bhawan, Plot No 4, Community Centre, Sector-09, R.K Puram, New Delhi - 110022.
2. Mr. Dharmendra (Manager) M/s CNG Filling Station (IGL) Located at Azad Hind Fauj Marg, Sector - 14, Dwarka, New Delhi - 110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: M/s CNG Filling Station (IGL) Located at Azad Hind Fauj Marg, Sector – 14, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Group J: Hazardous (CNG Filling Station)
3. Type of Case : Renewal (Ground + 01 Upper Floor)
4. Details of previous NOC: F6/DFS/MS/CNG/2021/SZ/418dated- 27/08/2021.
5. Fire Safety directives L. No. : OISD - 179/F5/(3A)/DFS/CNG/BP/2010/292
Dated 01/10/2010
6. Date of inspection :16/08/2024
7. Name of the Inspecting Officer :Sh.Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Dharmendra (Manager)
9. Year of Constructio : 2012
10. Applicant's letter No. :IGL/F&S/2024/15/81/1dated 10/07/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/9	Provided at site	Remarks MR/NMR																																															
1.	Access of building																																																		
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<table border="1" style="width: 100%;"> <tr> <td style="width: 25%;">9m</td> <td style="width: 75%;">12 m</td> </tr> <tr> <td>4.5m</td> <td>Directly accessible from road</td> </tr> <tr> <td>NA</td> <td>NA</td> </tr> </table>	9m	12 m	4.5m	Directly accessible from road	NA	NA		<table border="1" style="width: 100%;"> <tr> <td style="width: 25%;">MR</td> <td style="width: 75%;">MR</td> </tr> <tr> <td>MR</td> <td>NA</td> </tr> </table>	MR	MR	MR	NA																																					
9m	12 m																																																		
4.5m	Directly accessible from road																																																		
NA	NA																																																		
MR	MR																																																		
MR	NA																																																		
2.	Number, width, Type & Arrangements of exits																																																		
	<table border="1" style="width: 100%;"> <tr> <td style="width: 50%;">a. Number of staircases</td> <td style="width: 25%;">02 No.</td> <td style="width: 25%;">02 No. As per plan</td> <td style="width: 10%;">MR</td> </tr> <tr> <td> <ul style="list-style-type: none"> • Upper floors • Basements </td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>b. Width of staircases</td> <td colspan="3"></td> </tr> <tr> <td> <ul style="list-style-type: none"> • Upper floors • Basements </td> <td>120cm & 70 cms</td> <td>120cm & 70 cms</td> <td>MR</td> </tr> <tr> <td></td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>c. Protection of exits</td> <td colspan="3"></td> </tr> <tr> <td> <ul style="list-style-type: none"> • Fire check door • Pressurization </td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td></td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>d. No of continuous staircase to terrace</td> <td>NA</td> <td>01</td> <td>NA</td> </tr> <tr> <td></td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>e. Width Of Corridor</td> <td>1 mtr</td> <td>Provided</td> <td>MR</td> </tr> <tr> <td>f. Door Size</td> <td colspan="3"></td> </tr> </table>	a. Number of staircases	02 No.	02 No. As per plan	MR	<ul style="list-style-type: none"> • Upper floors • Basements 	NA	NA	NA	b. Width of staircases				<ul style="list-style-type: none"> • Upper floors • Basements 	120cm & 70 cms	120cm & 70 cms	MR		NA	NA	NA	c. Protection of exits				<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA		NA	NA	NA	d. No of continuous staircase to terrace	NA	01	NA		NA	NA	NA	e. Width Of Corridor	1 mtr	Provided	MR	f. Door Size					
a. Number of staircases	02 No.	02 No. As per plan	MR																																																
<ul style="list-style-type: none"> • Upper floors • Basements 	NA	NA	NA																																																
b. Width of staircases																																																			
<ul style="list-style-type: none"> • Upper floors • Basements 	120cm & 70 cms	120cm & 70 cms	MR																																																
	NA	NA	NA																																																
c. Protection of exits																																																			
<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA																																																
	NA	NA	NA																																																
d. No of continuous staircase to terrace	NA	01	NA																																																
	NA	NA	NA																																																
e. Width Of Corridor	1 mtr	Provided	MR																																																
f. Door Size																																																			
3.	Compartmentation																																																		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<table border="1" style="width: 100%;"> <tr> <td style="width: 25%;">NA</td> <td style="width: 25%;">NA</td> <td style="width: 25%;">NA</td> <td style="width: 25%;">NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA																													
NA	NA	NA	NA																																																
NA	NA	NA	NA																																																
NA	NA	NA	NA																																																
NA	NA	NA	NA																																																
NA	NA	NA	NA																																																



4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	20 nos.	22 Nos.	MR
	• Types	DCP, ABC & CO ₂	Co ₂ 4.5 kg (8Nos.) DCP Trolley of 75 kg (5 Nos.) DCP 10 kgs. (19 Nos.)	MR
	• IS marking	Required	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	Gas & Flame detectors	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Ground Floor	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required no smoking board		Provided MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage			
17.	Standby power supply	Required	Provided DG set 25 kva	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 Flooding	Provided for compressor	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/CNG/2021/SZ/418 dated- 27/08/2021 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday V Singh*
 Designation *AD/DK*

DO/SO
 19/8/21

CF/S2
 20/8/2021
 Director