

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/CGHS/SZ/2024/543

Dated: 04/09/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Pragma C.G.H.S. Ltd. Located at Plot No-1-B, Sector-2, Dwarka, New Delhi-110075 having 05 blocks comprised of ground/stilt + ten upper floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/CGHS/2019/SZ/1624 dated 14/08/2019. The premise was re inspected by the officer concerned of this department on 23/08/2024 in the presence of. Sh. Rajesh Sharma (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Residential Building" Group A-4 with effect from 04/09/2024 for a period of five years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/09/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service.
O/c

Copy to:

1. The President, Pragma C.G.H.S. Ltd. at Plot No-1-B, Sector-2, Dwarka, New Delhi-110075.
2. The Joint Director (Building) DDA, Vikas Sadan, INA, Delhi-110023.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

11/34
INSPECTION REPORT

1. Name & address of the building: Pragma C.G.H.S. Ltd. Located at Plot No-1-B, Sector-2, Dwarka, New Delhi-110075
2. Type of Occupancy : Residential Building "A" (Apartment)
3. Type of Case : Renewal (05 blocks, ground/stilt + ten upper floors)
4. Details of previous NOC : F6/DFS/MS/CGHS/2019/SZ/1624 dated 14/08/19
5. Fire Safety directives L.No. : F6/ DFS /MS/CGHS/02/581 dated 05/04/2002
6. Date of inspection : 23/08/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Rajesh Sharma (Manager)
9. Year of Construction : 2008
10. Applicant's letter No. : Email dated-19/08/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/19, N/20 & N/21	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 mtrs	60 mtrs	MR
	• Gate width	4.5 mtrs	Provided	MR (old case)
	• Width of internal road	6 mtrs	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 each block	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.25 mtr each	1.20m & 1m to 1.08m	MR (Being old case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	02 Nos	Provided	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Ventilation	MR

[Handwritten Signature]

N/35

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02 nos. each floor CO ₂ & WCO ₂ ISI marked	Provided Provided Provided	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 each block 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm 1 each block Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required Required	Provided Provided	MR MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 900 LPM 40 mtrs Required Required	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided Provided Provided Provided	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A MR MR MR MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	200000ltrs Required Required Required Required 20000 ltr each block	200000ltrs Provided Provided Provided Provided Provided	MR MR MR MR MR
15	Exit Signage	Required	Provided	MR

[Handwritten signature]

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car.	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co2 fire extinguisher provided near electric panel	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/CGHS/2019/SZ/1624 dated 14/08/19 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved, the FSC may be issued.

[Signature]
 Signature of the Inspecting Officer.
 Name *Uday Vir Singh*
 Designation *ADDP/DW*

[Signature]
[Signature]
 28/8/24

CFO (S2)

[Signature]
 28/8/2024
 Director
[Signature]
 29/8/24
[Signature]