



FIRE SAFETY CERTIFICATE

Certified that the M/s Shahdara Angels Educational Society (Regd.) located at Plot No. B - 12 & B - 20, Vasundhara Enclave, Delhi - 110096, (school is running ground plus four upper floor only) building comprised of basement, ground plus four upper floors, basement not in use as per affidavit given by the owner 24/08/2024 owned/occupied by M/s Shahdara Angels Educational Society (Regd.), was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/NDZ/2021/654 dated 26/08/2021. The School building was re-inspected by the officer concerned of this department on 22/08/2024 in presence of Mr. Sushant Singh Raghav (Principal) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class **Group B "Educational Building"** for school running on ground plus four upper floors only with effect from 04/09/2024 for a period of **three years**, in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 04/09/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE
@

Copy to:-

1. The Director of Education, GNCT of Delhi, Old Secretartion, Delhi - 110091.
2. The Principal, Shahdara Angels Educational Society (Regd.) located at Plot No. B - 12 & B - 20, Vasundhara Enclave, Delhi - 110096.

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for ground plus four floors only.
2. Basement shall not be used (as per affidavit dated 24.08.2024) for are purpose.
3. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
4. All the means of escape shall be kept free of all the type of obstruction all the time.
5. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
6. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
7. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
8. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
9. At the time of inspection basement is being used for storage purpose.
10. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| 1 | Name & address of the building | M/s Shahdara Angels Educational Society (Regd.) located at Plot No. B - 12 & B - 20, Vasundhara Enclave, Delhi - 110096. | | |
|------|--|--|------------------|---------------------------------|
| 2 | Building is comprised of | Basement, ground plus four upper floors. (School is running ground plus four upper floor only) basement not in use as per affidavit given by the owner 24/08/2024. | | |
| 3 | Type of occupancy | Educational Building | | |
| 4 | Type of case | Renewal | | |
| 5 | Details of previous FSC | F6/DFS/MS/School/NDZ/2021/654 dated 26/08/2021 | | |
| 6 | Fire safety directives letter no. | F6/DFS/MS/BP/2013/351 dated 27/11/2013 | | |
| 7 | Date of inspection | 22/08/2024 | | |
| 8 | Name of the inspecting officers | Yashwant Singh Meena ADO (Laxmi Nagar) | | |
| 9 | Name of the designation of officer from the building side | Mr. Sushant Singh Raghav (Principal) | | |
| 10 | Year of construction | (B+G+02) 2005 & (3 rd & 4 th floors) 2017 | | |
| 11 | Applicant's letter no. | Outdoor Dairy No.5207 dated 12/08/2024 | | |
| S.No | Minimum standard of fire prevention and fire safety U/R 33 | Circular Requirement | Provided at site | Remarks MR/NMR |
| 1 | Access to Building: | | | |
| | A | Road width | 6.0 mtrs. | 18 mtrs. / MR |
| | B | Gate width | 4.5 mtrs | 4.5 mtrs / MR |
| | C | Width of internal road | 6 mtrs | 6 mtrs / MR |
| 2 | Number, Width, Type and Arrangement of Exits: | | | |
| | A | Number of staircases | | |
| | | a | Upper floor | 03 nos. / 03 nos. / MR |
| | | b | Basement | 03 nos. / 04 nos.+ 02 nos / MR |
| | B | Width of staircases | | |
| | | a | Upper floor | 1.50 mtrs / 1.50 mtrs each / MR |
| | | b | Basement | 1.50 mtrs / 1.50 mtrs each / MR |
| | C | Protection of exits | | |
| | | a | Fire check door | Required / Provided / MR |
| | | b | Pressurization | N/A / N/A / N/A |
| | D | No. of continuous staircases to terrace | | 01 no. / 03 nos. / MR |
| | E | Width of corridor | | 1.50 mtrs. / 2.0 mtrs / MR |
| | F | Door size | | 1.0 mtr. / 1.0 mtr / MR |
| 3 | Compartmentation: | | | |
| | A | Fire check door | Required | Provided / MR |
| | B | Sealing of electrical shafts | Required | Provided / MR |
| | C | Fire rating of shaft door | Required | Provided / MR |
| | D | Water curtain | N/A | N/A / N/A |
| | E | Fire dampers | N/A | N/A / N/A |
| 4 | Smoke Management System: | | | |
| | A | Basement | Required | Provided / MR |
| | B | Upper floor | N/A | N/A / N/A |

W

| | | | | | | |
|----|--|-------------------------------|--------------------------------|-----------------------|----------|-----|
| 5 | Fire Extinguisher: | | | | | |
| | A | Total numbers | 20 nos. | 30 nos. | MR | |
| | B | Types | CO ₂ & ABC | CO ₂ & ABC | MR | |
| | C | ISI marking | ISI marked | ISI marked | MR | |
| 6 | First-Aid-Hose Reel: | | | | | |
| | A | Total numbers of each floor | 02 nos. | 02 nos. | MR | |
| | B | Length of hose reel hose | 30 mtrs | 30 mtr | MR | |
| | C | Nozzle diameter | 05 mm | 05 mm | MR | |
| 7 | Automatic Fire Detection and Alarming System: | | | | | |
| | A | Type of detectors | N/A | N/A | N/A | |
| | B | Location of main panel | N/A | N/A | N/A | |
| | C | Location of repeater panel | N/A | N/A | N/A | |
| | D | Alternate source of power | N/A | N/A | N/A | |
| | E | Hooters | Staircase | Provided | MR | |
| 8 | MOEFA: | | Required | Provided | MR | |
| 9 | Public Address System: | | Required | Provided | MR | |
| 10 | Automatic Sprinkler System: | | | | | |
| | A | Basement | Required | Provided | MR | |
| | B | Upper floor | N/A | N/A | N/A | |
| | C | Sprinkler above false ceiling | N/A | N/A | N/A | |
| 11 | Internal Hydrants: | | | | | |
| | A | Size of riser/down-comer | 150 mm | 150 mm | MR | |
| | B | Number of hydrants per floor | 02 nos. | 02 nos. | MR | |
| | C | Hose box | 02 nos. | 02 nos. | MR | |
| 12 | Yard Hydrants: | | | | | |
| | A | Total number of hydrants | 02 nos. | 02 nos. | MR | |
| | B | Hose box | 02 nos. | 02 nos. | MR | |
| 13 | Pumping Arrangements: | | | | | |
| | 1 | Ground level | | N/A | Provided | MR |
| | | A | Discharge of main pump | N/A | 900 LPM | MR |
| | | B | Head of main pump | N/A | 40 m | MR |
| | | C | Number of main pumps | N/A | 01 no | MR |
| | | D | Jockey pump out put | N/A | 450 LPM | MR |
| | | E | Jockey pump head | N/A | 40 m | MR |
| | | F | Standby pump out put | N/A | N/A | N/A |
| | | G | Standby pump head | N/A | N/A | N/A |
| | | H | Auto starting /manual stopping | N/A | Provided | MR |
| | | 2 | Terrace Level | | | |
| | A | | Discharge of pump | 900 LPM | 900 LPM | MR |
| | B | | Head of the pump | 40 m | 40 m | MR |
| | C | | Power supply | Required | Provided | MR |
| | D | Auto starting of pump | Required | Provided | MR | |

| | | | | |
|--|------------------------------|---------------|---------------|-----|
| 14 Captive Water Storage for Fire Fighting: | | | | |
| A | Underground tank capacity | N/A | 50,000 ltrs | MR |
| B | Draw-off connection | N/A | Provided | MR |
| C | Fire service inlet | N/A | Provided | MR |
| D | Access to tank | N/A | Provided | MR |
| E | Overhead tank capacity | 25,000 litres | 25,000 liters | MR |
| 15 Exit Signage: | | Required | Provided | MR |
| 16 Provision of Lifts: | | | | |
| A | Pressurization of lift shaft | N/A | N/A | N/A |
| B | Pressurization of lift lobby | N/A | N/A | N/A |
| C | Communication in lift car | N/A | N/A | N/A |
| D | Firemen's grounding switch | N/A | N/A | N/A |
| E | Lift signage | N/A | N/A | N/A |
| 17 Standby Power Supply: | | Required | Provided | MR |
| 18 Refuge Area: | | | | |
| A | Total area | N/A | N/A | N/A |
| B | Location | N/A | N/A | N/A |
| 19 Fire Control Room: | | | | |
| A | Detector system panel | Required | Provided | MR |
| B | Flow switch panel | Required | Provided | MR |
| C | PA system panel | Required | Provided | MR |
| D | Battery backup | Required | Provided | MR |
| E | Building floor plans | Required | Provided | MR |
| 20 Special Fire Protection systems for protection of special Risks, if any: | | | | N/A |

The fire protection systems provided in the school building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures required as under the rules the FSC issued vide letter No. F6/DFS/MS/School/NDZ/2021/654 dated 26/08/2021, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case.


27/8/2024

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

~~DY.CFO (NDZ)~~

KVP
29/08/24

C.F.O.

Please speak about the height of bldg.

~~DY.CFO (NDZ)~~

KVP

KVP
30/8/2024

Submitted for approval of

Director

2/9/24
ADOLN

KVP
30/8/2024