

c/72

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/2024/ E.H | 283

Dated : 02/09/2024

FIRE SAFETY CERTIFICATE

Certified that the **Evergreen Land Mark Pvt Ltd.** located at **54, Gr. Floor, Janpath, Connaught Place, New Delhi** in a building comprised of two Block – A - Basement + Ground + 03 Upper floor and Block-B(rear side) Ground + 1st floor & **Restaurant running at Ground floor only at B-Block.** The FSC was earlier granted by this department vide letter No.F6/DFS/MS/GH/2021/154 dated 27/07/21 to the said restaurant premises in the name & style M/S Connaught club (Evergreen Landmark Pvt. Ltd.). Now, the restaurant premises was re-inspected by the officers concerned of this department on 22/08/24 in the presence of Mr. Sachdeva and found that the said restaurant premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant premises is fit for occupancy class **Assembly Occupancy , Group-D Restaurant at Ground floor (rear side B-Block) only** and valid up to the period of three year from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 02/09/2024..... at New Delhi by.


Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect , NDMC , Palika Kendra , New Delhi.
2. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. ID No ID No. 2024080212080 dated 02/08/24.
3. The Manager, **Evergreen Land Mark Pvt Ltd**
54, Gr. Floor rear side, Janpath, Connaught Place, New Delhi.

Conditions for the validity of fire safety certificate

1. This FSC is valid only for restaurant (backside) at ground floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape such as exits , corridor , etc shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry”.

N/16

INSPECTION REPORT

1. Name & address of the building: Evergreen Land mark Pvt. Ltd, 54 Ground Floor, Janpath, Connaught Place, New Delhi
2. Type of occupancy:- Assembly Building Group-D
Two Block - A- Basement + Ground + 03 Upper floor and Rear side Block-B Ground + 1st floor, Restaurant running at B-Block, Ground floor only
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/2021/154 dated 27/07/21.
5. Fire safety directives No.- N/A
6. Date of inspection:- 22/08/24.
7. Name of the inspecting officer:- Sh. Ravinder Singh, ADO (CC)
Sh. Rajinder Atwal, DO/ CD
8. Name & designation of officer from the building side:- Mr. Sachdev
9. Year of construction:- Old Heritage Bldg.
10. Applicant's letter No:- ID No 2024080212080 dated 02/08/24.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr	06 mtr. ✓	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 mtr.	02 mtr. & 1.8 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	04 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			

	1) Total number of each floor	02	Provided /	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided /	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	ground floor	Provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Ground floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm /	MR
	2) Number of hydrants per floor	02	02 /	MR
	3) Hose box	02	02 /	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM /	MR
	b) Head of pump	30 mtr.	30 mtr. /	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltr.	10,000 ltr. /	MR

✓

M/18

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	Provided	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & Co2			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/EH/2021/154 dated 27/07/21, renewal under rule 35 of the Delhi Fire Service rules 2010, Accordingly, DFA, is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

[Handwritten Signature]
27/8/24

[Handwritten Signature]
28/8/24

Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Name :- Sh. Ravinder Singh
Designation : ADO (CC)

[Handwritten Signature]
27/8/24

[Handwritten Signature]
28/8/24

C.F.O.
[Handwritten Signature]
29/8/24

Director
[Handwritten Signature]
31/8/24

[Handwritten Signature]

As approved for perusal and signature please

[Handwritten Signature]
29/8/24

[Handwritten Signature]
29/8/24

[Handwritten Signature]
29/8/24