



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Indl./2024/SZ/ 534

Dated: 03/09/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s IndiGo Aircraft Maintenance (Hanger, Support Building & Workshop), Plot Near Peer Baba, Terminal 2, IGI Airport, New Delhi-110037, comprised of Hanger & Workshop: Ground Floor only, Support Building: Ground & 3 Upper Floors, owned/occupied by M/s IndiGo Aircraft Maintenance, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/Indl./2021/SZ/158 dated 10/03/2021. The premise was re-inspected by the officers concerned of this department on 23/08/2024 in presence of Sh. Satya Prakash (AM – Admin) & Sh. Rishabh Bhardwaj (AM – Facility) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group 'G' Industrial Building** with effect from 03/09/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/09/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Sh. Bratindra Chakraborty, M/s InterGlobe Aviation Limited (IndiGo), Room No. 34, Terminal 1D, IGI Airport, New Delhi-110037
2. The Chief Executive Officer, DIAL, New Udaan Bhawan, Opp. Terminal – 3, IGI Airport, New Delhi-110037

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. Any deviation with regard to construction, ventilation, occupancy, electric installation etc., may be got verified from concerned authorities.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1.	Name & address of the building	M/s IndiGo Aircraft Maintenance (Hanger, Support Building & Workshop), Plot Near Peer Baba, Terminal 2, IGI Airport, New Delhi-110037		
2.	Type of Occupancy	Group 'G' Industrial Building		
3.	Building Comprised of	Hanger & Workshop: Ground Floor only Support Building: Ground & 3 Upper Floors.		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/Indl./2021/SZ/158 dtd 10/03/2021		
6.	Fire Safety directives letter No.	F6/DFS/MS/2020/BP/377 dated 30/09/2020/NFPA		
7.	Date of inspection	23/08/2024		
8.	Name of Inspecting Officer	Manoj Kumar Sharma (DO/SD) & Santosh Kumar ADO (S/J)		
9.	Name and designation of Officer from building side	Sh. Satya Prakash (AM – Admin) & Sh. Rishabh Bhardwaj (AM – Facility)		
10.	Year of Construction	2020		
11.	Applicant letter received through	Outdoor Diary No. 5172 dated 12/08/2024		
S. No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	10m	10m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	6m	6m	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4 Nos	4 Nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.12m	1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	4 Nos	Provided	MR
	e. Width of Corridor	2.4m	Provided	MR
	f. Door Size	1.0m	1.20m	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Ground & Upper floors.	Required	Mechanical Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	58 Nos	Provided	MR
	• Types	ABC/CO ₂ /WCO ₂	ABC & CO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	3 Nos	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	Heat, Smoke/ Beam	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	All Areas	Provided	MR
8.	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Ground & Upper Floors	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	3 Nos	Provided	MR
	• Hose Box	3 Nos	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	10 Nos	Provided	MR
	• Hose Box	10 Nos	Provided	MR
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	2280, 3784 & 7000 LPM	Provided	MR
	➤ Head of main pump	135m, 135m & 100m	Provided	MR
	➤ Number of main pumps	5 Nos	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	135m	Provided	MR
	➤ Standby Pump out put	3784 & 7000 LPM	Provided	MR
	➤ Standby Pump Head	135m & 100m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Underground tank capacity	6,30,000 Ltrs	3,15,000 ltrs x 2	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	50,000 Ltr	50,000 Ltr	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Backup	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Cementitious grout over PEB main steel frame for 2 Hr. fire protection, High expansion foam Generation and gas flooding system provided	MR

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/Indl./2021/SZ/158 dated 10/03/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Manoj Kumar Sharma
 Signature of the Inspecting Officer
 Name: Manoj Kumar Sharma
 Designation: DO (SD)

Santosh Kumar
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)

CFO
Wing
 2/9/2024
 Director
 2/9/24
 ADO (SJ)

F.T. M4

Sir, F.T letter is put up for your sig. pl

Manoj Kumar Sharma
 Director
 2/9/24
 M2

Santosh Kumar
 2/9/24