



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Petl/2024/SZ/ 547

Dated: 06 / 09 / 2024

FIRE SAFETY CERTIFICATE

Certified that M/s Batra Car Care Centre (Petrol Pump cum Service Station) at Humayun Road, New Delhi-110003, comprised of single-story building, owned/occupied by M/s Batra Car Care Centre, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/2021/Petl/386 dated 12/08/2021. The premise was re-inspected by the officer concerned of this department on 29/08/2024 in the presence of Sh. Abhishek Kumar Singh (Manager) of the petrol pump and found that said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/ premise is fit for occupancy class "**Group J Hazardous Building**" (Petrol Pump) with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 06/09/2024 at New Delhi by


(ATUL GARG)
 DIRECTOR
 DELHI FIRE SERVICE
 @188E

Copy to: -

1. Authorized Signatory M/s Batra Car Care Centre (Petrol Pump cum Service Station) at Humayun Road, New Delhi-110003

Conditions for the validity of Fire Safety Certificate:

1. "No Smoking" and "Not to use Mobile Phone" sign boards should be displayed in such a manner as to be easily readable by all persons.
2. No trade susceptible to cause ignition of petroleum vapor by generating heat, mechanical/ electric spark should be allowed within the premises and its vicinity.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the employee's working at the petrol pump must know the correct method of operation of fire extinguishers/firefighting.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1	Name & Address of the Building	M/s Batra Car Care Centre (Petrol Pump cum Service Station) at Humayun Road, New Delhi-110003		
2	Type of Occupancy	Group J Hazardous Building		
3	Building Comprised of	Ground Floor only.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/SZ/2021/Pet/386 Dt. 12/08/2021		
6	Fire Safety Directives Letter No	F.5/(3A)/DFS/BP/2002/596 Dt. 11/10/2002		
7	Date of Inspection	29/08/2024		
8	Name of the Inspecting Officers	ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Abhishek Kumar Singh (Manager)		
10	Year of construction	2002		
11	Applicant letter received through	Outdoor Diary No. 5503 dated 22/08/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	NA	18 mtr	NA
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	NA	NA	NA
	➤ Basement.	NA	NA	NA
	b) Width of Staircase			
	➤ Upper floors	NA	NA	NA
	➤ Basement	NA	NA	NA
	c) Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	NA	NA	NA
	e) Width of corridor	NA	NA	NA
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	1 DCP of 70 kg & 15 ABC of 4.5 kg	Provided	MR
	• Types	ABC/DCP/CO ₂	Provided	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	NA	NA	NA
	• Length of hose-reel hose.	NA	NA	NA
	• Nozzle Diameter	NA	NA	NA


7.	Automatic fire detection & alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground floor.	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	NA	NA	NA
	• Number of Hydrant per floor	NA	NA	NA
	• Hose box.	NA	NA	NA
12.	Yard Hydrants.			
	• Total number of hydrants.	NA	NA	NA
	• Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting/Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump.	NA	NA	NA
	➤ Head of pump.	NA	NA	NA
	➤ Power supply.	NA	NA	NA
	➤ Auto starting of pump.	NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity (Used for washing the vehicles).	NA	6000 ltr.	NA
	➤ Draw-off connection.	NA	NA	NA
	➤ Fire Service Inlet.	NA	NA	NA
	➤ Access to tank.	NA	NA	NA
	• Overhead tank capacity.	NA	NA	NA
15.	No Smoking Signage.	Required	Provided (English & Hindi)	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17.	Standby Power Supply	NA	DG Set	NA
18.	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

19.	Fire Control Room. <ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.	Fire buckets filled with sand. No smoking boards & Emergency nos. were found displayed in Hindi & English. No loose electric wiring seen in premises.		MR

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/SZ/2021/Pet/386 dated 12/08/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)

DO (SD)

mm
079


CF *3/9/2021*

Director

AD/SJ

Sir, F.T letter is put up for your sig. p

Director
5/9/22
n


07/09/24