

C-23  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2024/En/292

Dated: 09/09/2024

**FIRE SAFETY CERTIFICATE**

Certified that M/s Bikanervala Foods Pvt. Ltd , Located at Ground Floor & First Floor, Plot No. 10, Sector-12 A, Dwarka, New Delhi in a building comprised of Basement+ Ground +03 Upper Floors, but the restaurant is running at Ground and 1<sup>st</sup> floor was issued FSC vide Letter no. F6/DFS/MS/SZ/2021/218, dated-08/09/2021, The premises was re inspected by the officers concerned of this department on 03-09-2024 in the presence of Sh. Chunnilal (Manager) & Sh. Varun (Employee) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D( At Ground & 1<sup>st</sup> Floor Only) with effect from 09/09/2024 for a period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/09/2024 at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service

Copy to:

1. M/s Bikanervala Foods Pvt. Ltd , Located at Ground Floor & First Floor, Plot No. 10, Sector-12 A, Dwarka, New Delhi
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.
3. The Add. Commissioner of Police (Lic), 1<sup>st</sup> Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.

**Following fire safety directives must be adhered to:-**

1. The staircase at terrace level shall be kept open & free from lock and key & all the exit shall be clear from any obstruction otherwise the FSC shall be null & void
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry

11/10  
**INSPECTION REPORT**

1. Name & address of the building: M/s Bikanervala Foods Pvt. Ltd, Located at Ground Floor & First Floor, Plot No. 10, Sector-12 A, Dwarka, New Delhi.
2. Type of Occupancy: **Group D (Assembly Building) ( At Ground & 1<sup>st</sup> Floor only )**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SZ/2021/218, dated-08/09/2021
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 03/09/2024
7. Name of the Inspecting Officer : Sh. Udaivir Singh ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Chunnilal (Manager) & Sh. Varun (Employee)
9. Year of Construction : 2009
10. Applicant's letter No. : Application No. 2024082112935 Dated -21/08/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/7, N/8 & N/9	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	Provided	MR
	• Gate width	4.5 m	Directly accessible from road	MR(Old Case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	03 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	2 X 150 cm & 100 cm	MR(Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	1 Provided	MR
	e. Width Of Corridor	1.5 mtr	Opening in hall	MR
	f. Door Size	02 m & 01 mtr on GF & 150 & 100 cm on FF	200, 145 & 100 cm on GF & 150, 110 & 100 cm on FF	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

80/6



N/11

4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA Required	NA Natural ventilation	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	09 nos. ABC & CO <sub>2</sub> ISI marked	Provided Provided ISI marked	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 30 mtrs 5mm	Provided Provided provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	Provided NA NA Provided Provided	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA Provided NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm 01 No 01 No	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40 m Required Required	NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA NA Required NA 20,000 ltrs	NA NA Provided NA Provided	NA NA MR NA MR
15	Exit Signage	Required	Provided	MR

ADW

N/12

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. F6/DFS/MS/SZ/2021/218, dated-08/09/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name Udau Ver Singh  
 Designation ADO/ADP

15/09/24  
8/9/24

CFO(S2)  
7/9/2024

Director  
Amey

Uplouder  
09/09/24  
[Signature]