

C/16

FORM 'H'  
 FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
 [Refer sub - rule (1) of rule 35]  
 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
 HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/DFS/MS/School/SZ/2024/ 877

Dated: 05/09/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of Deep Parmarth Secondary School Located at Puran Nagar, Mehrauli Road, New Delhi - 110077 comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/School/2018/SZ/2213, dated 01/010/2018. The premises was re inspected by the officer concerned of this department on 30/08/2024 in the presence of Sh. Paramjeet Singh (Admin) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi circular No: 262 – 362 dated 17/01/2005 and that the premises is fit for occupancy class B “Educational building” with effect from 05/09/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/09/2024 at New Delhi by.

  
 (Atul Garg)  
 Director  
 Delhi Fire Service.  


Copy to: -

1. The Principal, Deep Parmarth Secondary School, Puran Nagar, Mehrauli Road, New Delhi - 110077.
2. Director of Education Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building by laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired.

116  
**INSPECTION REPORT**

1. Name & address of the building: Deep Parmarth Secondary School Located at Puran Nagar, Mehrauli Road, New Delhi - 110077.
2. Type of Occupancy : Educational (Ground+ 2 UFs)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/2213, dated 01/10/2018
5. Fire Safety directives Letter No. : 262-362 dated 17/01/2005

1. Date of inspection : 30/08/2024
2. Name of the Inspecting Officer : ADO (DWK)
3. Name and designation of Officer

Total Area = 2450sqm. Covered Area = 1000 sqm, Class rooms = 25, No. of students = 900

from the building side: Sh. Paramjeet Singh (Admin)

4. Year of Construction : 2007
5. Applicant's letter No. : Email, dated 23/07/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/3, N/4 & N/5	Provided at site	Remarks MR/NMR
1.	<b>Access of building</b>			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, width, Type &amp; Arrangements of exits</b>			
	a. Number of staircases			
	• Upper floors	02 Nos.	02 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old case	Varies from 1.36 to 1.5m	MR(Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	01 mtr	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke managements System</b>			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c charge	Natural ventilation	MR

*(Handwritten signature)*







5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	01 No. for every 300 sq.mtr ABC or CO <sub>2</sub> ISI marked	24 Provided ABC & CO <sub>2</sub> ISI marked	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 No. 30 mtr 05 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm Required Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto starting/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	NA NA NA NA NA NA NA NA NA NA NA NA 450 lpm & 180 lpm 40 mtr Required Required	NA NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA NA NA NA 5000 ltr	NA NA NA NA Provided	NA NA NA NA MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2018/SZ/2213, dated 01/10/2018 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

  
 Sign of Inspecting Officer  
 Name: Udai vir Singh  
 Designation: ADO/DWK

  
  
  
 Director  
 4/9/2018