

C 32

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 878

Dated: 05/09/2024

FIRE SAFETY CERTIFICATE

Certified that the building Govt. Boys/Girls Sr. Sec. School Located at New Rohtak Road, New Delhi - 110005 comprised of Ground + 03 Upper Floors owned/occupied by Delhi Government was issued FSC vide Letter No. F6/DFS/MS/School/2021/SZ/844 dated 12/10/2021. The premises was inspected by the officers concerned of this department on 30/08/2024 in the presence of Ms. Archana Gupta (Incharge) and found that the said building have deemed complied with the fire prevention and fire safety requirements and that the premises is fit for occupancy class-B "Educational" with effect from 05/09/2024 for a period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/09/2024 at New Delhi by.


(Anul Garg)
Director
Delhi Fire Service.

Copy to:

1. The, Directorate of Education Old Secretariat Delhi - 110054
2. The Principal, Govt. Boys/Girls Sr. Sec. School Located at New Rohtak Road, New Delhi - 110005.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/21
INSPECTION REPORT

1. Name & address of the building: Govt. Boys/Girls Sr. Sec. School Located at New Rohtak Road, New Delhi - 110005.
2. Type of Occupancy : Educational (Ground + 3 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/SZ/844 dated 12/10/2021
5. Fire Safety directives Letter No. : UBL/NBC of India
6. Date of inspection : 30/08/2024
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Ms. Archana Gupta (Incharge)
9. Year of Construction : Before 2000
10. Applicant's letter No. : form J Dated 02/08/2024.

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/17, N/18 & N/19	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	12 mtr	MR
	• Gate width	4.5 mtr	5.7 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 No	02 No.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	1.85m & 119 cm (Iron staircase)	MR(Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	1 Provided	MR
	e. Width Of Corridor	1.50 mtr	Provided	MR
	f. Door Size	1.20 mtr	0.95m	MR(Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

Udai Vir Singh
-
h

N/22

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c charge	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	14 nos.	20 Nos.	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	100 mm	NA
	• Number of hydrants per floor	NA	01	NA
	• Hose Box	NA	01 No	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	2x450lpm	MR
	➤ Head of the pump	30Mtr	30 mtr	MR
	➤ Power supply	Required	Provided	MR

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2021/SZ/844 dated 12/10/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- Earlier

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation AD/DW

AD/SW
4/9/2021
 Director